



# **Prequalification Documents**

# Starline Pipe Supports and Vibration Isolators

Page 1 of 1

Head Office: Mars Complex, First Floor , 38 / 791 - Poothole Road , Thrissur , Kerala, INDIA - 680 004 Factory: Sree Sai Krithika Industrial Estate, 4 / 293 , S.F. No. 221 & 91, Seerapalayam, Podipalayam Post, Coimbatore, Tamil Nadu, INDIA - 641 105

Phone : (91) (487) 238 5001 , 238 5002 Email : purchase@starline.in





# **Manufacturer Catalogue**

Page 1 of 1

Head Office: Mars Complex, First Floor , 38 / 791 - Poothole Road , Thrissur , Kerala, INDIA - 680 004 Factory: Sree Sai Krithika Industrial Estate, 4 / 293 , S.F. No. 221 & 91, Seerapalayam, Podipalayam Post, Coimbatore, Tamil Nadu, INDIA - 641 105

Phone : (91) (487) 238 5001 , 238 5002 Email : purchase@starline.in

Book Number: 111 Dated 06-01-2025



### **Head Office:**

MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

**Factory:** 

Sree Sai Krithika Industrial Estate 4 / 293, S.F. No. 221 & 91, Sreerapalayam, Post - Podipalayam, Coimbatore, Tamil Nadu, India - 641 105

# Quality





Making a difference where it counts



S. No.	Description	Page No.
	Section A : Introduction	
01	Company Profile	A-01
02	Quality Policy	A-02
03	Health, Safety & Environment Policy	A-03
	Section B : Piping Supports	
01	Plain Split Clamp	B-01
02	Rubber Lined Split Clamp	B-03
03	Clevis Hanger	B-05
04	Clevis Hanger - Heavy Duty	B-07
05	Sprinkler Clamps	B-09
06	U Bolt	B-11
07	U Strap Clamp	B-13
08	Rubber Lined U Strap Clamp	B-17
09	Rubber Support Insert	B-21
10	Riser Clamp	B-24
11	Riser Clamps for Insulated Pipes	B-26
12	Roller Chair	B-28
13	Roller Stand	B-30
14	One Piece Channel Clip	B-32
15	Offset - Extended Clamps	B-33
16	Purlin Clamp	B-35
17	Pipe Stanchion Saddle with U Bolt	B-36
18	HI Beam Clamp	B-38
19	Universal Beam Clamp	B-40
20	Direct Weld Type Beam Clamp	B-42
21	Pipe Insulation Protection Shield	B-44
22	Vertical Riser Anchor	B-47
23	Multi Rack Pipe Roller	B-49
24	Heavy Duty Elastomeric Lined Pipe Support	B-51
25	Rigid Pipe Insulation Protection Shield	B-53
26	Cushion Clamp	B-56
	Section C : Vibration Isolators	
01	Cased Spring Mount - 25 mm and 50 mm Deflection	C-01
02	Open Spring Mount - Metal Based	C-04
03	Spring Hanger - Light Duty	C-06



R

S. No.	Description	Page No.
04	Spring Hanger - 25 mm Deflection	C-08
05	Spring Hanger - 50 mm Deflection	C-10
06	Pre Compressed Spring Hanger - 25 mm Deflection	C-12
07	Pre Compressed Spring Hanger - 50 mm Deflection	C-14
08	Combination Spring Hanger - Light Duty	C-16
09	Combination Spring Hanger - 25 mm and 50 mm Deflection	C-18
10	Elastomeric Hanger	C-21
11	Open Spring Mount-Elastomeric Based-25mm and 50mm Deflection	C-23
12	Elastomeric Round Mounts	C-26
13	Elastomeric Floor Mount	C-28
14	Elastomeric Modular Pads	C-30
15	Elastomeric Duct Mount	C-31
16	Elastomeric Multi Layer Pads	C-32
17	Restrained Spring Mount (Model: SRSM)	C-35
18	Seismic Cased Restrained Spring Mount (Internally Adjustable):	
	25 and 50 mm Deflection	C-37
19	Housed Spring Mount	C-41
20	Inertia Base Frames	C-44
21	Bellows - Industrial Stainless Steel Bellows	C-46
22	Elastomeric Floating Floor Mounts	C-49
23	Pre-Compressed Combination Spring Hangers - Light Duty	C-50
24	Pre-Compressed Hanger - Light Duty	C-52
25	Elastomeric Hanger - Light Duty	C-54



# MISSION: TO BE THE BEST FOR OUR CUSTOMERS AND THE PREFERRED SOURCE FOR PRECISION ENGINEERING COMPONENTS IN SHEET METAL, WIRE, MOLDED RUBBER AND ENGINEERING PLASTICS.

Starline Enterprises started its Business Activity in Engineering Components in the year 2005, initially as a Sourcing Organization for Precision Engineering Components addressing the Export Market.

Inspired by the support given by our Customers, and our continuing quest to deliver Quality Products to our Customers, we set up and established our own Manufacturing Unit for the Production of Pressed Sheet Metal, Wire, Engineering Plastic and Moulded Natural Rubber & Synthetic Rubber Components.

To support our Mission, we have Qualified and Experienced Engineers to extend complete Technical Support to our Customers in terms of developing products to the Customer specifications and requirements.

Our factory is fully equipped with necessary machinery including Mechanical Presses, Hydraulic Presses and Hydro Pneumatic Presses, Precision Drilling / Tapping Machines, Rubber Mill / Rubber Moulding Presses / Rubber Extruders, Powder Coating Booth and Curing Oven in addition to complete testing and measurement devices from a fully automatic 1 Ton capacity Spring Testing Machine, to Durometers for Rubber Testing and the best in measurement and weighing instruments.

At our Office end, we have Professional and fully Trained Staff to coordinate with our Customers which in turn ensures timely responses to Customer needs and constant availability of feedback to Customer demands.

We are ISO 9001 : 2015 Certified Company and follows Procedural and Documentation System which is Compliant with the standard procedures and above referred ISO.



We also serve the emerging needs of our Customers by having the services of Qualified and Competent Tool Room Engineers who can design and develop new components as per individual Customer requirement. UALITY POLICY

at Starline. We work hard to ensure Customer Satisfaction by providing high Quality Products, adhering to Customer Delivery Schedules and maintaining a successful working relationship. We put Customer's needs and expectations first. Adhering to this policy in all our departments ensures maximum value to our Customers.

Quality and Customer Satisfaction is a continuous and never ending process

Our Material Procurement Department has a well established network by which only Quality Materials from Standard Companies are procured. Before its entry into our Warehouse, they are all checked and evaluated to ensure the highest Standards of Quality. Quality Checks are done at each level of Productions which are all well Documented.

Finally the Finished Goods are checked with the Engineering Drawings once again to ensure that Quality is maintained. Only after the approval of Quality Control Department which is a Stand Alone Department, the Material gets packed for Shipment.

We are committed to Customer Satisfaction through

- Good Quality Products
- Competitive Pricing
- On Time Deliveries
- Proper Response to Queries
- Compliance





HEALTH, SAFETYAND ENVIRONMENT POLIC

We give utmost importance to Health, Safety and Environment Policy. Starline maintains its Workplace safe from Hazards and Dangerous Practices. We have given the Employees the Power to reject a job which has to be done in an Unsafe Manner with the result we have a Zero accident rate to date.

We ensure that our Employees are Healthy and injury free and also ensures that we comply with the Local Environment Regulations to achieve the following:

- 1. Promote Healthy Life Style amongst Employees.
- 2. Eliminate all Employee injuries by making the Workplace and Sites free from Hazards and Unsafe Acts.
- 3. Reduce Pollutants in the Application Processes and Site Operations.
- 4. Conserve Natural Resources by conserving Water, Electricity & other Consumables and disposal of Waste complying with the local laws.
- 5. Establish Safety and Environmental Protection Standards that comply with the Local Laws.
- 6. Employees to comply with these Standards as per their job description and Rules and Procedures of the company.

# **Piping Supports**

MEnterprises

Head Office: MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in, www.starlinesupports.com

Factory: Sree Sai Krithika Industrial Estate 4 / 293, S.F. No. 221 & 91, Sreerapalayam, Post - Podipalayam, Coimbatore, Tamil Nadu, India - 641 105





MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Plain Split Clamps

# Catalogue Number : 8000100 : Rev. 04 Dated 09-02-2017







**Dual Thread Nut** 

# SELECTION TABLE (Table No: B-01-01)

Model	Range	Size	Nominal		Dimensi	Thick	Safe		
No.		(inch)	OD (mm)	А	В	С	D	(mm)	Load (Kgs)
SPSC018	15-18	3/8	15	59	20	23	30	1.5	200
SPSC022	18-22	1/2	22	66	20	26	37	1.5	200
SPSC028	23-28	3/4	28	72	20	29	43	1.5	200
SPSC035	30-35	1	35	79	20	33	50	1.5	200
SPSC040	38-43	1 1⁄4	40	86	20	36	57	1.5	200
SPSC048	45-50	1 1/2	48	92	20	39	63	1.5	200
SPSC054	51-56		54	98	20	42	69	1.5	200
SPSC060	58-63	2	60	104	20	45	75	1.5	200
SPSC070	64-69		70	114	20	50	85	1.5	250
SPSC075	70-76	2 1/2	75	119	20	53	90	2	250
SPSC083	78-86		83	127	20	57	98	2	250
SPSC090	87-95	3	90	134	20	60	105	2	250
SPSC100	96-104	3 1/2	100	144	20	65	115	2	250
SPSC115	105-114	4	115	159	20	73	130	2	300
SPSC125	116-123		125	169	20	78	140	2	300
SPSC133	124-132		133	177	20	82	148	2	300
SPSC140	132-140	5	140	184	20	85	155	2.5	300
SPSC150	142-150		150	194	20	90	165	2.5	300
SPSC160	152-161		160	204	25	95	175	2.5	300
SPSC168	164-175	6	168	212	25	99	183	2.5	300
SPSC200	214-225	8	200	244	25	115	215	2.5	300
SPSC220	257-269		220	264	25	125	235	2.5	300
SPSC250	271-283	10	250	294	25	140	265	2.5	300
SPSC315	315-331	12	315	359	25	173	330	2.5	300

# APPLICATION (Table No: B-02-01)

		-	-	
Model No.	Steel (	SCH 40)	UPVC / PE	ABS
	Inches	mm		
SPSCC018				16
SPSCC022	1⁄2	22	20	DN15 (21.4)
SPSCC028	3⁄4	28	25	DN20 (26.8)
SPSCC035	1	35	32, 38	DN25 (33.6)
SPSCC040	1 1⁄4	42	40, 43	DN32 (42.3)
SPSCC048	1 1⁄2	48	45	DN40 (48.3)
SPSCC054			54	
SPSCC060	2	60	60	DN50 (60.4)
SPSCC063				
SPSCC070			70	
SPSCC075	2 1/2	75	75	DN65 (75.4)
SPSCC083			83	
SPSCC090	3	90	90	
SPSCC100			102	DN80 (88.9)
SPSCC110			110	
SPSCC115	4	115	115	DN100 (114.3)
SPSCC125			125	
SPSCC133			135	
SPSCC140	5	140	140	DN125 (140.2)
SPSCC150			152	
SPSCC160			160	
SPSCC168	6		168	DN150 (168.3)
SPSCC200			200	
SPSCC220	8	219	220, 225	DN200 (225.0)
SPSCC250			250	DN225 (250.4)
SPSCC315				DN300 (315.5)



# Plain Split Clamps

# . Compliance:

 1.1) Federal Specification AS-A-1192 (Type 1)
 1.2) MSS-SP58 (Type 1)
 1.3) MSS-SP69
 1.4) WW-H-171E (Type 1)
 1.5) EG-ASTMB 633 SC3, BS 1706 FE / ZN 12

2. Material : Mild Steel elctrogalvanised to 8-9 Micron thickness confirming to EG-ASTM B 633SC3

3. Application : Ceiling suspension or vertical wall mounting of piping.

# 4. Features :

- 4.1) Both clamps are ribbed for providing additional strength
- 4.2) Lips are provided with additional thread lengths by means of extended collared tap holes.
- 4.3) For pipe size, OD 100 mm and above, welded side nuts have been provided.
- 4.4) Suspension nuts have twin threads, M8, M10 for flexibility of installation.
- 4.5) Side bolts have slotted cross head for ease of tightening.

# 5. Selection / Ordering :

- 5.1) Pipe OD / pipe size plus insulation thickness.
- 5.2) Indicate if Starline Rubber Inserts are proposed to be used. (for automatic selection of clamp).
- 5.3) Hot Dip Galvanised Finish (Suffix "HDG") (Coating Thickness: 80 to 90 Microns)
- 5.4) EPDM Lined (Suffix "R")
- 5.5) Epoxy Powder Coated Finish (Suffix "P")
- 5.6) Stainless Steel Construction (Suffix "SS")

# Note:

• Due to policy of continual improvement, the specifications are subject to change without prior

# notice.

- Measurements are subject to 5% tolerance.
- To achieve good sound suppression, do not overload fitting.





MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com







Dual Thread Nut

# SELECTION TABLE (Table No: B-03-01)

Model No.	Range	Pipe OD	Nomi-	Fixing Nut		Dimer	nsion (	(mm)	Thick	Break	Safe
	(mm)	(inch)	nal OD		A	В	С	D	(mm)	Load	Load
			(mm)							(kgs)	(kgs)
SRLSC018	12-16	3/8" / 1/4"	15	M8 / M8-M10	60	20	26	36	1.5	600	200
SRLSC022	17-23	1⁄2"	22	M8 / M8-M10	65	20	29	43	1.5	600	200
SRLSC028	24-30	3⁄4"	28	M8 / M8-M10	70	20	32	50	1.5	600	200
SRLSC035	32-38	1"	35	M8 / M8-M10	85	20	36	56	1.5	600	200
SRLSC040	39-45	1 ¼"	42	M8 / M8-M10	92	20	39	63	1.5	600	200
SRLSC048	45-51	1 1⁄2"	48	M8 / M8-M10	98	20	42	72	1.5	600	200
SRLSC054	52-58		54	M8 / M8-M10	104	20	45	75	1.5	600	200
SRLSC060	58-64	2"	60	M8 / M8-M10	110	20	48	81	1.5	600	200
SRLSC063	65-71		63	M8 - M10	115	20	51	88	1.5	600	250
SRLSC075	72-81	2 1⁄2"	75	M8 - M10	125	20	56	96	2	900	250
SRLSC090	82-89	3"	90	M8 - M10	146	20	63	111	2	900	250
SRLSC100	90-98	3 ½"	100	M8 - M10	156	20	68	121	2	900	250
SRLSC110	99-108		110	M8 - M10	166	20	73	131	2	900	250
SRLSC115	110-116	4"	115	M8 - M10	171	20	78	136	2	900	300
SRLSC125	119-127		125	M10	181	20	81	146	2	900	300
SRLSC133	126-135		133	M10	184	20	85	154	2	900	300
SRLSC140	136-145	5"	140	M10	196	20	88	161	2	900	300
SRLSC150	146-156		150	M10	206	20	93	171	2	900	300
SRLSC168	158-169	6"	168	M10	224	25	102	189	2	900	300
SRLSC170	170-180		175	M10	235	25	106	195	2	900	300
SRLSC194	194-206		190	M10	245	25	110	200	2	900	300
SRLSC200	208-220	8"	200	M10 / M12	256	25	118	221	2.5	900	300
SRLSC220	225-238		220	M10 / M12	276	25	128	241	2.5	900	300
SRLSC250	247-260		250	M10 / M12	306	25	143	271	2.5	900	300
										F	age: B-03

	<u>`</u>		-	
Copper	Steel (Sch 40)		UPVC/PE	ABS
(inches)	(inches)	(mm)		
15, 18	3/8" / ¼"	16		
22	1⁄2"	22	20	DN15 (21.4)
24, 28	3⁄4"	28	25	DN20 (26.8)
35	1"	35	32, 38	DN25 (33.6)
42	1 ¼"	42	40, 43	DN32 (42.3)
	1 ½"	48	45	DN40 (48.3)
54			54	
64	2"	60	60	DN50 (60.4)
67, 70			70	
76	2 ½"	75	75	DN65 (75.4)
80			83	
	3"	90	90	
102, 105			102	DN80 (88.9)
108			110	
	4"	115	115	DN100 (114.3)
125			125	
			135	
	5"	140	140	DN125 (140.2)
			152	
159			160	
167	6"	168		DN150 (168.3)
206			200	
	8"	219	220, 225	DN200 (225.0)
	Copper (inches) 15, 18 22 24, 28 35 42 54 64 67, 70 76 80 102, 105 108 102, 105 108 125 108 125 125	Copper (inches)Steel (S (inches)15, 18 $3/8" / 1/4"$ 22 $1/2"$ 24, 28 $3/4"$ 351"42 $1 1/4"$ 42 $1 1/2"$ 54 $642"67, 70762 1/2"80102, 105$	Copper (inches)Steel (Sch 40)(inches)(inm)15, 18 $3/8" / \frac{1}{4}"$ 1622 $\frac{1}{2}2"$ 2224, 28 $\frac{3}{4}"$ 28351"3542 $1\frac{1}{4}"$ 4242 $1\frac{1}{4}"$ 42642"6067, 70176 $2\frac{1}{2}"$ 75803"90102, 1053"901084"1151255"1401595"1401676"1682068"219	Copper (inches)Steel ( $\times$ 40)UPVC/PE (inches)(inches)(mm)15, 18 $3/8" / 4/2"$ 1622 $1/2"$ 2224, 28 $3/4"$ 28351"35351"3532, 3842 $14/2"$ 42 $11/2"$ 4842 $11/2"$ 4854-54642"6067, 70-7076 $21/2"$ 7580-102102, 105-102108-110125-125126-135159-1601676"1682068"2192068"2192068"219

# (Table No: B-04-01)



# Rubber Lined Split Clamps

# 1. Compliance:

1.1 Federal Specification AS-A-1192 (Type 1)

- 1.2 MSS-SP58 (Type 1)
- 1.3 MSS-SP69
- 1.4 WW-H-171E (Type 1)
- 1.5 EG-ASTMB 633 SC3, BS 1706 FE / ZN 12

2. Material : Mild Steel elctrogalvanised to 8-9 microns confiring to EG-ASTM B 633 SC3

3. Application : Ceiling suspension or vertical wall mounting of piping.

# 4. Features :

- 4.1 High quality Rubber lining for suppression of sound and vibration.
- 4.2 Both clamps are ribbed for providing additional strength
- 4.3 Lips are provided with additional thread lengths by means of extended collared tap holes.
- 4.4 For pipe size, OD 100 mm and above, welded side nuts have been provided.
- 4.5 Suspension nuts have twin threads, M8, M10 for flexibility of installation.
- 4.5 Side bolts have slotted cross head for ease of tightening.

# $5. \hspace{0.1 cm} \textbf{Selection} \hspace{0.1 cm} / \hspace{0.1 cm} \textbf{Ordering}: \\$

- 5.1 Pipe OD / pipe size plus insulation thickness.
- 5.2 Indicate if Starline Rubber Inserts are proposed to be used. (for automatic selection of clamp).
- 5.3 Hot Dip Galvanised Finish (Suffix "HDG") (Coating Thickness: 80 to 90 Microns)
- 5.4 EPDM Lined (Suffix "R")
- 5.5 Epoxy Powder Coated Finish (Suffix "P")
- 5.6 Stainless Steel Construction (Suffix "SS")

# Note:

- Due to policy of continual improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.
- To achieve good sound suppression, do not overload fitting.





MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

Clevis Hanger Catalogue Number : 8000102 : Rev. 04 Dated 16-01-2024









# **SELECTION TABLE (Table No: CHS-160124)**

Model	UL / FM	Steel Pipe	Dimensions in mm						
		Nominal	А	В	C	D	d	Load	
					(Adjustment)			(Kg)	
CHS 13	UL	1⁄2"	51	38	15	M6	10	250	
CHS 19	UL / FM	3⁄4"	59	43	15	M6	10	250	
CHS 25	UL / FM	1"	80	60	27	M6	10	250	
CHS 30	UL / FM	1¼"	90	65	30	M6	10	250	
CHS 40	UL / FM	11/2"	103	75	36	M6	10	250	
CHS 50	UL / FM	2"	120	85	40	M6	10	250	
CHS 65	UL / FM	2½"	145	105	47	M8	12	350	
CHS 75	UL / FM	3"	170	120	57	M8	12	350	
CHS 88	UL / FM	31⁄2"	190	137	45	M8	12	350	
CHS 100	UL / FM	4"	205	145	59	M10	12	500	
CHS 125	UL / FM	5"	250	176	55	M10	12	650	
CHS 150	UL / FM	6"	280	190	55	M12	12	650	
CHS 200	UL / FM	8"	334	225	60	M16	20	950	
CHS 250		10"	400	255	60	M16	22	1150	
CHS 300		12"	460	285	60	M16	22	1700	
CHS 350		14"	510	320	65	M20	24	1700	
CHS 400		16"	565	350	70	M24	24	2200	
CHS 450		18"	650	410	100	M24	24	2200	
CHS 500		20"	725	460	100	M30	30	2400	
CHS 600		24"	840	520	100	M30	30	2700	
CHS 750		30"	1025	620	125	M36	30	3100	
CHS 900		36"	1210	730	150	M36	30	4500	





- 1.1 Federal Specification AS-A-1192 (Type 1)
- 1.2 MSS-SP58 (Type 1)
- 1.3 MSS-SP69
- 1.4 WW-H-171E (Type 1)
- 1.5 EG-ASTMB 633 SC3, BS 1706 FE / ZN 12
- 1.6 UL Listed

### 2. Application:

- 2.1 To achieve effective level installation of pipe lines.
- 2.2 Fire fighting and chilled water pipe work.
- 2.3 Independent suspension of large pipes.
- 2.4 Suspension of insulated or plain stationary piping.
- 2.5 Suitable for sound suppression in pipe lines.

### 3. **Product Features:**

- 3.1 Allows vertical level adjustment of pipe lines after installation.
- 3.2 Models CHS250 and above are fitted with steel spacer sleeve as standard.
- 3.3 Optional EPDM lined hangers are available to minimize condensation, improve noise attenuation and prevent contact between dissimilar metals.
- 3.4 Material : Mild Steel electro galvanized. Optional hot dip galvanized / stainless steel.

### **Selection / Ordering:** 4.

- 4.1 Bare piping : OD.
- 4.2 Insulated Piping : effective OD or pipe size plus insulation thickness.
- 4.3 Whether Starline Rubber Support Inserts are proposed to be used.
- 4.4 Material Specs :

EPDM lined: (Suffix "R"). Epoxy powder coated finish (Suffix "EPC"). Hot dip galvanizes (Suffix "HDG") Stainless Steel (Suffix "SS")

### 5. **Installation Guide lines:**

Suspension nuts to be provided with oversized washers and tighten properly to ensure proper hanger performance.

# **Clevis Hanger**

# Note:

• Due to policy of continual improvement, the specifications are subject to change without prior notice.



To achieve good sound suppression, do not overload fitting.





Pipe Hangers EX28297



MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Clevis Hanger - Heavy Duty

Catalogue Number : 8000110 : Rev. 01 Dated 20-02-15





# SELECTION TABLE (Table No. 200215-01)

Part No.	Pipe	Dimensions (mm)							
	Size	Upper	Lower	Rod	Bolt Size	Н	D	Load	
	Inches	Steel	Steel	Hole Size				LBS	
SCHHD13	1⁄2"	3 x 25	3 x 25	10	M8 x 60	70	22	2710	
SCHHD19	3⁄4"	3 x 25	3 x 25	10	M8 x 68	76	28	2710	
SCHHD25	1"	3 x 25	3 x 25	10	M8 x 78	82	35	2710	
SCHHD32	1-1/4"	3 x 25	3 x 25	10	M8 x 82	92	42	2710	
SCHHD38	1-1/2"	3 x 25	3 x 25	10	M8 x 88	100	48	2710	
SCHHD51	2"	3 x 25	3 x 25	10	M10 x 110	117	60	2710	
SCHHD64	2-1/2"	4 x 25	4 x 25	10	M10 x 125	146	73	5020	
SCHHD76	3"	4 x 25	4 x 25	10	M10 x 140	155	89	5020	
SCHHD89	3-1/2"	4 x 25	4 x 25	10	M10 x 155	173	105	5020	
SCHHD102	4"	6 x 32	6 x 32	10	M10 x 170	198	115	6360	
SCHHD127	5"	6 x 32	6 x 32	12	M12 x 195	232	140	6360	
SCHHD152	6"	6 x 40	5 x 40	12	M12 x 225	266	168	8630	
SCHHD203	8"	6 x 40	5 x 40	12	M12 x 275	338	219	8890	
SCHHD254	10"	6 x 40	6 x 40	16	M16 x 360	419	273	16010	
SCHHD305	12"	9 x 50	6 x 50	20	M20 x 420	490	323	16900	
SCHHD356	14"	9 x 50	6 x 50	20	M20 x 455	556	355	18680	
SCHHD406	16"	12 x 65	6 x 65	24	M24 x 510	610	406	20460	
SCHHD457	18"	12 x 65	6 x 65	24	M24 x 555	675	457	21350	
SCHHD508	20"	12 x 75	9 x 75	30	M24 x 610	715	508	21350	
SCHHD610	24"	16 x 75	9 x 75	30	M24 x 710	850	610	21350	
SCHHD762	30"	19 x 75	9 x 75	30	M24 x 890	995	755	26690	

# 1. Compliance:

- 1.1 Federal Specification AS-A-1192 (Type 1)
- 1.2 MSS-SP58 (Type 1)
- 1.3 MSS-SP69
- 1.4 WW-H-171E (Type 1)
- 1.5 EG-ASTMB 633 SC3, BS 1706 FE / ZN 12

# 2. Application:

- 2.1 To achieve effective level installation of pipe lines.
- 2.2 Fire fighting and chilled water pipe work.
- 2.3 Independent suspension of large pipes.
- 2.4 Suspension of insulated or plain stationary piping.
- 2.5 Suitable for sound suppression in pipe lines.

# 3. Product Features:

- 3.1 Allows vertical level adjustment of pipe lines after installation.
- 3.2 Models CHS250 and above are fitted with steel spacer sleeve as standard.
- 3.3 Optional EPDM lined hangers are available to minimize condensation, improve noise attenuation and prevent contact between dissimilar metals.
- 3.4 Material : Mild Steel electro galvanized. Optional hot dip galvanized / stainless steel.

### 4. Selection / Ordering:

- 4.1 Bare piping : OD.
- 4.2 Insulated Piping : effective OD or pipe size plus insulation thickness.
- 4.3 Whether Starline Rubber Support Inserts are proposed to be used.
- 4.4 Material Specs : EPDM lined: (Suffix "R"). Epoxy powder coated finish (Suffix "EPC"). Hot dip galvanizes (Suffix "HDG") Stainless Steel (Suffix "SS")

# 5. Installation Guide lines:

5.1 Suspension nuts to be provided with oversized washers and tighten properly to ensure proper hanger performance.



Clevis Hanger Heavy Duty



Note:

• Due to policy of continual improvement, the specifications are subject to change without prior notice.

• Measurements are subject to 5% tolerance.



MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Sprinkler Clamps

Catalogue Number : 8000103 : Rev. 04 Dated 16-01-2024









# SELECTION TABLE (Table No: SC-160124)

Model No.	UL / FM	Pipe Size (inches) (r) (mm)	Threaded Connection	Strip Size (mm) (H)	Height (mm) (mm)	Height Adjustment (h) Load (kgs)	Safe working
SSC022	UL	1⁄2"	10	1.2x19	54	28	150
SSC028	UL/FM	3⁄4"	10	1.2x19	61	33	150
SSC035	UL/FM	1"	10	1.2x19	68	29	150
SSC040	UL/FM	1 ¼"	10	1.2x19	75	29	150
SSC048	UL/FM	1 1⁄2"	10	1.2x19	81	29	150
SSC060	UL/FM	2"	10	1.2x19	100	36	150
SSC075	UL/FM	2 1⁄2"	10	2x24	120	40	225
SSC090	UL/FM	3"	10	2x24	135	40	225
SSC100	UL/FM	3 1/2"	10	2x24	150	44	225
SSC115	UL/FM	4"	10	2x24	165	44	225
SSC140	UL/FM	5"	12	2.5x24	195	47	300
SSC168	UL/FM	6"	12	2.5x24	230	54	300
SSC200		8"	12	2.5x24	290	62	300
SSC250		10"	12	2.5x24	345	65	300



# 1. Complince:

- 1.1 Federal Specification AS-A-1192 (Type 1)
- 1.2 MSS-SP58 (Type 1)
- 1.3 MSS-SP69
- 1.4 WW-H-171E (Type 1)
- 1.5 EG-ASTMB 633 SC3, BS 1706 FE / ZN 12
- 1.6 UL Listed

# 2. Material :

Mild Steel electro galvanized to 8 - 9 microns confirming to ASTM B633 SC3

# 3. Application :

Sprinkler system and fire extinguishing systems for free hanging of horizontal pipe lines.

# 4. Features :

- 4.1 Swivel Nuts are counter sunk to eliminate damage to threads.
- 4.2 Additional strength provided by notching of lips.
- 4.3 Knurled nut facilitates vertical adjustment of pipe levels after installation.
- 4.4 One piece clip guarantees high permissible load.
- 4.5 Mounting possible without any additional tooling.

# 5. Selection / Ordering :

- 5.1 Hot Dip Galvanised finish (suffix "HDG")
- 5.2 EPDM Lined (suffix "R").
- 5.3 Epoxy Powder Coated Finish (suffix "P")
- 5.4 Stainless Steel Construction (suffix "SS")





# Sprinkler Clamps

# Starline

# Note:

- Due to policy of continual improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.

Starline Enterprises

MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com







# **SELECTION TABLE (Table No: B-09-01)**

Model No.	Size	Threaded	Dimensions (mm)				
		Connection	Х	Y	Z		
SUB022	1⁄2"	M6	21	42	25		
SUB028	3⁄4"	M6	27	48	25		
SUB035	1"	M6	34	54	25		
SUB042	1 ¼"	M6	43	62	25		
SUB048	1 ½"	M8	48	75	35		
SUB060	2"	M8	60	87	35		
SUB075	2 1⁄2"	M8	76	103	35		
SUB090	3"	M10	89	122	45		
SUB115	4"	M10	115	148	45		
SUB140	5"	M12	140	180	50		
SUB160	6"	M12	168	205	50		
SUB219	8"	M12	219	260	50		
SUB273	10"	M16	273	324	70		
SUB324	12"	M16	324	375	70		
SUB356	14"	M16	356	407	70		
SUB406	16"	M16	406	458	70		
SUB457	18"	M20	457	522	85		
SUB508	20"	M20	508	573	85		
SUB558	22"	M20	559	624	85		
SUB610	24"	M20	610	675	85		
SUB660	26"	M24	664	738	100		
SUB710	28"	M24	716	789	100		
SUB762	30"	M24	767	840	100		
SUB915	36"	M24	920	995	100		

### 1. **Compliance:**

- 1.1 Federal Specification AS-A-1192 (Type 1)
- 1.2 MSS-SP58 (Type 1)
- 1.3 MSS-SP69
- 1.4 WW-H-171E (Type 1)
- 1.5 EG-ASTMB 633 SC3, BS 1706 FE / ZN 12

### 2. Material :

- 2.1 Mild Steel, Stainless Steel, Brass
- 2.2 Coating options for Mild Steel:
  - 2.2.1 Electro galvanized to 8-9 microns conforming to EG ASTM B633 SC3.
  - 2.2.2 Hot Dip Galvanised. Coating Thickness minimum 90 microns. Threaded end will be retapped and special coating applied to prevent rusting.
  - 2.2.3 Rubber Moulded Lining in Natural Rubber, EPDM, Nitrile Rubber etc.
  - 2.2.4 Rubber Sleeve Lining in Natural Rubber, EPDM, Nitrile Rubber etc.
  - 2.2.5 Epoxy Coating

# Application : Clamping plain or insulated pipes to standard channel supports such as trapeze hangers, floor stands and wall brackets.

### 4. Features:

3.

Full range of intermediate sizes available to ensure a simple and effective support and clamping arrangement for insulated / non insulated piping.

### 5. Selection / Ordering:

- 5.1 Bare piping : OD.
- 5.2 Insulated Piping : Effective OD or pipe size plus insulation thickness.
- 5.3 If Starline Rubber Support Inserts are proposed to be used, then Model Number of Starline Rubber Support.
- 5.4 Material Specs :
  - 5.4.1 EPDM lined: (Suffix "R").
  - 5.4.2 Epoxy powder coated finish (Suffix "EPC").
  - 5.4.3 Hot dip galvanized (Suffix "HDG")

To achieve good sound suppression, do not overload fitting.

5.4.4 Stainless Steel (Suffix "SS")

Measurements are subject to 5% tolerance.

### Note:

• Due to policy of continual improvement, the specifications are subject to change without prior notice.









MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# U Strap Clamps Catalogue Number : 8000105 : Rev. 02 Dated 09-02-2017





# DIMENSIONAL DATA FOR U-STRAP CLAMP (Table No: B-11-01)

Model	Size	D	А	В	d	С
		(mm)	(mm)	(mm)	Bolt Size	Strip Size(mm)
SUSC022	1⁄2"	22	79	54	M8	25x2
SUSC028	3⁄4"	28	85	60	M8	25x2
SUSC035	1"	35	92	67	M8	25x2
SUSC042	1 1⁄4"	42	99	74	M8	25x2
SUSC048	1 1⁄2"	48	106	81	M8	25x2
SUSC054		54	112	87	M8	25x2
SUSC060	2"	60	118	93	M8	25x2
SUSC067		67	125	100	M8	25x2
SUSC075	2 1⁄2"	75	146	116	M10	25x3
SUSC082		82	151	121	M10	25x3
SUSC086		86	157	127	M10	25x3
SUSC090	3"	90	160	130	M10	25x3
SUSC094		94	164	134	M10	25x3
SUSC100	3 ½"	100	172	142	M10	25x3
SUSC105		105	177	147	M10	25x3
SUSC110		110	182	152	M10	25x3
SUSC115	4"	115	187	157	M10	25x3
SUSC120		120	192	162	M10	25x3
SUSC126		126	198	168	M10	25x3
SUSC133		133	202	172	M10	25x3
SUSC137		137	206	176	M10	25x3
SUSC142		142	213	183	M10	25x3
SUSC148		148	219	189	M10	25x3
SUSC155		155	226	196	M10	25x3
SUSC161		161	233	203	M10	25x3
SUSC167	6"	167	240	210	M10	25x3
SUSC173		173	246	216	M10	25x3
SUSC179		179	250	220	M10	25x3
SUSC185		185	257	227	M10	38x3
SUSC190		190	262	232	M10	38x3

Model	Size	D	А	В	d	С
		(mm)	(mm)	(mm)	Bolt Size	Strip Size(mm)
SUSC198		198	270	240	M10	38x3
SUSC205		205	275	245	M10	38x3
SUSC212		212	281	251	M10	38x3
SUSC219	8"	219	288	258	M10	38x3
SUSC223		223	295	265	M10	38x3
SUSC230		230	300	270	M10	38x3
SUSC241		241	340	300	M12	38x4
SUSC259		259	356	316	M12	38x4
SUSC263		263	363	323	M12	38x4
SUSC273	10"	273	368	328	M12	38x4
SUSC285		285	380	340	M12	38x4
SUSC295		295	392	352	M12	38x4
SUSC315		315	412	372	M12	38x4
SUSC323	12"	323	420	380	M12	38x4
SUSC338		338	434	394	M12	38x4
SUSC345		345	446	406	M12	38x4
SUSC356	14"	356	473	423	M16	50x4
SUSC374		374	491	441	M16	50x4
SUSC387		387	506	456	M16	50x4
SUSC400		400	518	468	M16	50x4
SUSC406	16"	406	524	474	M16	50x4
SUSC420		420	541	491	M16	50x4
SUSC432		432	550	500	M16	50x4
SUSC450		450	567	517	M16	50x4
SUSC456	18"	456	574	524	M16	50x5
SUSC470		470	591	541	M16	50x5
SUSC482		482	600	550	M16	50x5
SUSC508	20"	508	624	574	M16	50x5
SUSC521		521	639	589	M16	50x5
SUSC533	10	533	651	601	M16	50x5
SUSC559	11	559	676	626	M16	50x5
SUSC572		572	690	640	M16	50x5
SUSC583	11	583	702	652	M16	50x5
SUSC610	24"	610	726	676	M16	50x5
SUSC634		634	762	712	M16	50x6
SUSC660		660	788	738	M16	50x6



U Strap Clamps

# 1. Compliance:

- 1.1 Federal Specification AS-A-1192 (Type 1)
- 1.2 MSS-SP58 (Type 1)
- 1.3 MSS-SP69
- 1.4 WW-H-171E (Type 1)
- $1.5 \quad \text{EG-ASTMB 633 SC3, BS 1706 FE} \ / \ \text{ZN 12}$





- Due to policy of continual improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.



# U Strap Clamps

# Selection for Common Pipe / Insulation Sizes (Table No: B-13-01)

Steel Pipe Nominal	Clamp Model for Insulation / RSI Thickness							
	Bare Pipe	19 mm	25 mm	32 mm	38 mm	50 mm		
1⁄2"	SUSC022	SUSC060	SUSC075	SUSC086	SUSC100	SUSC120		
3⁄4"	SUSC028	SUSC067	SUSC082	SUSC094	SUSC105	SUSC126		
1"	SUSC035	SUSC075	SUSC086	SUSC100	SUSC110	SUSC137		
1 ¼"	SUSC042	SUSC082	SUSC094	SUSC105	SUSC120	SUSC142		
1 ½"	SUSC048	SUSC086	SUSC100	SUSC115	SUSC126	SUSC148		
2"	SUSC060	SUSC100	SUSC110	SUSC126	SUSC137	SUSC161		
2 <sup>1</sup> /2"	SUSC075	SUSC115	SUSC126	SUSC142	SUSC155	SUSC175		
3"	SUSC090	SUSC126	SUSC142	SUSC155	SUSC167	SUSC190		
4"	SUSC115	SUSC155	SUSC167	SUSC179	SUSC190	SUSC219		
5"	SUSC142	SUSC179	SUSC190	SUSC205	SUSC219	SUSC241		
6"	SUSC167	SUSC205	SUSC219	SUSC230	SUSC241	SUSC273		
8"	SUSC219		SUSC273	SUSC285	SUSC295	SUSC323		
10"	SUSC273		SUSC323	SUSC338	SUSC345	SUSC374		
12"	SUSC323		SUSC374	SUSC387	SUSC400	SUSC420		
14"	SUSC356		SUSC406	SUSC420	SUSC432	SUSC456		
16"	SUSC406		SUSC456	SUSC470	SUSC482	SUSC508		
18"	SUSC456		SUSC508	SUSC521	SUSC533	SUSC559		
20"	SUSC508		SUSC559	SUSC572	SUSC583	SUSC610		

# 2. Material:

Mild Steel Electro galvanized to 8 - 9 microns confirming to EG ASTM B633 SC3

# 3. Application:

Clamping plain or insulated pipes to standard channel supports such as trapeze hangers, floor stands and wall brackets.

# 4. Features:

Slotted mounting holes for convenient installation. Intermediate sizes available to ensure tight installation.

# 5. Selection / Ordering:

- 5.1 Hot Dip Galvanised Finish (Suffix "HDG")
- 5.2 EPDM Lined (Suffix "R")
- 5.3 Epoxy Powder Coated Finish (Suffix "P")
- 5.4 Stainless Steel Construction (Suffix "SS")





U Strap Clamps

# U Strap Clamp : Selection Table : for PVC and CPVC Pipes - Schedule 40 (Table Number : 29122015-01)

<b>PVC and CPVC Pipes - Schedule</b> 40								
Model No.	Nominal Pipe Size	OD (inches)	Min. Wall Thickness	ID(inches)	Weight(lb/ft)			
	(inches)	()	(inches)		PVC	CPVC		
SUSCPVC00840	1⁄2	0.840	0.109	0.622	0.16	0.17		
SUSCPVC01050	3⁄4	1.050	0.113	0.824	0.21	0.23		
SUSCPVC01315	1	1.315	0.133	1.049	0.32	0.34		
SUSCPVC01660	1 1⁄4	1.660	0.140	1.380	0.43	0.46		
SUSCPVC01900	1 1⁄2	1.900	0.145	1.610	0.51	0.55		
SUSCPVC02375	2	2.375	0.154	2.067	0.68	0.74		
SUSCPVC02875	2 1/2	2.875	0.203	2.469	1.07	1.18		
SUSCPVC03500	3	3.500	0.216	3.068	1.41	1.54		
SUSCPVC04500	4	4.500	0.237	4.026	2.01	2.20		
SUSCPVC05563	5	5.563	0.258	5.047	2.73	2.84		
SUSCPVC06625	6	6.625	0.280	6.065	3.53	3.86		
SUSCPVC08625	8	8.625	0.322	7.981	5.39	5.81		
SUSCPVC10750	10	10.750	0.365	10.020	7.55	8.24		
SUSCPVC12750	12	12.750	0.406	11.938	10.01	10.89		
SUSCPVC14000	14	14.000	0.438	13.124	11.80	12.90		
SUSCPVC16000	16	16.000	0.500	15.000	15.43	16.90		

### Note:

• Due to policy of continual improvement, the specifications are subject to change without prior notice.



• Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.



MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Rubber Lined U Strap Clamps Catalogue Number : 8000105 : Rev. 01 Dated 07-10-2014



# DIMENSIONAL DATA FOR RUBBER LINED U-STRAP CLAMP (Table No: B-11-01)

Model	Size	D	А	В	d	С
		(mm)	(mm)	(mm)	Bolt Size	Strip Size(mm)
SUSC022R	1⁄2"	22	79	54	M8	25x2
SUSC028R	3⁄4"	28	85	60	M8	25x2
SUSC035R	1"	35	92	67	M8	25x2
SUSC042R	1 1⁄4"	42	99	74	M8	25x2
SUSC048R	1 1⁄2"	48	106	81	M8	25x2
SUSC054R		54	112	87	M8	25x2
SUSC060R	2"	60	118	93	M8	25x2
SUSC067R		67	125	100	M8	25x2
SUSC075R	2 1/2"	75	146	116	M10	25x3
SUSC082R		82	151	121	M10	25x3
SUSC086R		86	157	127	M10	25x3
SUSC090R	3"	90	160	130	M10	25x3
SUSC094R		94	164	134	M10	25x3
SUSC100R	3 1⁄2"	100	172	142	M10	25x3
SUSC105R		105	177	147	M10	25x3
SUSC110R		110	182	152	M10	25x3
SUSC115R	4"	115	187	157	M10	25x3
SUSC120R		120	192	162	M10	25x3
SUSC126R		126	198	168	M10	25x3
SUSC133R		133	202	172	M10	25x3
SUSC137R		137	206	176	M10	25x3
SUSC142R		142	213	183	M10	25x3
SUSC148		148	219	189	M10	25x3
SUSC155R		155	226	196	M10	25x3
SUSC161R		161	233	203	M10	25x3
SUSC167R	6"	167	240	210	M10	25x3
SUSC173R		173	246	216	M10	25x3
SUSC179R		179	250	220	M10	25x3
SUSC185R		185	257	227	M10	38x3
SUSC190R		190	262	232	M10	38x3

Model	Size	D	Α	В	d	C
		(mm)	(mm)	(mm)	Bolt Size	Strip Size(mm)
SUSC198R		198	270	240	M10	38x3
SUSC205R		205	275	245	M10	38x3
SUSC212R		212	281	251	M10	38x3
SUSC219R	8"	219	288	258	M10	38x3
SUSC223R		223	295	265	M10	38x3
SUSC230R		230	300	270	M10	38x3
SUSC241R		241	340	300	M12	38x4
SUSC259R		259	356	316	M12	38x4
SUSC263R		263	363	323	M12	38x4
SUSC273R	10"	273	368	328	M12	38x4
SUSC285R		285	380	340	M12	38x4
SUSC295R		295	392	352	M12	38x4
SUSC315R		315	412	372	M12	38x4
SUSC323R	12"	323	420	380	M12	38x4
SUSC338R		338	434	394	M12	38x4
SUSC345R		345	446	406	M12	38x4
SUSC356R	14"	356	473	423	M16	50x4
SUSC374R		374	491	441	M16	50x4
SUSC387R		387	506	456	M16	50x4
SUSC400R		400	518	468	M16	50x4
SUSC406R	16"	406	524	474	M16	50x4
SUSC420R		420	541	491	M16	50x4
SUSC432R		432	550	500	M16	50x4
SUSC450R		450	567	517	M16	50x4
SUSC456R	18"	456	574	524	M16	50x5
SUSC470R	1	470	591	541	M16	50x5
SUSC482R	1	482	600	550	M16	50x5
SUSC508R	20"	508	624	574	M16	50x5
SUSC521R	1	521	639	589	M16	50x5
SUSC533R		533	651	601	M16	50x5
SUSC559R		559	676	626	M16	50x5
SUSC572R		572	690	640	M16	50x5
SUSC583R		583	702	652	M16	50x5
SUSC610R	24"	610	726	676	M16	50x5
SUSC634R		634	762	712	M16	50x6
SUSC660R		660	788	738	M16	50x6



# **Rubber Lined U Strap Clamps**

# 1. Compliance:

- 1.1 Federal Specification AS-A-1192 (Type 1)
- 1.2 MSS-SP58 (Type 1)
- 1.3 MSS-SP69
- 1.4 WW-H-171E (Type 1)
- $1.5 \quad \text{EG-ASTMB 633 SC3, BS 1706 FE} \ / \ \text{ZN 12}$

# 3

# Note:

- Due to policy of continual improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.
- To achieve good sound suppression, do not overload fitting.



# Rubber Lined U Strap Clamps

# Selection for Common Pipe / Insulation Sizes (Table No: B-13-01)

Steel Pipe Nominal	Clamp Model for Insulation / RSI Thickness							
	Bare Pipe	19 mm	25 mm	32 mm	38 mm	50 mm		
1⁄2"	SUSC022R	SUSC060R	SUSC075R	SUSC086R	SUSC100R	SUSC120R		
3⁄4"	SUSC028R	SUSC067R	SUSC082R	SUSC094R	SUSC105R	SUSC126R		
1"	SUSC035R	SUSC075R	SUSC086R	SUSC100R	SUSC110R	SUSC137R		
1 ¼"	SUSC042R	SUSC082R	SUSC094R	SUSC105R	SUSC120R	SUSC142R		
1 ½"	SUSC048R	SUSC086R	SUSC100R	SUSC115R	SUSC126R	SUSC148R		
2"	SUSC060R	SUSC100R	SUSC110R	SUSC126R	SUSC137R	SUSC161R		
2 ½"	SUSC075R	SUSC115R	SUSC126R	SUSC142R	SUSC155R	SUSC175R		
3"	SUSC090R	SUSC126R	SUSC142R	SUSC155R	SUSC167R	SUSC190R		
4"	SUSC115R	SUSC155R	SUSC167R	SUSC179R	SUSC190R	SUSC219R		
5"	SUSC142R	SUSC179R	SUSC190R	SUSC205R	SUSC219R	SUSC241R		
6"	SUSC167R	SUSC205R	SUSC219R	SUSC230R	SUSC241R	SUSC273R		
8"	SUSC219R		SUSC273R	SUSC285R	SUSC295R	SUSC323R		
10"	SUSC273R		SUSC323R	SUSC338R	SUSC345R	SUSC374R		
12"	SUSC323R		SUSC374R	SUSC387R	SUSC400R	SUSC420R		
14"	SUSC356R		SUSC406R	SUSC420R	SUSC432R	SUSC456R		
16"	SUSC406R		SUSC456R	SUSC470R	SUSC482R	SUSC508R		
18"	SUSC456R		SUSC508R	SUSC521R	SUSC533R	SUSC559R		
20"	SUSC508R		SUSC559R	SUSC572R	SUSC583R	SUSC610R		

# 2. Material:

Mild Steel Electro galvanized to 8 - 9 microns confirming to EG ASTM B633 SC3

# 3. Application:

Clamping plain or insulated pipes to standard channel supports such as trapeze hangers, floor stands and wall brackets.

# 4. Features:

Slotted mounting holes for convenient installation. Intermediate sizes available to ensure tight installation.

# 5. Selection / Ordering:

- 5.1 Hot Dip Galvanised Finish (Suffix "HDG")
- 5.2 EPDM Lined (Suffix "R")
- 5.3 Epoxy Powder Coated Finish (Suffix "P")
- 5.4 Stainless Steel Construction (Suffix "SS")





# Rubber Lined U Strap Clamp : Selection Table : for PVC and CPVC Pipes - Schedule 40 (Table Number : 29122015-01)

<b>PVC and CPVC Pipes - Schedule</b> 40									
Model No.	Nominal Pipe Size	OD (inches)	Min. Wall Thickness	Min. Wall ID(inches) Weig		t(lb/ft)			
	(inches)	()	(inches)		PVC	CPVC			
SUSCPVC00840R	1/2	0.840	0.109	0.622	0.16	0.17			
SUSCPVC01050R	3⁄4	1.050	0.113	0.824	0.21	0.23			
SUSCPVC01315R	1	1.315	0.133	1.049	0.32	0.34			
SUSCPVC01660R	1 1⁄4	1.660	0.140	1.380	0.43	0.46			
SUSCPVC01900R	1 1/2	1.900	0.145	1.610	0.51	0.55			
SUSCPVC02375R	2	2.375	0.154	2.067	0.68	0.74			
SUSCPVC02875R	2 1/2	2.875	0.203	2.469	1.07	1.18			
SUSCPVC03500R	3	3.500	0.216	3.068	1.41	1.54			
SUSCPVC04500R	4	4.500	0.237	4.026	2.01	2.20			
SUSCPVC05563R	5	5.563	0.258	5.047	2.73	2.84			
SUSCPVC06625R	6	6.625	0.280	6.065	3.53	3.86			
SUSCPVC08625R	8	8.625	0.322	7.981	5.39	5.81			
SUSCPVC10750R	10	10.750	0.365	10.020	7.55	8.24			
SUSCPVC12750R	12	12.750	0.406	11.938	10.01	10.89			
SUSCPVC14000R	14	14.000	0.438	13.124	11.80	12.90			
SUSCPVC16000R	16	16.000	0.500	15.000	15.43	16.90			

### Note:

• Due to policy of continual improvement, the specifications are subject to change without prior notice.



• Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.



MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# **Rubber Support Insert**

Catalogue Number : 8000106 : Rev. 03 Dated 28-10-2015







# TEST STANDARDS (Table No: B-14-01)

Sl.	Physical Properties	Test	Unit	Specification		
No.		Standard				
01	Hardness	ISO 7619	Shore A	85 +/- 3		
02	Specific Gravity		g/cm <sup>3</sup>	(1.3 +/- 0.1)*		
03	Tear Strength	ASTM D 624	Kgs/cm	22 min		
04	Applicable Temp.	Range -30 deg to 80 deg				
05	Other Properties	Excelle	ent resistance	e to water,		
		mild	acid and alk	alis		
06	Tensile Strength	ISO 37	Kgs/cm <sup>2</sup>	52 minium		
07	Thermal		w/mºC	0.16		
	Conductivity					

- \* Optionally 1.6 g/cm<sup>3</sup> available on Request
- Fire Resistant Grade also available on Request

# 1. Compliance:

British Standards, BS 3974 : Part I

### 2. Material :

Compounded Rubber

# 3. Application :

Effective means of preventing crushing of insulation at pipe support points of chilled water, condenser water and domestic hot / cold water installation.



# **Rubber Support Insert**

### 4. Features :

- 4.1 Dimensional accuracy is ensured since each set is individually machine moulded.
- 4.2 Green Product.
- 4.3 Product is extremely rigid. Hence resistant to deterioration over a period of time.
- 4.4 Unlike wood, material is non corrosive.
- 4.5 Lower installation cost due to lack of requirement of additional metal sheets for wider load distribution.
- 4.6 Termite control not required.
- 4.7 Tongue and groove arrangement between RSI inserts saves labour cost and time.
- 4.8 Rubber pipe supports also provide an acoustic barrier against transmission of high frequencies.
- 4.9 Rubber support inserts are available for all pipe size and insulation thickness and are integrated with our various type of pipe supports to ensure fast and quality pipe installation.
- 4.10 Density: 1100-1400 Kg / M<sup>3</sup>
- 4.11 Temperature resistance: 20°C 120°C

### 5. Selection / Ordering :

- 5.1 Nominal pipe size, Pipe OD and insulation thickness.
- 5.2 Refer table for details.



# **RUBBER SUPPORT INSERT**

# SELECTION TABLE (Table No.: B-16-01)

Pipe Size		Pipe	Size	Standard Width
Steel ( Nominal )	Part No.	Copper (OD)	Part No.	
		16 mm	RSIC16	25 mm
1/2"	RSIS21	22 mm	RSIC22	25 mm
3⁄4"	RSIS27	28 mm	RSIC28	25 mm
	RSIS33	35 mm	RSIC35	25 mm
1 1/4"	RSIS42	42 mm	RSIC42	25 mm
11/2"	RSIS48			25 mm
		54 mm	RSIC54	25 mm
2"	RSIS60			25 mm
		67 mm	RSIC67	25 mm
		73 mm	RSIC73	38 mm
21⁄2"	RSIS73	76 mm	RSIC76	38 mm
		80 mm	RSIC80	38 mm
3"	RSIS89			38 mm
		105 mm	RSIC105	38 mm
		108 mm	RSIC108	38 mm
4"	RSIS114			50 mm
5"	RSIS141	140 mm	RSIC140	50 mm
		156 mm	RSIC156	50 mm
		159 mm	RSIC159	50 mm
6"	RSIS168			50 mm
		168 mm	RSIC168	50 mm
8"	RSIS219	219 mm	RSIC219	50 mm
10"	RSIS273			50 mm
12"	RSIS324			50 mm
14"	RSIS356			50 mm
16"	RSIS406			75 mm
18"	RSIS457			75 mm
20"	RSIS508			100 mm
24"	RSIS610			100 mm
30"	RSIS762			100 mm
36"	RSIS914			100 mm
40"	RSIS1016			100 mm

### Note:

- Due to policy of continual improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.





MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com







# **SELECTION TABLE (Table No: B-17-01)**

Part No.	Pipe Size	Length	Metal Size (mm)	Bolt Size	Max Load
		(L)	(E)		Kgs
SRC022	1⁄2"	200	4x25	M10	80
SRC028	3⁄4"	210	4x25	M10	90
SRC035	1"	230	4x25	M10	100
SRC040	1 1⁄4"	260	4x25	M10	120
SRC048	1 1⁄2"	260	4x25	M10	120
SRC060	2"	260	4x25	M10	150
SRC075	2 1⁄2"	290	4x38	M12	200
SRC090	3"	290	4x38	M12	250
SRC100	3 1/2"	330	4x38	M12	350
SRC115	4"	330	4x38	M12	350
SRC140	5"	350	6x38	M16	550
SRC168	6"	380	6x38	M16	700
SRC220	8"	470	8x38	M16	900
SRC273	10"	520	10x50	M16	1100
SRC323	12"	580	12x50	M20	1100
SRC355	14"	610	12x50	M20	1600
SRC406	16"	660	16x60	M20	1600
SRC457	18"	710	16x60	M20	1900
SRC508	20"	760	16x60	M20	1900
SRC610	24"	880	16x75	M20	2400
SRC762	30"	1040	16x75	M20	2400
SRC915	36"	1210	16x100	M25	3200

# 1. Compliance:

- 1.1 Federal Specification AS-A-1192 (Type 1)
- 1.2 MSS-SP58 (Type 1)
- 1.3 MSS-SP69
- 1.4 WW-H-171E (Type 1)
- 1.5 EG-ASTMB 633 SC3, BS 1706 FE / ZN 12

# 2. Material:

Mild Steel Electrogalvanised to 8-9 microns confirming to EG-ASTM B 633 SC3

# 3. Application:

Guide and provide rigid support and ensuring stability under large lateral load for all types of vertical piping.

# 4. Features:

When used as pipe guides, lateral stability is ensured while permitting axial thermal expansion / contraction.

# 5. Selection / Ordering:

- 5.1 Pipe OD and material plus insulation thickness.
- 5.2 Hot Dip Galvanised Finish (Suffix "HDG")
- 5.3 EPDM Lined (Suffix "R")
- 5.4 Epoxy Powder Coated Finish (Suffix "P")
- 5.5 Stainless Steel Construction (Suffix "SS")



**Riser** Clamp

### Note:

• Due to policy of continual improvement, the specifications are subject to change without prior notice.



Measurements are subject to 5% tolerance.
To achieve good sound suppression, do not overload fitting.

Starline Enterprises

MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Riser Clamp for Insulated Pipes

Catalogue Number : 8000129 : Rev. 01 Dated 22-11-2014

# 1. Compliance:

- 1.1 Federal Specification AS-A-1192 (Type 1)
- 1.2 MSS-SP58 (Type 1)
- 1.3 MSS-SP69
- 1.4 WW-H-171E (Type 1)
- 1.5 EG-ASTMB 633 SC3, BS 1706 FE / ZN 12

# 2. Material:

Mild Steel Electrogalvanised to 8-9 microns conforming to EG-ASTM B 633 SC3.

# 3. Application:

Widely used for vertical risers carrying Hot water, Chilled Water, Cold water, Refrigerants, Dual Temperature, Steam, Air, Gas and Vacuum.

# 4. Features:

- 4.1 Available on all Pipe Sizes
- 4.2 Easy Installation
- 4.3 Positive Load Transfer : Axially Downward
- 4.4 Insulating Structural Inserts for Piping installation
- 4.5 Eliminate Condensation Sweating on Chilled water risers.
- 4.6 Top and Bottom plates provide rigid support and ensuring slip free stability under large lateral loads and shock loads for all type of vertical piping.

# 5. Selection / Ordering:

- 5.1 Pipe OD and material plus insulation thickness.
- 5.2 Hot Dip Galvanised Finish (Suffix "HDG")
- 5.3 EPDM Lined (Suffix "R")
- 5.4 Epoxy Powder Coated Finish (Suffix "P")
- 5.5 Stainless Steel Construction (Suffix "SS")
- 5.6 Copper plate construction (Suffix "Cu")





# SELECTION TABLE - RISER CLAMP FOR INSULATED PIPES (Table Number : 22112014-01)

Part No.	Pipe Size	Length (mm)	Metal Size (mm)	Bolt Size	Max Load (Kgs)
RCFIP022	1⁄2"	200	4x25	M10	80
RCFIP028	3⁄4"	210	4x25	M10	90
RCFIP035	1"	230	4x25	M10	100
RCFIP040	1 1⁄4"	260	4x25	M10	120
RCFIP048	1 1⁄2"	260	4x25	M10	120
RCFIP060	2"	260	4x25	M10	150
RCFIP075	2 1⁄2"	290	4x38	M12	200
RCFIP090	3"	290	4x38	M12	250
RCFIP100	3 1/2"	330	4x38	M12	350
RCFIP115	4"	330	4x38	M12	350
RCFIP140	5"	350	6x38	M16	550
RCFIP168	6"	380	6x38	M16	700
RCFIP220	8"	470	8x38	M16	900
RCFIP273	10"	520	10x50	M16	1100
RCFIP323	12"	580	12x50	M20	1100
RCFIP355	14"	610	12x50	M20	1600
RCFIP406	16"	660	16x60	M20	1600
RCFIP457	18"	710	16x60	M20	1900
RCFIP508	20"	760	16x60	M20	1900
RCFIP610	24"	880	16x75	M20	2400
RCFIP762	30"	1040	16x75	M20	2400
RCFIP915	36"	1210	16x100	M25	3200



• Due to policy of continuus improvement, the specifications are subject to change without prior notice.


Starline Enterprises

MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Roller Chair (SPRC)

Catalogue Number : 8000108 : Rev. 01 Dated 19-02-2015



# SELECTION TABLE (Table No: RC42-1)

Model	Pipe		Dimensions					Max. Load
	Dia	W	А	Е	С	Material	D	(Kg)
SPRC 50	2"	110	80	35	40	6 x 32	13	360
SPRC 75	3"	145	100	50	45	6 x 32	13	360
SPRC 100	4"	180	120	50	50	8 x 38	16	520
SPRC 125	5"	215	135	75	50	8 x 38	16	520
SPRC 150	6"	250	160	80	60	10 x 50	16	520
SPRC 200	8"	285	205	85	75	10 x 50	20	1250
SPRC 250	10"	345	245	130	90	12 x 50	20	1250
SPRC 300	12"	395	295	140	105	12 x 50	20	1600
SPRC 350	14"	440	330	165	120	12 x 60	24	1600
SPRC 400	16"	480	375	210	140	12 x 75	24	3600
SPRC 450	18"	525	420	235	155	12 x 75	24	3600
SPRC 500	20"	555	450	260	165	12 x 75	24	3600
SPRC 600	24"	665	540	310	200	16 x 100	24	5300
SPRC 750	30"	690	615	310	200	20 x 100	24	7400
SPRC 900	36"	840	695	310	200	20 x 100	24	7400

#### 1 Compliance

- 1.1 Conforming to MSS-SP69, MSS-SP58(Type 44), BS 3974:part1, Federal Specifications WW-H-171E & A-A-1192A Type 45
- 1.2 EG to ASTM B633SC3, BS 1706 FE/ZN12

#### 2. Application

2.1 The roller chairs are used for long horizontal pipe lines which are subjected for temperature fluctuations. These are designed to compensate longitudinal movement of pipe line due to expansion or contraction of both insulated and non-insulated piping. These rollers are typically used in large district cooling/ heating plant distribution piping, process pipe lines boilers piping etc.

#### 3. Product Features

- 3.1 Starline roller chairs are made from solid steel iron rollers for rigid pipe supporting.
- 3.2 The rollers are available in wide range of material specification
  - 3.2.1 Fully electrogalvanized cast iron rollers are standard.
  - 3.2.2 Stainless steel roller chair (suffix "SS")
  - 3.2.3 Nylon roller chair (suffix "NL")
  - 3.2.4 Hot dip galvanized roller chair(suffix "HDG")
  - 3.2.5 Epoxy powder coated roller chair (suffix "EP")
- 3.3 The roller pin and rods are made from high tensile steel fully electrogalvanized as standard / hot dip galvanized as optional.
- 3.4 Optional pipe guide assembly shall be provided to protect the piping in case of water hammer and external vibrations.
- 4. Note:Insulation protection shied/saddle shall be used under insulation to support insulated piping.



#### Roller Chair (SPRC)



Optional Pipe Guide Assembly

#### Note:

• Due to policy of continual improvement, the specifications are subject to change without prior notice.



- Measurements are subject to 5% tolerance.
- To achieve results, do not overload.



MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# **Roller Stand**

Catalogue Number : 8000109 : Rev. 01 Dated 19-02-15



# SELECTION TABLE (Table No: RS190215-01)

Model	Steel		Dimensions (mm)						Max	Trad
	Nominal	H*	W	А	В	C	Е	F	d	(kg)
SRS4-6	4"	120								
	5"	136	160	150	50	115	135	100	16	520
	6"	152								
SRS8-10	8"	213	235	215	80	160	165	110	20	1250
	10"	242	235	215	00	100	105	110	20	1230
SRS12-14	12"	283	300	275	92	220	200	145	20	1600
	14"	302	500	215	2					
SRS16-20	16"	340								
	18"	368	340	310	100	245	215	150	24	3600
	20"	396								
SRS22-24	24"	455	390	340	110	265	240	165	24	5300
SRS26-30	30"	545	470	430	118	345	270	185	28	7400
SRS32-34	34"	605	490	465	123	380	285	200	28	7400
SRS36-42	36"	635	540	500	125	415	300	215	28	10300
	42"	720	510	500	125	115	500	215	20	10500
SRS48-54	48"	800	580	550	135	465	330	245	28	13100
	54"	880	200	220	100				20	10100
SRS60-66	60"	970	620	600	155	500	375	275	35	19300
l	66"	1046	020	000	100				55	1,200

\* Dimension 'H' may vary marginally depending upon the effective OD of supported pipe.

· For insulated pipe, please select the Roller Stand Model based on effective pipe OD.

#### 1. Compliance

- 1.1 Conforming to MSS-SP69, MSS-SP58(Type 44), BS 3974:part1, Federal Specifications WW-H-171E & A-A-1192A Type 45
- 1.2 EG to ASTM B633SC3, BS 1706 FE/ZN12

#### 2. Application

2.1 The Roller Stands are used for long horizontal pipe lines which are subjected for temperature fluctuations. These are designed to compensate longitudinal movement of pipe line due to expansion or contraction of both insulated and non-insulated piping. These Roller Stands are typically used in large district cooling / heating plant distribution piping, process pipe lines boilers piping etc.

#### 3. Product Features

- 3.1 Starline Roller Stands are made from solid steel iron rollers for rigid pipe supporting.
- 3.2 The Roller Stands are available in wide range of material specification
  - 3.2.1 Fully electrogalvanized cast iron Roller Stands are standard.
  - 3.2.2 Stainless steel Roller Stands (suffix "SS")
  - 3.2.3 Nylon Roller Stands (suffix "NL")
  - 3.2.4 Hot dip galvanized Roller Stands (suffix "HDG")
  - 3.2.5 Epoxy powder coated Roller Stands (suffix "EP")
- 3.3 The roller pin and rods are made from high tensile steel fully electrogalvanized as standard / hot dip galvanized as optional.
- 3.4 Optional pipe guide assembly shall be provided to protect the piping in case of water hammer and external vibrations.

#### 4. Note:

Insulation protection shield / saddle shall be used under insulation to support insulated piping.



## **Roller Stand**



Note:

Due to policy of continuous improvement, the specifications are subject to change without prior notice.

Starline Enterprises

MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# **One Piece Channel Clip**

Catalogue Number : 8000128 : Rev. 02 Dated 18-Jan. 2016

#### **1** Construction Features:

- 1.1 Used for Parallel Piping mounted on Channels
- 1.2 Quick Installation Design

#### 2. Technical Data:

Note:

- 2.1 Pre Galvanised Zinc Coating conforms to A A653 Grade 90
- 2.2 Electro Galvanised as per ASTM B 633 Standards
- 2.3 Hot Dip Galvanised Conforming to ASTM A123 or A153

# Selection Table - One Piece Channel Clip Table Number : 18011602

Part No.	Steel Pipe Size	Strip Size (mm)
SCC138022	1/2"	2 x 32
SCC138028	3⁄4"	2 x 32
SCC138035	1"	2 x 32
SCC138040	1 ¼"	2 x 32
SCC138048	1 1⁄2"	2.5 x 32
SCC138060	2"	2.5 x 32
SCC138075	2 1/2"	2.5 x 32
SCC138090	3"	2.5 x 32
SCC138100	3 1/2"	2.5 x 32
SCC138115	4"	2.5 x 32
SCC138168	6"	2.5 x 32





Due to policy of continuous improvement, the specifications are subject to change without prior notice.

Starline Enterprises

MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Offset / Extended Clamps

Catalogue Number : 8000115 : Rev. 01 Dated 19-01-2016

#### 1. Compliance:

1.1 Galvanising to ASTM B633 SC3, BS 1706 FE/ZN 12

#### 2. Application:

Clamps designed for installation of pipe lines at fixed or adjustable distance away from walls or floor.

#### 3. Product Features:

- 3.1 Offset clamps are used for fixing pipes at fixed distance "H" from wall or floor.
- 3.2 Extended pipe clamps, as shown, permit adjustment of distance from wall or floor at site by cutting and/or bending the legs suitably.

#### 4. Material: Steel

Finish - Electro Galvanised

5. Options: Epoxy powder coated finish (add suffix "P") EPDM Lined (add suffix "R") HOT DIP galvanized (add suffix " HDG") Stainless steel (add suffix " SS")

#### 6. Ordering

6.1 Specify the type of clamp, model number and finish







# **SELECTION TABLE FOR OFFSET / EXTENDED CLAMPS** (Table No. : 190116)

Model	Steel Pipe	Dimensions (mm)						Max	
	Nom(OD)	А	В	С	D	E	Н	d	Load (kg)
OPC/EPC20	¾" (27mm)	178	148	108	M10	4.5x25	80	11	85
OPC/EPC25	1" (34mm)	184	154	114	M10	4.5x25	80	11	85
OPC/EPC30	1-1/4" (42mm)	192	162	122	M10	4.5x25	80	11	85
OPC/EPC40	1-1/2" (48mm)	198	168	128	M10	4.5x25	80	11	110
OPC/EPC50	2" (60mm)	210	180	140	M10	4.5x25	80	11	150
OPC/EPC65	2-1/2" (76mm)	265	225	175	M12	6x25	110	14	180
OPC/EPC75	3" (89mm)	280	240	190	M12	6x25	110	14	200
OPC/EPC100	4" (114mm)	305	265	215	M12	6x25	110	14	250
OPC/EPC125	5" (140mm)	380	330	265	M16	6x40	135	18	300
OPC/EPC150	6" (165 mm)	405	355	290	M16	6x40	135	18	350
OPC/EPC200	8" (219mm)	463	413	348	M16	6x50	165	18	400

### Note:

Note:

- 1. Clamps for other pipe sizes available on application. Please specify effective pipe OD, including insulation, if present.
- 2. Offset clamps with customized height "H" available on application.
- 3. Extended clamps with longer legs available on application.



Page: B-34



Head Office: MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

## Purlin Clamp

Catalogue Number : 8000130 : Rev. 01 Dated 31-07-2017

#### 1. Material :

Mild Steel elctrogalvanised to 8-9 Micron thickness conforming to EG-ASTM B633 SC3

#### 2. Application :

- 2.1 Electrical Fixing and Fastening
- 2.2 Acoustical, Ceiling and Partitioning
- 2.3 HVAC, Plumbing and Refrigeration
- 2.4 Fire Sprinkler.
- **2**.5 Lighting and Plumbing Fixtures.

#### 3. Features :

- 3.1 Easy Installation. This fixture doesn't require drilling or notching.
- 3.2 The clamps are positively latched using nut and bolt.

#### 4. Selection / Ordering :

- 4.1 Hot Dip Galvanised Finish (Suffix "HDG")
- 4.2 Electro Galvanised (Standard)
- 4.3 Epoxy Powder Coated Finish (Suffix "P")
- 4.4 Stainless Steel Construction (Suffix "SS")





# Selection Table - Purlin Clamp Table Number : B-05082017

SNo.	Description	Length – L (mm)	Dia – d (mm)	Thickness (mm)	Width (mm)	Height - H (mm)	Load in Kg
01	Purlin Clamp	85	11.5	3	25	37	25

#### Note:

- Due to policy of continuous improvement, the specifications are subject to change without prior notice
- Measurements are subject to 5% tolerance.
- To achieve good sound suppression, do not overload fitting.



MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Pipe Stanchion Saddle with U Bolt

Catalogue Number : 8000119 : Rev. 01 Dated 03-08-2017

#### 1. Compliance:

- 1.1 US Standards MSS-SP58 (Type 37)
- 1.2 MSS-SP69
- 1.3 EG to ASTM B633 SC3
- 1.4 BS 1706 FE/ZN 12

#### 2. Application:

For support of individual horizontal pipes close to the floor. Supplied complete with U Bolt for securing supported pipe firmly to the saddle.

#### 3. Product Features:

- 3.1 U-Bolts are available with EPDM Sleeve, to prevent contact between dissimilar materials when used with copper, plastic, aluminium or glass pipe.
- 3.2 Besides the table below, we offer intermediate sizes designed to closely fit the effective pipe OD for any insulation thickness.

#### 4. Material:

- Steel Finish -Electro Galvanised post manufacture.
- 5. Options: U-Bolt with EPDM Sleeve (suffix "R") Hot Dip Galvanised finish (suffix "HDG") Stainless Steel construction (suffix "SS")

#### 6. Selection / Ordering:

- 6.1 For usage with plain piping other than steel, please provide details of pipe material and OD.
- 6.2 For insulated pipe, please specify effective OD or pipe size plus insulation thickness. Standard (as below) or intermediate models will be selected as appropriate.
- 6.3 Where Starline Rubber Support Inserts are used, specifying matching SPSS Saddles will suffice.
- 6.4 SPFS Models can be selected from the table below.

#### 7. Installation Guidelines:

- 7.1 Starline Pipe Stanchion Saddle is designed to be used in conjunction with Pipe Floor Stanchions (please refer to Starline Pipe Floor Stanchions catalogue for details)
- 7.2 Pipe Saddle can be welded to PFS after final positioning of pipe.
- 7.3 If adjustment of pipe level is required after installation, Adjustable Pipe Stanchion Saddles should be ordered (please refer to Starline PSSA catalogue for details)



# SELECTION TABLE FOR PIPE STANCHION SADDLES (Table No. : 30031502)

Model	Steel Pipe	Dimensions (mm)				
		А	B*	D	C	
SPSS 50	2"	100	86	48	50	
SPSS 65	2-1/2"	100	94	48	50	
SPSS 75	3"	100	101	48	50	
SPSS 100	4"	100	116	48	50	
SPSS 125	5"	100	129	60	65	
SPSS 150	6"	100	142	60	65	
SPSS 200	8"	100	170	73	75	
SPSS 250	10"	100	199	73	75	
SPSS 300	12"	100	224	73	75	
SPSS 350	14"	100	244	100	100	
SPSS 400	16"	100	269	100	100	
SPSS 450	18"	100	294	100	100	
SPSS 500	20"	100	320	114	125	
SPSS 600	24"	100	371	114	125	
SPSS 750	30"	100	447	114	125	
SPSS 900	36"	100	524	114	125	

Note:

• Dimension "B" would vary marginally from given figures depending on the effective OD of supported pipe.



• Due to policy of continuous improvement, the specifications are subject to change without prior notice.



Head Office: MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

## HI Beam Clamp Catalogue Number : 8000113 : Rev. 01 Dated 25-07-2023

#### 1. Compliance:

- 1.1 Federal Specification AS-A-1192 (Type 1)
- 1.2 MSS-SP58 (Type 21)
- 1.3 MSS-SP69
- 1.4 WW-H-171E (Type 1)
- 1.5 EG-ASTMB 633 SC3, BS 1706 FE / ZN 12

#### 2. Material:

Mild Steel Electrogalvanised to 8-9 microns conforming to EG-ASTM B 633 SC3.

#### 3. Application:

Used for pipe supports for H and I Beams.

#### 4. Features:

- 4.1 Engineered for all sizes of I beams and Beams
- 4.2 Easy Installation
- 4.3 Positive Load Transfer: Axially Downward

- 5.1 Beam Size
- 5.2 Hot Dip Galvanised Finish (Suffix "HDG)
- 5.3 Epoxy Powder Coated Finish (Suffix "P")
- 5.4 Stainless Steel Construction (Suffix "SS")



# SELECTION TABLE – HI BEAM CLAMP (Table Number : HIBC-250723)

Beam Size	Part No. for I Beam	Part number H Beam	Load Carrying Capacity
I Beam 50mm	SIBC 50	SHBC50	350
I Beam 75mm	SIBC 75	SHBC75	450
I Beam 100mm	SIBC 100	SHBC100	600
I Beam 125mm	SIBC 125	SHBC125	600
I Beam 150mm	SIBC 150	SHBC150	900
I Beam 175mm	SIBC 175	SHBC175	900
I Beam 200mm	SIBC 200	SHBC200	1200
I Beam 250mm	SIBC 250	SHBC250	1500

Note:



*notice.Measurements are subject to 5% tolerance.* 

• To achieve good sound suppression, do not overload fitting.

• Due to policy of continuous improvement, the specifications are subject to change without prior



Head Office: MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

## Universal Beam Clamp Catalogue Number : 8000122 Rev. 01 Dated 29-07-23

#### 1. Compliance:

- 1.1 Federal Specification AS-A-1192 (Type 1)
- 1.2 MSS-SP127
- 1.3 WW-H-171E (Type 1)
- 1.4 EG-ASTMB 633 SC3, BS 1706 FE / ZN 12

#### 2. Material:

Mild Steel Electrogalvanised to 8-9 microns conforming to EG-ASTM B 633 SC3.

#### 3. Application:

Used for pipe supports

#### 4. Features:

- 4.1 Engineered for all types of beams
- 4.2 Easy Installation
- 4.3 Positive Load Transfer: Axially Downward

- 5.1 Beam Size
- 5.2 Hot Dip Galvanised Finish (Suffix "HDG)
- 5.3 Epoxy Powder Coated Finish (Suffix "P")
- 5.4 Stainless Steel Construction (Suffix "SS")



## SELECTION TABLE – UNIVERSAL BEAM CLAMP (Table Number: UBC-290723)

Model	Rod Size mm	Load Carrying Capacity Kg
SUBC M 10	10	300
SUBC M 12	12	350
SUBC M 16	16	500
SUBC M 20	20	600
SUBC M 24	24	700
SUBC M 30	30	800

Note:

• Due to policy of continuous improvement, the specifications are subject to change without prior notice.



• Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.



Head Office: MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Direct Weld Type Beam Clamp

Catalogue Number : 8000132 Rev. 01 dated 25-07-23

#### 1. Compliance:

- 1.1 Federal Specification AS-A-1192 (Type 1)
- 1.2 MSS-SP58 (Type 21)
- 1.3 MSS-SP69
- 1.4 WW-H-171E (Type 1)
- 1.5 EG-ASTMB 633 SC3, BS 1706 FE / ZN 12

#### 2. Material:

Mild Steel Electrogalvanised to 8-9 microns conforming to EG-ASTM B 633 SC3.

#### 3. Application:

Used for Welding directly structural assembly

#### 4. Features:

- 4.1 Easy Installation
- 4.2 Thread lock provided
- 4.3 Designed for variety of load sizes

- 5.1 Load Carrying capacity
- 5.2 Hole size
- 5.3 Hot Dip Galvanised Finish (Suffix "HDG)
- 5.4 Epoxy Powder Coated Finish (Suffix "P")
- 5.5 Stainless Steel Construction (Suffix "SS")



# SELECTION TABLE – DIRECT WELD TYPE BEAM CLAMP (Table Number : DWTBC-250723)

Model	Hole Size	Maximum Load Bearing in Kg
SDWB 10	10	400
SDWB 12	12	500
SDWB 16	16	1000
SDWB 20	20	1500
SDWB 24	24	2000
SDWB 30	30	3500
SDWB 36	36	5000
SDWB 42	42	7000

Note:

• Due to policy of continuous improvement, the specifications are subject to change without prior notice.



• Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.



Head Office: MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Pipe Insulation Protection Shield Catalogue Number : 8000114 Rev 01 Dated 29-07-23

#### 1. Compliance:

- 1.1 Federal Specification AS-A-1192 (Type 1)
- 1.2 MSS-SP58 (Type 39)
- 1.3 MSS SP 69
- 1.4 EG-ASTMB 633 SC3, BS 1706 FE / ZN 12

#### 2. Material:

Mild Steel Electrogalvanised to 8-9 microns conforming to EG-ASTM B 633 SC3.

#### 3. Application:

Used to install roller supports for insulated pipes

#### 4. Features:

- 4.1 Engineered specifically for respective pipe sizes and insulation thickness
- 4.2 Easy Installation
- 4.3 High load bearing capacity.
- 4.4 Available in 300mm 1000mm length
- 4.5 Neoprene caps available to reduce direct Heat dissipation loss

- 5.1 Pipe Size and Insulation Thickness
- 5.2 Hot Dip Galvanised Finish (Suffix "HDG)
- 5.3 Epoxy Powder Coated Finish (Suffix "P")
- 5.4 Stainless Steel Construction (Suffix "SS")



# SELECTION TABLE – Pipe Insulation Protection Shield (Table Number : PIPS-290723)

Model	Pipe size	Insulation	Thickness	Load (Kgs)
SIPS 025 025 300	1"	25mm	300mm	250
SIPS 032 025 300	1 1/4"	25mm	300mm	250
SIPS 040 025 300	1 1/2"	25mm	300mm	250
SIPS 050 025 300	2"	25mm	300mm	350
SIPS 065 025 300	2 1/2"	25mm	300mm	450
SIPS 080 025 300	3"	25mm	300mm	650
SIPS 100 025 300	4"	25mm	300mm	750
SIPS 125 025 500	5"	25mm	500mm	1100
SIPS 150 025 500	6"	25mm	500mm	1300
SIPS 200 025 500	8"	25mm	500mm	1450
SIPS 250 025 500	10"	25mm	500mm	1500
SIPS 025 050 300	1"	50mm	300mm	250
SIPS 032 050 300	1 1/4"	50mm	300mm	250
SIPS 040 050 300	1 1/2"	50mm	300mm	250
SIPS 050 050 300	2"	50mm	300mm	350
SIPS 065 050 300	2 1/2"	50mm	300mm	450
SIPS 080 050 300	3"	50mm	300mm	650
SIPS 100 050 300	4"	50mm	300mm	750
SIPS 125 050 500	5"	50mm	500mm	1100
SIPS 150 050 500	6"	50mm	500mm	1300
SIPS 200 050 500	8"	50mm	500mm	1450
SIPS 250 050 500	10"	50mm	500mm	1500
SIPS 300 050 500	12"	50mm	500mm	2600
SIPS 350 050 500	14"	50mm	500mm	2600
SIPS 400 050 500	16"	50mm	500mm	3600
SIPS 450 050 500	18"	50mm	500mm	5600
SIPS 500 050 600	20"	50mm	600mm	7600
SIPS 600 050 600	24"	50mm	600mm	8000
SIPS 750 050 750	30"	50mm	750mm	9000
SIPS 900 050 750	36"	50mm	750mm	9500
SIPS 1000 050 750	40"	50mm	750mm	10000

Model	Pipe size	Insulation	Thickness	Load (Kgs)
SIPS 025 025 300	1"	25mm	300mm	250
SIPS 050 075 300	2"	75mm	300mm	350
SIPS 065 075 300	2 1/2"	75mm	300mm	450
SIPS 080 075 300	3"	75mm	300mm	650
SIPS 100 075 300	4"	75mm	300mm	750
SIPS 125 075 500	5"	75mm	500mm	1100
SIPS 150 075 500	6"	75mm	500mm	1300
SIPS 200 075 500	8"	75mm	500mm	1450
SIPS 250 075 500	10"	75mm	500mm	1500
SIPS 300 075 500	12"	75mm	500mm	2600
SIPS 350 075 500	14"	75mm	500mm	2600
SIPS 400 075 500	16"	75mm	500mm	3600
SIPS 450 075 500	18"	75mm	500mm	5600
SIPS 500 075 600	20"	75mm	600mm	7600
SIPS 600 075 600	24"	75mm	600mm	8000
SIPS 750 075 750	30"	75mm	750mm	9000
SIPS 900 075 750	36"	75mm	750mm	9500
SIPS 1000 075 750	40"	75mm	750mm	10000
SIPS 100 100 300	4"	100mm	300mm	750
SIPS 125 100 500	5"	100mm	500mm	1100
SIPS 150 100 500	6"	100mm	500mm	1300
SIPS 200 100 500	8"	100mm	500mm	1450
SIPS 250 100 500	10"	100mm	500mm	1500
SIPS 300 100 500	12"	100mm	500mm	2600
SIPS 350 100 500	14"	100mm	500mm	2600
SIPS 400 100 500	16"	100mm	500mm	3600
SIPS 450 100 500	18"	100mm	500mm	5600
SIPS 500 100 600	20"	100mm	600mm	7600
SIPS 600 100 600	24"	100mm	600mm	8000
SIPS 750 100 750	30"	100mm	750mm	9000
SIPS 900 100 750	36"	100mm	750mm	9500
SIPS 1000 100 750	40"	100mm	750mm	10000

#### Note:

- Due to policy of continuous improvement, the specifications are subject to change without prior
- notice.

Measurements are subject to 5% tolerance.
To achieve good sound suppression, do not overload fitting.





Head Office: MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

## Vertical Riser Anchor Catalogue Number : 8000111 Dated 31-07-2023

#### 1. Compliance:

- 1.1 Federal Specification AS-A-1192 (Type 1)
- 1.2 MSS-SP58
- 1.3 MSS SP 69
- 1.4 EG-ASTMB 633 SC3, BS 1706 FE / ZN 12

#### 2. Material:

Mild Steel Electrogalvanised to 8-9 microns conforming to EG-ASTM B 633 SC3.

#### 3. Application:

Used for vibration isolation of vertical pipe risers

#### 4. Features:

- 4.1 All Directional Restraint Anchor used for vertical pipe riser.
- 4.2 Isolate vibration created by flowing fluids, water hammers, rotating equipment etc
- 4.3 High load bearing capacity.
- 4.4 Capable to withstand up to 1g seismic load.
- 4.5 Neoprene elastomers for sustaining oil, grease etc

- 5.1 Load Capacity
- 5.2 Hot Dip Galvanised Finish (Suffix "HDG)
- 5.3 Epoxy Powder Coated Finish (Suffix "P")
- 5.4 Stainless Steel Construction (Suffix "SS")



Model	Top width	Base Width	Bottom Length	Load Kg
	mm	mm	mm	
SRA 750	100	100	200mm	750
SRA 1500	130	130	300mm	1500
SRA 3000	160	160	500mm	3000
SRA 7000	250	250	700mm	7000
SRA15000	500	500	800mm	15000

# SELECTION TABLE – Vertical Riser Anchor (Table Number : VRA-310723)

#### Note:

• Due to policy of continuous improvement, the specifications are subject to change without prior notice.

• Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.



Starline Enterprises

MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

## Multi Rack Pipe Roller Catalogue Number : 8000117 : Rev 01 Dated 29-07-23

#### 1. Compliance:

- 1.1 Federal Specification AS-A-1192 (Type 1)
- 1.2 MSS-SP58 (Type 41)
- 1.3 MSS SP69
- 1.4 WW-H-171E (Type 1)
- 1.5 EG-ASTMB 633 SC3, BS 1706 FE / ZN 12

#### 2. Material:

Mild Steel Electrogalvanised to 8-9 microns conforming to EG-ASTM B 633 SC3.

#### 3. Application:

Roller Supports are used to compensate thermal Expansion/ Contraction caused by temperature changes of long pipe lines. Multi rack roller set facilitate arrangement multiple pipe line vertically.

#### 4. Features:

- 4.1 Machined smooth surfaced rollers.
- 4.2 Easy Installation
- 4.3 Positive Load Transfer: Axially Downward
- 4.4 Easy Height Adjustment
- 4.5 Nylock Nuts provided for Safety

- 5.1 Beam Size
- 5.2 Hot Dip Galvanised Finish (Suffix "HDG)
- 5.3 Epoxy Powder Coated Finish (Suffix "P")
- 5.4 Stainless Steel Construction (Suffix "SS")



		Dimension						
Model	Steel Pipe Size	Width of Roller L mm	Rod Dia mm	Load Carrying Capacity Kg				
SMRS 50	2"	120	12	400				
SMRS 65	2 1⁄2"	150	12	400				
SMRS 75	3"	160	12	400				
SMRS 100	4"	190	16	550				
SMRS 125	5"	230	16	550				
SMRS 150	6"	280	20	550				
SMRS 200	8"	310	24	1500				
SMRS 250	10"	370	24	1500				
SMRS 300	12"	420	24	1500				
SMRS 350	14"	470	30	4000				
SMRS400	16"	520	30	4000				
SMRS 450	18"	560	30	4000				
SMRS 500	20"	600	30	4000				
SMRS 600	24"	680	36	6000				
SMRS 750	30"	850	36	6000				
SMRS 900	36"	1000	40	8000				
SMRS 1000	40"	1200	40	8000				

# SELECTION TABLE – Multi Rack Pipe Roller (Table Number : MRPR-290723)

#### Note:

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.





MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Heavy Duty Elastomeric Lined Pipe Support

Catalogue Number : 8000133 : Rev. 03 Dated 08-08-2023

#### 1. Compliance:

- 1.1 MSS SP 58
- 1.2 EG ASTM 633 SC3
- 1.3 WW-H-171E

#### 2. Application:

- 2.1 FRP/GRP Piping
- 2.2 HDPE Piping
- 2.3 PP Piping
- 2.4 PVC Piping
- 2.5 Similar Non Metallic Piping

#### 3. Product Features:

- 3.1 Allows horizontal expansion and contraction of piping.
- 3.2 Suitable for insulated piping.
- 3.3 Elastomeric Coating to prevent metal piecing and subsequent leaks.
- 3.4 Positive Gripping of Piping.
- 3.5 Available in Carbon Steel with Powder coating, Hot dip galvanized and stainless steel.
- 3.6 Used where Structure is below the pipe.
- 3.7 Suitable for pipe racks.

- 4.1 Bare piping OD:
- 4.2 Add Suffix for Hot dip galvanised and Stainless Steel.
- 4.3 Add Suffix for Insulation Thickness (customized insulation thickness also apply)



Pipe Size in inch	Pipe Size in mm	Product Code	Suffix for Hot dip/ Stainless Steel	Insulation Thickness mm	Bearing Length in mm	Maximum Load in kg
2"	50	SHDES 50	HDG//SS	50//75//100	200	250
3"	80	SHDES 80	HDG//22	50//75//100	200	350
4"	100	SHDES 100	HDG//22	50//75//100	200	500
6"	150	SHDES 150	HDG//22	50//75//100	300	650
8"	200	SHDES 200	HDG//22	50//75//100	300	750
10"	250	SHDES 250	HDG//22	50//75//100	300	950
14"	350	SHDES 350	HDG//22	50//75//100	350	1600
16"	400	SHDES 400	HDG//22	50//75//100	350	1800
18"	450	SHDES 450	HDG//22	50//75//100	350	2200
20"	500	SHDES 500	HDG//22	50//75//100	350	3100
24"	600	SHDES 600	HDG//22	50//75//100	400	4000
30"	750	SHDES 750	HDG//22	50//75//100	500	5500
36"	900	SHDES 900	HDG//22	50//75//100	500	7500
40"	1000	SHDES 400	HDG//22	50//75//100	500	9000

# SELECTION TABLE FOR HEAVY DUTY ELASTOMERIC LINED PIPE SUPPORT (Table No: HDELPS-080823)

Note:

• Due to policy of continuous improvement, the specifications are subject to change without prior notice.

• *Measurements are subject to 5% tolerance.* 

• To achieve good sound suppression, do not overload fitting.





MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

## **Rigid Pipe Insulation Protection Shield**

Catalogue Number : 8000134 : Rev. 02 dated 26-08-2023

#### 1. Compliance:

- 1.1 Federal Specification AS-A-1192 (Type 1)
- 1.2 MSS SP58 (Type 39)
- 1.3 MSS SP 69
- 1.4 EG-ASTMB 633 SC3, BS 1706 FE / ZN 12

#### 2. Material:

Mild Steel Electrogalvanised to 8-9 microns conforming to EG-ASTM B 633 SC3.

#### 3. Application:

These are used outside rigid insulation inserts, like rubber support insert, Calcium silicate, High density PU Foam etc to avoid concentrated load.

#### 4. Features:

- 4.1 Engineered specifically for respective pipe sizes and insulation thickness
- 4.2 Easy Installation
- 4.3 High load bearing capacity.
- 4.4 Available in 300mm 1000mm length
- 4.5 The sheets chamfered to outwards to avoid metal piecing in to the insulation.

- 5.1 Pipe Size and Insulation Thickness (Optional sizes are available as per request)
- 5.2 Hot Dip Galvanised Finish (Suffix "HDG)
- 5.3 Epoxy Powder Coated Finish (Suffix "P")
- 5.4 Stainless Steel Construction (Suffix "SS")



Model	Pipe Size	Insulation Thickness	Length	Load Kg
SRIPS 025 025 300	1"	25 mm	200 mm	250
SRIPS 032 025 300	1 1/4"	25 mm	200 mm	250
SRIPS 040 025 300	1 1/2"	25 mm	200 mm	250
SRIPS 050 025 300	2"	25 mm	200 mm	350
SRIPS 065 025 300	2 1/2"	25 mm	200 mm	450
SRIPS 080 025 300	3"	25 mm	300 mm	650
SRIPS 100 025 300	4"	25 mm	300 mm	750
SRIPS 125 025 500	5"	25 mm	300 mm	1100
SRIPS 150 025 500	6"	25 mm	300 mm	1300
SRIPS 200 025 500	8"	25 mm	300 mm	1450
SRIPS 250 025 500	10"	25 mm	300 mm	1500
SRIPS 025 050 300	1"	50 mm	200 mm	250
SRIPS 032 050 300	1 1/4"	50 mm	200 mm	250
SRIPS 040 050 300	1 1/2"	50 mm	200 mm	250
SRIPS 050 050 300	2"	50 mm	200 mm	350
SRIPS 065 050 300	2 1/2"	50 mm	300 mm	450
SRIPS 080 050 300	3"	50 mm	300 mm	650
SRIPS 100 050 300	4"	50 mm	300 mm	750
SRIPS 125 050 500	5"	50 mm	300 mm	1100
SRIPS 150 050 500	6"	50 mm	300 mm	1300
SRIPS 200 050 500	8"	50 mm	300 mm	1450
SRIPS 250 050 500	10"	50 mm	300 mm	1500
SRIPS 300 050 500	12"	50 mm	300 mm	2600
SRIPS 350 050 500	14"	50 mm	300 mm	2600
SRIPS 400 050 500	16"	50 mm	500 mm	3600
SRIPS 450 050 500	18"	50 mm	500 mm	5600
SRIPS 500 050 600	20"	50 mm	500 mm	7600
SRIPS 600 050 600	24"	50 mm	600 mm	8000
SRIPS 750 050 750	30"	50 mm	600 mm	9000
SRIPS 900 050 750	36"	50 mm	600 mm	9500
SRIPS 1000 050 750	40"	50 mm	600 mm	10000
SRIPS 050 075 300	2"	75 mm	200 mm	350
SRIPS 065 075 300	2 1/2"	75 mm	200 mm	450
SRIPS 080 075 300	3"	75 mm	300 mm	650
SRIPS 100 075 300	4"	75 mm	300 mm	750

# SELECTION TABLE - RIGID PIPE INSULATION PROTECTION SHIELD (Table No. RPIPS260823)



			1	
Model	Pipe Size	Insulation Thickness	Length	Load Kg
SRIPS 125 075 500	5"	75 mm	300 mm	1100
SRIPS 150 075 500	6"	75 mm	300 mm	1300
SRIPS 200 075 500	8"	75 mm	300 mm	1450
SRIPS 250 075 500	10"	75 mm	300 mm	1500
SRIPS 300 075 500	12"	75 mm	300 mm	2600
SRIPS 350 075 500	14"	75 mm	300 mm	2600
SRIPS 400 075 500	16"	75 mm	500 mm	3600
SRIPS 450 075 500	18"	75 mm	500 mm	5600
SRIPS 500 075 600	20"	75 mm	500 mm	7600
SRIPS 600 075 600	24"	75 mm	600 mm	8000
SRIPS 750 075 750	30"	75 mm	600 mm	9000
SRIPS 900 075 750	36"	75 mm	600 mm	9500
SRIPS 1000 075 750	40"	75 mm	600 mm	10000
SRIPS 100 100 300	4"	100 mm	300 mm	750
SRIPS 125 100 500	5"	100 mm	300 mm	1100
SRIPS 150 100 500	6"	100 mm	300 mm	1300
SRIPS 200 100 500	8"	100 mm	300 mm	1450
SRIPS 250 100 500	10"	100 mm	300 mm	1500
SRIPS 300 100 500	12"	100 mm	300 mm	2600
SRIPS 350 100 500	14"	100 mm	300 mm	2600
SRIPS 400 100 500	16"	100 mm	500 mm	3600
SRIPS 450 100 500	18"	100 mm	500 mm	5600
SRIPS 500 100 600	20"	100 mm	500 mm	7600
SRIPS 600 100 600	24"	100 mm	600 mm	8000
SRIPS 750 100 750	30"	100 mm	600 mm	9000
SRIPS 900 100 750	36"	100 mm	600 mm	9500
SRIPS 1000 100 750	40"	100 mm	600 mm	10000

## INSULATION PROTECTION SHIELD



Typical Application With Roller stand

# INSULATION PROTECTION SHIELD



Typical Application With Clevis Hanger

#### Note:

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- •

Measurements are subject to 5% tolerance. To achieve good sound suppression, do not overload fitting. •





MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# **Cushion Clamp**

Catalogue Number : 8000135 : Rev. 02 Dated 01-08-2024

# **STARLINE CUSHION CLAMP**

Cushion clamps are used as guide for piping lines for soft piping materials such as Copper piping, HDPE piping, PVC piping etc.

#### 1. Compliance:

- 1.1 Federal Specification AS-A-1192 (Type 1)
- 1.2 MSS-SP58 (Type 1)
- 1.3 MSS-SP69
- 1.4 WW-H-171E (Type 1)
- 1.5 EG-ASTMB 633 SC3, BS 1706 FE / ZN 1

#### 2. Application:

- 2.1 To achieve effective level installation of pipe
- 2.2 Copper and HDPE piping
- 2.3 Independent suspension of large pipes.
- 2.4 Suspension of insulated or plain stationary piping.
- 2.5 Suitable for sound suppression in pipe lines.

#### 3. Product Features:

- 3.1 Soft Cushion material like TPR, FTR.
- 3.2 Available in Galvanised, HDG and SS.

#### 4. Selection / Ordering:

- 4.1 Bare piping: OD.
- 4.2 Flat Surface must be ensured for fixing cushion.

4.3 Material Specs: EPDM lined: (Suffix "R").

Epoxy powder coated finish (Suffix "EPC"). Hot dip galvanized (Suffix "HDG") Stainless Steel (Suffix "SS")

#### 5. Installation Guide lines:

- 5.1 nuts to be provided with oversized washers and tighten properly to ensure proper performance.
- 5.2 Fixing surface must be Flat and Level.



# SELECTION TABLE – CUSHION CLAMP (Table No. : CC-01082024)

Sl.No.	Description	Size
1	Starline Cushion Clamp, ¼"	1⁄4"
2	Starline Cushion Clamp, 3/8"	3/8"
3	Starline Cushion Clamp, <sup>1</sup> ⁄2"	1⁄2"
4	Starline Cushion Clamp, 5/8"	5/8"
5	Starline Cushion Clamp, <sup>3</sup> / <sub>4</sub> "	3⁄4"
6	Starline Cushion Clamp, 7/8"	7/8"
7	Starline Cushion Clamp, 1 1/8"	1 1/8"
8	Starline Cushion Clamp, 1 3/8"	1 3/8"
9	Starline Cushion Clamp, 1 5/8"	1 5/8"
10	Starline Cushion Clamp, 2 1/8"	2 1/8"
11	Starline Cushion Clamp, 2 5/8"	2 5/8"
12	Starline Cushion Clamp, 3 1/8"	3 1/8"
13	Starline Cushion Clamp, 3 5/8"	3 5/8"
14	Starline Cushion Clamp, 4 1/8"	4 1/8"
15	Starline Cushion Clamp, 5 1/8"	5 1/8"
16	Starline Cushion Clamp, 6 1/8"	6 1/8"

Note:



• Due to policy of continuous improvement, the specifications are subject to change without prior notice.

• Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.

# Vibration Isolators

Star **im** Enterprises

Head Office: MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in, www.starlinesupports.com

Factory: Sree Sai Krithika Industrial Estate 4 / 293, S.F. No. 221 & 91, Sreerapalayam, Post - Podipalayam, Coimbatore, Tamil Nadu, India - 641 105





MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Cased Spring Mount

# 25 mm & 50 mm Standard Deflection

Catalogue Number : 9000100 : Rev. 12 Dated 06-10-2023

#### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and ASHRAE Guidelines for Vibration Isolation

#### 2. Application:

Cased Spring Mounts are used for isolating floor mounted sources of noise and vibration near critically quiet areas. These mounts are combination of Neoprene and Spring. Hence it can isolate audible / inaudible noise and vibration produced from floor mounted Mechanical Equipments such as Reciprocating Compressors, Close Coupled and Base Mounted Pumps, Packaged Air Handling Units, Condensing Units, Roof Top Air Handling Units, Air Cooled / Water Cooled Chillers, Centrifugal / Axial Fans, Internal Cumbustion Engines, Generators, Drop Hammers, Punch Presses upto static deflection requirement of upto 50 mm.

#### 3. Product Features:

- 3.1 Spring elements are designed to operate without Spring Buckling and shall have minimum of 50% overload capacity. Horizontal Stiffness is designed to have 85% to 100% of vertical stiffness with working deflection of maximum 60% at Rated load.
- 3.2 Spring mount has external leveling arrangements to ensure equipment is in level condition after installation.
- 3.3 Deflection can be provided for 25 mm and 50 mm at Rated Load.
- 3.4 Inner walls of lower casing have resilient rubber Snubbers which
  - 3.4.1 Provides a smooth guide for the top casing.
  - 3.4.2 Prevents metal to metal contact.
  - 3.4.3 Limits lateral movement during startups, shutdown and due to horizontal wind load.
- 3.5 Thick Ribbed Neoprene Pads are provided below the springs which provide noise barrier for high frequencies which may otherwise be transmitted to building structures. 10 mm thick Neoprene Sound Pads are provided.
- 3.6 Springs are powder coated with individual colours to facilitate identification.
- 3.7 Springs and Casings are powder coated upto 100 Microns with 1,000 Hours of Salt Spray Rating conforming to ASTM B-117. Option:
  - 3.7.1 Frame Hot Dip Galvanised (Prefix Part Number with "HDG")
  - 3.7.2 Spring Neoprene Coated (Prefix Part Number with "N")
  - 3.7.3 Spring Plastic Coated (Prefix Part Number with "P")

#### 4. Selection / Ordering:

While calculating operating equipment weight, variables such as weight of water, weight of pipe fittings, valves etc should be taken into consideration to arrive at the actual loading on the spring.

#### 5. Installation Guidelines:

Detailed installation guidelines are included in the spring mount package.



SELECTION TABLE FOR 25 mm DEFLECTION CASED SPRING MOUNTS (Table No: SCSM25-06102									61023 <b>)</b>	
Isolator Model	Rated Load (kg)	Spring Colours			Di	imension	s (mm)			
			L	W	$H^*$	HIR <sup>*</sup>	Α	BC	D	d
SCSM25-A25	25	Green								
SCSM25-A30	30	Brown								
SCSM25-A50	50	Black								
SCSM25-A60	60	Yellow								
SCSM25-A75	75	White	1.17		114	100	107	110	14103755	1.00
SCSM25-A100	100	Blue	147	55	114	128	106	116	M10X75	M8
SCSM25-A150	150	Grey								
SCSM25-A200	200	Orange								
SCSM25-A250	250	Red								
SCSM25-A300	300	Purple								
SCSM25-A400	400	Purple***								
SCSM25-B200	200	Green								
SCSM25-B250	250	Brown			143	146	160	178	M12X75	
SCSM25-B300	300	Grey	213	74						M10
SCSM25-B400	400	Purple								
SCSM25-B500	500	Black								l
SCSM25-B600	600	Yellow								
SCSM25-B700	700	Yellow***								
SCSM25-C400	400	Brown			143	146				
SCSM25-C500	500	Grey							M16X125	M14
SCSM25-C600	600	Orange					174.5			
SCSM25-C700	700	Green								
SCSM25-C800	800	Brown*	225	86				188.3		
SCSM25-C900	900	Grey*								
SCSM25-C1000	1000	Orange*								
SCSM25-C1100	1100	Green*								
SCSM25-C1200	1200	Orange**								
SCSM25-C1300	1300	Green**								
SCSM2-2C1400	1400	Green								
SCSM25-2C1600	1600	Brown*								
SCSM25-2C1800	1800	Grey*								
SCSM25-2C2000	2000	Orange*	310	90	160	180	250	280	M16X100	M12
SCSM25-2C2200	2200	Green*								
SCSM25-2C2400	2400	Orange**								
SCSM25-2C2600	2600	Green**								
5051V125-402800	2800	Green								
SUSIVIZO-4U3200	3600	Brown <sup>*</sup>								
SCSW25 4C4000	4000	Orango*				180	310			
SCSW12J-4C4000	4400	Croop*	325	170	160			295	24	M36
SCSW12J-4C4400	4900	Orango**								
SCSW12J-4C4000	5200	Croop**								
3031423-403200	5200	Green								

\* with WHITE Core Spring

\*\* with BLUE Core Spring\*\*\* with RED Core Spring



# SELECTION TABLE FOR 50 mm DEFLECTION CASED SPRING MOUNTS (Table No: SCSM25-290623)

Isolator Model	Pated Load (kg)	Spring Colours	Dimensions (mm)							
Isolator widder	Kated Load (kg)	Spring Colours	L	W	$H^*$	HIR <sup>*</sup>	А	BC	D 5 M10X75 5 M16X100 5 M18X100 5 20	d
SCSM50-A010	10	Brown								
SCSM50-A015	15	Orange								
SCSM50-A030	30	Green	ĺ							
SCSM50-A040	40	Red								
SCSM50-A060	60	White	165	00	140	150	150	100	M10V75	140
SCSM50-A100	100	Blue	165	90	140	158	150	180	MIUX/5	M8
SCSM50-A150	150	Black								
SCSM50-A200	200	Yellow								
SCSM50-A250	250	Purple								
SCSM50-A300	300	Grey								
SCSM50-C200	200	Red		100	178		170	205	M16X100	M14
SCSM50-C250	250	Orange								
SCSM50-C300	300	Brown				220				
SCSM50-C400	400	Green	240							
SCSM50-C500	500	Yellow								
SCSM50-C600	600	Yellow*								
SCSM50-C700	700	Yellow**								
SCSM50-C800	800	Yellow***								
SCSM50-2C1000	1000	Yellow								
SCSM50-2C1200	1200	Yellow*	250	100	195	220	250	200	M18V100	M12
SCSM50-2C1400	1400	Yellow**	550	100	165		230	290	WIIOAIUU	10112
SCSM50-2C1600	1600	Yellow***								
SCSM50-4C2000	2000	Yellow								
SCSM50-4C2400	2400	Yellow*	250	170	105	220	210	205	20	1124
SCSM50-4C2800	2800	Yellow**	330	1/0	183	220	310	295	20	IVI24
SCSM50-4C3200	3200	Yellow***								



with WHITE Core Spring with BLUE Core Spring

\*\*\*

with BLACK Core Spring

**Cased Sprint Mount** 25 mm & 50 mm Deflection

\*

\*\*



#### Note:

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance. •
- To achieve good sound suppression, do not overload fitting. •

Page: C-03

Starline Enterprises

MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Open Spring Mounts - Metal Based

#### Catalogue Number : 9000101 : Rev. 06 Dated 06-10-2023

#### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and Ashrae Guidelines for Vibration Isolation

#### 2. Application:

To isolate vibration from rotating and reciprocating machines. For example : Air Handling Units, Axial and Centrifugal Fans, Duct work, Pipe Work, Condensing Units, Pump Units, Chillers, Genset etc.

#### 3. Product Features:

- 3.1 The Springs are designed to have a stiffness ratio more than unity which ensures buckle free operation throughout load range.
- 3.2 Springs and Casing are powder coated with 1000 hours of Salt Spray Test conforming to ASTM B-117.
- 3.3 Upper Load Plate and Leveling Assembly are provided for accurate Leveling.
- 3.4 In heavier capacities, Springs are welded to Load Plate with Neoprene Pad.
- 3.5 Standard Product Range offers upto 2" deflection with optional Custom made Isolators of higher deflection.
- 3.6 Thick ribbed Neoprene Pads are provided below Load Plate for noise isolation and non skid. 10-18 mm thick neoprene sound pads are provided.
- 3.7 Colour Coded Coated Springs for easy identification of Load.
- 4. Selection / Ordering: Static Load.









## **SELECTION TABLE (Table No: C-05-01)** Isolation Efficiency at Typical Machine Speeds

M/C Speed (rpm)		Efficiency %				
	15mm Defl.	25mm Defl.	50mm Defl.			
300	Do not use	34.0	75.2			
500	68.7	83.3	92.3			
750	88.1	93.2	96.7			
1000	93.7	96.3	98.2			
1200	95.5	97.4	98.7			
1500	97.3	98.4	99.2			
1750	98.0	99.8	99.4			
2000	98.5	99.1	99.5			

The above figures are theoretical values only based on the vertical natural frequency of the spring system assuming in infinitely stiff structural supports. The effects of high frequency spring coil resonances on low frequency performance are also ignored.

# Technical Specifications for Open Spring Mount - Metal Based Table Number : OSMMB25-061023

Part No.	Colour	Rated	Deflection	Dimensions (mm)								
	Code	Load	at Rated	Δ	R	C	ם	F	F	G	н	Ţ
		(kg)	Load(mm)	11	<u> </u>			ц	1	0	11	)
SOSMMB25-A25	Green	25	25									
SOSMMB25-A30	Brown	30	25									
SOSMMB25-A50	Black	50	25									
SOSMMB25-A60	Yellow	60	25									
SOSMMB25-A75	White	75	25				110	10			20	
SOSMMB25-A100	Blue	100	25	105	85	75			M10	9		45
SOSMMB25-A150	Grey	150	25									
SOSMMB25-A200	Orange	200	25									
SOSMMB25-A250	Red	250	25									
SOSMMB25-A300	Purple	300	25									
SOSMMB25-A250	Red	250	25									
SOSMMB25-A300	Purple	300	25									
SOSMMB25-B200	Green	200	25									
SOSMMB25-B250	Brown	250	25									
SOSMMB25-B300	Grey	300	25	1.40	110	100	1.40	10	7 4 1 4	10	07	(1)
SOSMMB25-B400	Purple	400	25	140	110	100	140	10	M14	13	27	62
SOSMMB25-B500	Black	500	25									
SOSMMB25-B600	Yellow	600	25									
SOSMMB25-C400	Brown	400	25									
SOSMMB25-C500	Grey	500	25	140	165	130	200	12	M16	17	30	72
SOSMMB25-C600	Orange	600	25									
SOSMMB25-C700	Green	700	25									







#### Note:

• Due to policy of continual improvement, the specifications are subject to change without prior notice.

• Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.


MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Spring Hanger - Light Duty

Catalogue Number : 9000102 : Rev. 08 Dated 07-12-2021

#### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and Ashrae Guidelines for Vibration Isolation

#### 2. Application:

Generally for light duty applications like small fans, humidifiers, variable air volume boxes, small fan coil units, small size piping and air ducting in mechanical rooms.

#### 3. Product Features:

- 3.1 The Springs are designed to have a stiffness ratio more than unity which ensures buckle free operation throughout load range.
- 3.2 Suspension rod misalignment (30 degree arc) is compensated in hanger design.
- 3.3 Locking rubber bush centralizes the spring and prevents dislocation.
- 3.4 Springs are powder coated with appropriate color coding to facilitate identification.
- 3.5 Frame is made of G.I. steel and powder coated to 100 microns paint thickness (exceeds 1000 hours of salt spray test) and conforming to ASTM B-117. Options:
  - 3.5.1 Frame and Spring Hot Dip Galvanised (Prefix Part Number with "HDG")
  - 3.5.2 Spring Neoprene Coated (Prefix Part Number with "N")
  - 3.5.3 Spring Plastic Coated (Prefix Part Number with "P")
  - 3.5.4 Frame and Spring Hot Dip Galvanised with Neoprene Rubber Coating (Prefix Part Number with "HDGN")
- 3.6 The Springs are designed to have additional 50% of rated load at 1.5 of rated deflection.

#### 4. Selection / Ordering:

Point load (Calculated to include all variables such as weight of water in pipe lines etc if applicable).

#### 5. Installation Guide lines:

Included in packaging.



### SELECTION TABLE FOR SPRING HANGERS - LIGHT DUTY (Table No: SHLD-24-11-20)

Isolator Model	Rated	Rated	Spring		Din	nension (	(mm)	
	Deflection	Load (kg)	Colours	L	W	$\mathbf{F}^*$	Η	d(max)
SSHL-M6		6	Orange					
SSHL-M9		9	Grey					
SSHL-M15	13 mm	15	Blue	65	50	54	85	M10
SSHL-M21		21	Green					
SSHL-M28		28	White					
SSHL-P6		6	Green					
SSHL-P9		9	Red					
SSHL-P15		15	Black					
SSHL-P21	25 mm	21	Yellow	65	50	70	105	M10
SSHL-P28		28	Blue					
SSHL-P35		35	Grey					
SSHL-P50		50	Orange					

\* Represents average free height in each grouping of models. Height of some models in group may vary slightly from this figure.

# Spring Hanger - Light Duty





#### Note:

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.
- To achieve good sound suppression, do not overload fitting.



MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Spring Hanger 25 mm Standard Deflection

#### Catalogue Number : 9000103 : Rev. 07 Dated 06-01-2025

#### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and Ashrae Guidelines for Vibration Isolation

#### 2. Application:

Spring Hangers are used for isolation of vibration produced by suspended mechanical equipment, low speed suspended fan, transformers, duct work, piping etc... These are especially recommended for isolating any suspended source of audible / inaudible noise and vibration with minimum static deflection requirement exceeding 13 mm and up to 25 mm.

#### 3. Product Features:

- 3.1 The Springs are designed to have a stiffness ratio more than unity which ensures buckle free operation throughout load range.
- 3.2 Suspension rod misalignment (30 degree arc) is compensated in hanger design.
- 3.3 Locking rubber bush centralizes the spring and prevents dislocation.
- 3.4 Springs are powder coated with appropriate color coding to facilitate identification.
- 3.5 Frame is made of G.I. steel and powder coated to 100 microns paint thickness (exceeds 1000 hours of salt spray test) and conforming to ASTM B-117.

Option : Frame Hot Dip Galvanized. Part Number prefix with "HDG". Spring Neoprene Coated. Part Number prefix with "N". Spring Plastic Dip Coated. Part Number prefix with "P".

- 3.6 Isolation Brackets are capable of overloading upto 500%.
- 3.7 The Springs are designed to have additional 50% of rated load at 1.5 of rated deflection.

#### 4. Selection / Ordering:

Point load (Calculated to include all variables such as weight of water in pipe lines etc. if applicable).

5. Installation Guide lines: Included in packaging.



SPRING HANGER 25MM DEFLECTION A, B & C BODIES

SELECTION 1	TABLE - 25 MM DE	FLECTION SPRING	HANGE	RS (Tabl	e No: SH	25-0601	25)
				Dim	ensions (	mm)	
Isolator Model	Rated Load (kg)	Spring Colours	L	W	F	Н	d
SSH25-A25	25	Green					
SSH25-A30	30	Brown	]				
SSH25-A50	50	Black					
SSH25-A60	60	Yellow					
SSH25-A75	75	White	75	60	80	120	M12
SSH25-A100	100	Blue				120	1112
SSH25-A150	150	Grey	]				
SSH25-A200	200	Orange	1				
SSH25-A250	250	Red					
SSH25-A300	300	Purple					
SSH25-B200	200	Green					
SSH25-B250	250	Brown	07	00	06	1.45	M1D
SSH25-B300	300	Grey	03	00	90	145	IVIIZ
SSH25-B400	400	Purple					
SSH25-C400	400	Brown					
SSH25-C500	500	Grey			105	1.00	1 (00
SSH25-C600	600	Orange	90	80	105	160	M20
SSH25-C700	700	Green					
SSH25-2C800	800	Brown					
SSH25-2C1000	1000	Grey					
SSH25-2C1200	1200	Orange	200	100	105	170	M30
SSH25-2C1400	1400	Green			105	170	1,100
SSH25-2C1600	1600	Brown *					
SSH25-2C1800	1800	Grey*					
SSH25-2C2000	2000	Orange*					
SSH25-2C2200	2200	Green*	200	100	105	170	M36
SSH25-2C2400	2400	Orange**					

\* With White Core Spring

\*\* With Blue Core Spring Spring Hangers with Higher Capacity available on application



#### Note:

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.





MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Spring Hanger 50 mm Standard Deflection

#### Catalogue Number : 9000104 : Rev. 05 Dated 23-06-2021

#### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and Ashrae Guidelines for Vibration Isolation

#### 2. Application:

Spring Hangers are used for isolation of vibration produced by suspended mechanical equipment, low speed suspended fan, transformers, duct work, piping etc... These are especially recommended for isolating any suspended source of audible / inaudible noise and vibration with minimum static deflection requirement exceeding 25 mm and upto 50 mm.

#### 3. Product Features:

- 3.1 The Springs are designed to have a stiffness ratio more than unity which ensures buckle free operation throughout load range.
- 3.2 Suspension rod misalignment (30 degree arc) is compensated in hanger design.
- 3.3 Locking rubber bush centralizes the spring and prevents dislocation.
- 3.4 Springs are powder coated with appropriate color coding to facilitate identification.
- 3.5 Frame is made of G.I. steel and powder coated to 100 microns paint thickness (exceeds 1000 hours of salt spray test) and conforming to ASTM B-117. Option :

Frame Hot Dip Galvanized. Part Number prefix with "HDG". Spring Neoprene Coated. Part Number prefix with "N". Spring Plastic Dip Coated. Part Number prefix with "P".

- 3.6 Isolation Brackets are capable of overloading upto 500%.
- 3.7 The Springs are designed to have additional 50% of rated load at 1.5 of rated deflection.

#### 4. Selection / Ordering:

Point load (Calculated to include all variables such as weight of water in pipe lines etc if applicable).

#### 5. Installation Guide lines:

Included in packaging.

#### 6. Options:

Spring Hangers of Higher Capacity and Deflection shall be Engineered as per Specific Requirements. Nomenclature for Special Engineered Spring Hangers shall be SSH(XXX - Deflection-G(XXXXX-Load).



SPRING HANGER 50mm DEFLECTION A & C BODIES

SELECTION T	ABLE FOR 50 MM	DEFLECTION SPRII	NG HANG	GERS (Ta	ble No: (	C-11-180	620)
Isolator Model	Rated Load (kg)	Spring Colours		Dim	ensions (	mm)	
		opring corours	L	W	F	Н	d
SSH50-A10	10	Brown					
SSH50-A15	15	Orange					
SSH50-A30	30	Green					
SSH50-A40	40	Red					
SSH50-A60	60	White					
SSH50-A100	100	Blue	90	80	120	170	M12
SSH50-A150	150	Black					
SSH50-A200	200	Yellow					
SSH50-A250	250	Purple					
SSH50-A300	300	Grey					
SSH50-C400	400	Green	120	100	160	220	M20
SSH50-C500	500	Yellow			100	220	
SSH50-2C600	600	Grey					
SSH50-2C800	800	Green					
SSH50-2C1000	1000	Yellow	220	100	160	240	M30
SSH50-2C1200	1200	Yellow*					
SSH50-2C1400	1400	Yellow**					
SSH50-2C1600	1600	Yellow***					
SSH50-4C2000	2000	Yellow					
SSH50-4C2400	2400	Yellow**	220	200	160	240	M36
SSH50-4C2800	2800	Yellow**					
SSH50-4C3200	3200	Yellow***					



\* With WHITE Core Spring \*\* With BLUE Core Spring \*\*\* With BLACK Core Spring

• Spring Hangers with higher capacity available on application.

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.



Page: C-11

Note:



MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Precompressed Spring Hanger 25 mm Standard Deflection

#### Catalogue Number : 9000105 : Rev. 05 Dated 23-06-2021

#### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and Ashrae Guidelines for Vibration Isolation

#### 2. Application:

Suspension of water pipe lines and seismically restrained rotating equipments.

#### 3. Product Features:

- 3.1 The Springs are designed to have a stiffness ratio more than unity which ensures buckle free operation throughout load range.
- 3.2 Suspension rod misalignment (30 degree arc) is compensated in hanger design.
- 3.3 Direct connection to lower suspension rod by means of a threaded rod coupler.
- 3.4 Printed deflection scale to indicate total spring deflection.
- 3.5 Pre compressed spring effectively minimizes transfer of variations in pipe load during filling of pipes thus protecting equipment connections / flexible joints and also prevents overloading of the main equipment isolators.
- 3.6 Locking rubber bush centralizes the spring and prevents dislocation.
- 3.7 Springs are powder coated with appropriate color coding to facilitate identification.
- 3.8 Frame is made of G.I. steel and powder coated to 100 microns paint thickness (exceeds 1000 hours of salt spray test) and conforming to ASTM B-117.
- 3.9 The Springs are designed to have additional 50% of rated load at 1.5 of rated deflection.

#### Option:

- 1) Frame Hot Dip Galvanised (Prefix Part Number with "HDG")
- 2) Spring Neoprene Coated (Prefix Part Number with "N")
- 3) Spring Plastic Coated (Prefix Part Number with "P")

#### 4. Selection / Ordering:

Point load (Calculated to include all variables such as weight of water in pipe lines etc if applicable).

5. Installation Guide lines:

Included in packaging.



Pre-Compressed Spring Hanger 25 mm Standard Deflection

<b>SELECTION TABLE -</b>	25 MM DEFLECTIO	ON PRECOMPRESSE	D SPRIN	IG HANG	GERS (Ta	ble No: 1008	20-01)
Isolator Model	Rated Load (kg)	Spring Colours		Ι	Dimensio	on (mm)	
			L	W	F	Н	d
SPCSH25-A25	25	Green					
SPCSH25-A50	50	Black					
SPCSH25-A75	75	White					
SPCSH25-A100	100	Blue	75	60	88	110	M12
SPCSH25-A150	150	Grey					
SPCSH25-A200	200	Orange					
SPCSH25-B200	200	Green					
SPCSH25-B250	250	Brown	90	80	105	150	M16
SPCSH25-B300	300	Grey	70	00	105	150	10110
SPCSH25-B400	400	Purple					
SPCSH25-C400	400	Brown					
SPCSH25-C500	500	Grey	90	80	105	150	M20
SPCSH25-C600	600	Orange					
SPCSH25-C700	700	Green					
SPCSH25-2C800	800	Brown					
SPCSH25-2C1000	1000	Grey					
SPCSH25-2C1200	1200	Orange					
SPCSH25-2C1400	1400	Green	200	100	105	160	M30
SPCSH25-2C1600	1600	Brown*	200	100	105	100	10100
SPCSH25-2C1800	1800	Grey*					
SPCSH25-2C2000	2000	Orange*					
SPCSH25-2C2200	2200	Green*					
SPCSH25-2C2400	2400	Orange**	200	100	105	160	M36
SPCSH25-2C2600	2600	Green**	200	100	105	100	10120



- Pre-Compressed Spring Hanger 25 mm Standarded Deflection A,B & C Bodies

- \* With WHITE Core Spring
- \*\* With BLUE Core Sprint

#### Note:

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.

Measurements are subject to 5% tolerance.
To achieve good sound suppression, do not overload fitting.





MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Precompressed Spring Hanger 50 mm Standard Deflection

### Catalogue Number : 9000106 : Rev. 05 Dated 06-01-2025

#### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and Ashrae Guidelines for Vibration Isolation

#### 2. Application:

Suspension of water pipe lines and seismically restrained rotating equipments.

#### 3. Product Features:

- 3.1 The Springs are designed to have a stiffness ratio more than unity which ensures buckle free operation throughout load range.
- 3.2 Suspension rod misalignment (30 degree arc) is compensated in hanger design.
- 3.3 Direct connection to lower suspension rod by means of a threaded rod coupler.
- 3.4 Printed deflection scale to indicate total spring deflection.
- 3.5 Pre compressed spring effectively minimizes transfer of variations in pipe load during filling of pipes thus protecting equipment connections / flexible joints and also prevents overloading of the main equipment isolators.
- 3.6 Locking rubber bush centralizes the spring and prevents dislocation.
- 3.7 Springs are powder coated with appropriate color coding to facilitate identification.
- 3.8 Frame is made of G.I. steel and powder coated to 100 microns paint thickness (exceeds 1000 hours of salt spray test) and conforming to ASTM B-117.
- 3.9 The Springs are designed to have additional 50% of rated load at 1.5 of rated deflection.

#### Options:

- 1) Frame Hot Dip Galvanised (Prefix Part Number with "HDG")
- 2) Spring Neoprene Coated (Prefix Part Number with "N")
- 3) Spring Plastic Coated (Prefix Part Number with "P")

#### 4. Selection / Ordering:

Point load (Calculated to include all variables such as weight of water in pipe lines etc if applicable).

5. Installation Guide lines:

Included in packaging.



SELECTION TABL	E FOR 50 MM DEFLE	CTION PRECOMPRE	SSED SPF	RING HAI	NGERS (	Table No: 060	125)
Isolator Model	Rated Load (kg)	Spring Colours		Ľ	Dimensio	on (mm)	
		1 0	L	W	F	Н	d
SPCSH50-A10	10	Brown					
SPCSH50-A15	15	Orange					
SPCSH50-A30	30	Green					
SPCSH50-A40	40	Red					
SPCSH50-A60	60	White	83	80	96	145	M12
SPCSH50-A100	100	Blue					
SPCSH50-A150	150	Black					
SPCSH50-A200	200	Yellow					
SPCSH50-A250	250	Purple					
SPCSH50-A300	300	Grey					
SPCSH50-C250	250	Orange					
SPCSH50-C300	300	Brown	120	100	200	160	M20
SPCSH50-C400	400	Green					
SPCSH50-C500	500	Yellow					
SPCSH50-2C600	600	Brown					
SPCSH50-2C800	800	Green					
SPCSH50-2C1000	1000	Yellow	220	100	210	160	M36
SPCSH50-2C1200	1200	Yellow*	220	100	210	100	10150
SPCSH50-2C1400	1400	Yellow**					
SPCSH50-2C1600	1600	Yellow***					
SPCSH50-4C2000	2000	Yellow					
SPCSH50-4C2400	2400	Yellow*	240	200	210	170	1100
SPCSH50-4C2800	2800	Yellow**	240	200	210	100	11/130
SPCSH50-4C3200	3200	Yellow***					

# Precompressed Spring Hanger 50 mm Standard Deflection



#### Note:

- Due to policy of continual improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.
- To achieve good sound suppression, do not overload fitting.

Starline

# \* With WHITE Core Spring \*\* With BLUE Core Spring \*\*\* With BLACK Core Spring



MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# **Combination Spring Hangers - Light Duty**

Catalogue Number : 9000107 : Rev. 05 Dated 13-07-2021

#### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and Ashrae Guidelines for Vibration Isolation

#### 2. Application:

Generally for light duty applications like small fans, humidifiers, variable air volume boxes, small fan coil units, small size piping and air ducting in mechanical rooms.

#### 3. Product Features:

- 3.1 Double protection against transmission of noise to structures is assured as the neoprene component provides an effective acoustic barrier and the moulded neoprene cup below the spring prevents metal to spring contact, thus effectively isolating the suspended equipment from the structure.
- 3.2 The Springs are designed to have a stiffness ratio more than unity which ensures buckle free operation throughout load range.
- 3.3 Suspension rod misalignment (30 degree arc) is compensated in hanger design.
- 3.4 Locking rubber bush centralizes the spring and prevents dislocation.
- 3.5 Springs are powder coated with appropriate color coding to facilitate identification.
- 3.6 Frame is made of G.I. steel and powder coated to 100 microns paint thickness (exceeds 1000 hours of salt spray test) and conforming to ASTM B-117.

Options:

- 1) Frame Hot Dip Galvanised (Prefix Part Number with "HDG")
- 2) Spring Neoprene Coated (Prefix Part Number with "N")
- 3) Spring Plastic Coated (Prefix Part Number with "P")
- 3.7 The Springs are designed to have additional 50% of rated load at 1.5 of rated deflection.
- 4. Selection / Ordering:

Point load (Calculated to include all variables such as weight of water in pipe lines etc if applicable).

#### 5. Installation Guide lines:

Included in packaging.



COMBINATION SPRING HANGER LIGHT DUTY 13mm & 25mm DEFLECTION

SELECTION	TABLE FOR	COMBINATI	ON SPRING H	ANGER	S - LIGH	T DUTY	(Table N	o: C-17-1	<b>30721</b> )
Isolator	Rated	Rated	Spring			Dim	ensions	(mm)	
Model	Deflection	Load (kg)	Colour	L	W	SF*	RF	Н	d (max)
SCSHL-M6		6	Orange						
SCSHL-M9		9	Grey						
SCSHL-M15	13 mm	15	Blue	65	50	54	30	120	M10
SCSHL-M21		21	Green						
SCSHL-M28		28	White						
SCSHL-P6		6	Green						
SCSHL-P9		9	Red						
SCSHL-P15	25 mm	15	Black		50	70	20	1.40	N(10
SCSHL-P21		21	Yellow	65	50	/0	30	140	MIO
SCSHL-P28		28	Blue	Ī					
SCSHL-P35		35	Grey	Ī					
SCSHL-P50		50	Orange						

Represents average free height in each grouping of models. Height of some models in group may vary slightly from this figure.



#### *Note:*

\*

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.



MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Combination Spring Hanger 25 mm & 50 mm Standard Deflection Catalogue Number : 9000108 : Rev. 07 Dated 06-10-2023

#### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and Ashrae Guidelines for Vibration Isolation

#### 2. Application:

- 2.1 Generally used for suspension of heavy rotating equipment, for example Air Handling Units, Fan Coil Units, Ventilation Fans, Large Variable Air Volume Boxes, Pipes and air ducts in Mechanical Rooms.
- 2.2 These are highly effective when vibrations of high frequency and large amplitude are present.

#### 3. Product Features:

- 3.1 Double protection against transmission of noise to structures is assured as the neoprene component provides an effective acoustic barrier and the moulded neoprene cup below the spring prevents metal to spring contact, thus effectively isolating the suspended equipment from the structure.
- 3.2 The Springs are designed to have a stiffness ratio more than unity which ensures buckle free operation throughout load range.
- 3.3 Suspension rod misalignment (30 degree arc) is compensated in hanger design.
- 3.4 Locking rubber bush centralizes the spring and prevents dislocation.
- 3.5 Springs are powder coated with appropriate color coding to facilitate identification.
- 3.6 Frame is made of G.I. steel and powder coated to 100 microns paint thickness (exceeds 1000 hours of salt spray test) and conforming to ASTM B-117. Options:
  - 1) Frame Hot Dip Galvanised (Prefix Part Number with "HDG")
  - 2) Spring Neoprene Coated (Prefix Part Number with "N")
  - 3) Spring Plastic Coated (Prefix Part Number with "P")
- 3.7 The Springs are designed to have additional 50% of rated load at 1.5 of rated deflection.

#### 4. Selection / Ordering:

Point load (Calculated to include all variables such as weight of water in pipe lines etc if applicable).

5. Installation Guide lines: Included in packaging.



Combination Spring Hanger 25mm & 50mm Standard Deflection A, B & C Bodies

### SELECTION TABLE FOR 25 MM DEFLECTION COMBINATION SPRING HANGERS (Table No: CSH25-061023)

Isolator	Rated	Spring			Dimensio	ons (mm)		
Model	Load (kg)	Colours	L	W	SF*	RF	Н	d
SCSH-A25	25	Green						
SCSH-A30	30	Brown						
SCSH-A50	50	Black						
SCSH-A60	60	Yellow	]					
SCSH-A75	75	White	75	60	78	39	170	M12
SCSH-A100	100	Blue						
SCSH-A150	150	Grey	]					
SCSH-A200	200	Orange						
SCSH-A250	250	Red						
SCSH-A300	300	Purple						
SCSH-B200	200	Green						
SCSH-B250	250	Brown	90	80	100	46	200	M16
SCSH-B300	300	Grey			100	01	200	
SCSH-B400	400	Purple						
SCSH-C400	400	Brown						
SCSH-C500	500	Grey	00	00	105	72	240	
SCSH-C600	600	Orange	90	00	105	75	240	
SCSH-C700	700	Green						
SCSH-2C800	800	Brown						
SCSH-2C1000	1000	Grey	120	120	105	73	240	M30
SCSH-2C1200	1200	Orange						
SCSH-2C1400	1400	Green						

\* Represents average free height in each grouping of models. Height of some models in group may vary slightly from this figure.



#### Note:

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.



Isolator Model	Rated Load (kg)	Spring Colours		Di	mension	(mm)	
		1 0	L	W	Н	E(apprx.)	d
SCSH50-A10	10	Brown					
SCSH50-A15	15	Orange					
SCSH50-A30	30	Green					
SCSH50-A40	40	Red					
SCSH50-A60	60	White					
SCSH50-A100	100	Blue	100	90	215	115	M16
SCSH50-A150	150	Black				50° 60° 518	
SCSH50-A200	200	Yellow					
SCSH50-A250	250	Purple	]				
SCSH50-A300	300	Grey					
SCSH50-C200	200	Red					
SCSH50-C250	250	Orange					
SCSH50-C300	300	Brown	107	100	250	130	M24
SCSH50-C400	400	Green					
SCSH50-C500	500	Yellow	1				
SCSH50-2C800	800	Green					
SCSH50-2C1000	1000	Yellow	240	100	250	130	M30
SCSH50-2C1200	1200	Yellow*			250		
SCSH50-2C1400	1400	Yellow**					
SCSH50-2C1600	1600	Yellow***					



Combination Spring Hanger 25mm & 50mm Standard Deflection A,B & C Bodies

### \* With WHITE Core Sprint

\*\* With BLUE Core Spring

\*\*\* With BLACK Core Spring

Starline Page: C-20

#### Note:

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.
- To achieve good sound suppression, do not overload fitting.



MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

#### **Elastomeric Hanger**

#### Catalogue Number : 9000109 : Rev. 04 Dated 30-06-2023

#### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and Ashrae Guidelines for Vibration Isolation

#### 2. Application:

Elastomeric Hangers are recommended for the isolation of vibration produced by suspended Mechanical Equipment less than 15 kw, such as exhaust fans, duct work, Fan Coil Units, Piping etc... These are especially recommended to isolate sources of audible frequency of vibration where static deflection requirement is upto 13 mm.

#### 3. Product Features:

3.1 Frame is made of G.I. steel and powder coated to 100 microns paint thickness (exceeds 1000 hours of salt spray test) and conforming to ASTM B-117.

Option : Frame Hot Dip Galvanised. Part Number prefix with "HDG".

- 3.2 Elastomeric Rubber Mount is designed with hollow conical section thus ensuring loading of rubber in shear as well as compression mode and hence provides better isolation performance.
- 3.3 Hanger Cage is designed to accommodate suspension rod misalignment upto  $30^{\circ}$
- 3.4 Colour coded to facilitate easy identification
- 3.5 Steel Brackets are fail safe upto 500% overloading
- 3.6 As Elastomeric Rubber is inherently resistant against oil, grease etc, this is suitable for installation in the corrosive environment.
- 3.7 Steel plates impregnated inside the mounts will ensure uniform distribution of applied load.
- 4. Selection / Ordering:

Point load (Calculated to include all variables such as weight of water in pipe lines etc if applicable).

5. Installation Guide lines:

Included in packaging.



Model	Colour Code	Rated Load (kg)	Rated	D	imensi	ions (n	nm)	
			Deflection(mm)	L	W	Н	F	d
SNH-A-R	Red	18						
SNH-A-G	Green	35	8	65	50	80	35	M12
SNH-A-B	Blue	50						
SNH-B-R	Red	100						
SNH-B-G	Green	140	10	77	60	100	48	M12
SNH-B-B	Blue	200						
SNH-C-R	Red	250						
SNH-C-G	Green	350	10	94	80	145	73	M16
SNH-C-B	Blue	500						
SNH-D-R	Red	600						
SNH-D-G	Green	700	13	107	95	180	90	M20
SNH-D-B	Blue	900						

# SELECTION TABLE (Table No: EH-300623)

# Elastomeric Hanger



#### *Note:*

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.

Measurements are subject to 5% tolerance.
To achieve good sound suppression, do not overload fitting.





MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Open Spring Mounts - Elastomeric Based 25 & 50 mm Deflection

#### Catalogue Number : 9000110 : Rev. 09 Dated 06-10-2023

#### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and ASHRAE Guidelines for Vibration Isolation

#### 2. Application:

These are widely used for making Inertia Base Frames along with snubbers

#### 3. Product Features:

- 3.1 Spring elements are designed to operate without spring buckling with horizontal stiffness equal to vertical stiffness
- 3.2 These springs are provided with 50% overload capacity at 1.5 times of rated deflection.
- 3.3 Bottom plates are made of thick ribbed Elastomeric Pad for isolating noise and vibration.
- 3.4 Standard product range up to 2" deflection and custom isolators with higher deflections are available.
- 3.5 Upper load plate and leveling assembly are provided for accurate leveling.
- 3.6 The springs are powder coated with appropriate colour coding to facilitate identification.
- 3.7 Springs are powder coated to 100 microns paint thickness (exceeds 1,000 hours of salt spray test) conforming to ASTM B-117
- 3.8 As Elastomeric Rubber is inherently resistant against oil, grease, UV etc, this is suitable corrosive outdoor applications.

#### Options:

- 1. Frame Hot Dip Galvanised (Prefix "HDG")
- 2. Spring Elastomeric coated (Prefix "N")
- 3. Spring Plastic coated (Prefix "P")
- 4. Stainless Steel Bolt (Prefix "SS")

#### 4. Selection / Ordering:

Point Load (calculated to include variables such as weight of water in pipe lines etc. if applicable)

#### 5. Installation Guide lines:

Included in packing.



### Selection Table for Open Spring Mounts - Elastomeric Based - 25 mm Deflection (Table Number : SOSMEB25-061023)

Model No.	Rated	Spring Colour	Dimensions (mm)				ım)	
	Load (kg)		L	W	Н	BC	D	d
SOSMRB25-A25	25	Green						
SOSMRB25-A30	30	Brown						
SOSMRB25-A50	50	Black						
SOSMRB25-A60	60	Yellow	96	57	105	78	M12	12
SOSMRB25-A100	100	Blue						
SOSMRB25-A150	150	Grey						
SOSMRB25-A200	200	Orange						
SOSMRB25-A250	250	Red						
SOSMRB25-A300	300	Purple						
SOSMRB25-B200	200	Green						
SOSMRB25-B250	250	Brown						
SOSMRB25-B300	300	Grey						
SOSMRB25-B400	400	Purple	138	77	142	107	M12	12
SOSMRB25-B500	500	Black						
SOSMRB25-B600	600	Yellow						
SOSMRB25-B700	700	Yellow ***						
SOSMRB25-C400	400	Brown						
SOSMRB25-C500	500	Grey						
SOSMRB25-C600	600	Orange						
SOSMRB25-C700	700	Green						
SOSMRB25-C800	800	Brown *	155	87	142	121	M12	12
SOSMRB25-C900	900	Grey *						
SOSMRB25-C1000	1000	Orange *						
SOSMRB25-C1100	1100	Green *						
SOSMRB25-C1200	1200	Orange **						
SOSMRB25-C1300	1300	Green **						



- # with RED Core Spring
- \* with WHITE Core Spring
- \*\* with BLUE Core Spring
- \*\*\* with BLACK Core Spring



Selection	<b>Table for</b>	Open	Spring	Mounts	- Elastomeric	: Based	- 50 mm	Deflection
		(Tal	ble Nun	nber : S(	<b>DSMEB50-30</b>	0623)		

Model No.	Rated	Spring Colour			Dimen	sions (n	nm)	
	Load (kg)		L	W	Н	BC	D	d
SOSMRB50-A10	10	Brown						
SOSMRB50-A15	15	Orange						
SOSMRB50-A30	30	Green						
SOSMRB50-A40	40	Red						
SOSMRB50-A60	60	White	100	100	150	100	10	1410
SOSMRB50-A100	100	Blue	120	108	150	102	12	MIO
SOSMRB50-A150	150	Black						
SOSMRB50-A200	200	Yellow						
SOSMRB50-A250	250	Purple						
SOSMRB50-A300	300	Grey						
SOSMRB50-C200	200	Red						
SOSMRB50-C250	250	Orange						
SOSMRB50-C300	300	Brown						
SOSMRB50-C400	400	Green						
SOSMRB50-C500	500	Yellow	170	140	200	140	20	M16
SOSMRB50-C600	600	Yellow*						
SOSMRB50-C700	700	Yellow**						
SOSMRB50-C800	800	Yellow***						



\*with WHITE Core Spring \*\*with BLUE Core Spring \*\*\*with BLACK Core Spring



#### *Note:*

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.
- To achieve good sound suppression, do not overload fitting.



MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

### Elastomeric Round Mount Catalogue Number : 9000111 : Rev. 03 Dated 30-06-2023











#### 1. Compliance:

British Standards, BS 3974 : Part I

#### 2. Application:

Suitable for high frequency vibration / noise generated from Fan Coil Units, Axial Fans, Pumps, Blowers etc...

#### 3. Product Features:

3.1 High strength bond and specially compounded elastomers assure a long life and high load carrying capacity.

3.2 Low cost, light weight, compact, easy to install and maintenance free.

#### 4. Selection / Ordering:

Static Load

SELECTION TABLE - ELASTOMERIC ROUND MOUNTS (Table No: ERM-300623)										
Size	Туре	Max	Deflec-	DØ	Т	Thread Size &	k Stud Length or			
		Static Load	tion	(mm)	(mm)		Thread Depth			
		(kg)	(mm)			Bolt	Nut			
SRM-13	A	4.5	1.0	13	13	3/16"BSWx13L	3/6"BSWx4 Deep			
SRM-19	A	4.5	1.0	13	13	3/16"BSWx13L	3/6"BSWx4 Deep			
SRM-16	A	4.5	1.0	13	13	3/16"BSWx13L	3/6"BSWx4 Deep			
SRM-19	A	18	3.0	19	19	<sup>1</sup> /4"BSWx19L	¼"BSWx6 Deep			
	В	25	3.0	19	19					
SRM-20	A	6.0	3.0	20	25					
	В	6.0	3.0	20	25					
	A	16	1.5	25	19	5/16"BSWx22L	5/18"BSWx6 Deep			
	В	22	1.5	25	19					
SRM-25	A	30	3.5	25	20					
	В	45	3.5	25	20	M6x1Px13L	M6x1Px6 Deep			
SRM-25	A	50	3.5	25	22	M6x1Px13L	M6x1Px6 Deep			
SRM-25	A	37	3.5	25	30					
	В	52	3.5	25	30	M8x1.25Px20L	M8x1.25Px6 Deep			
SRM-30	A	64	3.5	30	22	M8x1.25Px25L	M8x1.25Px6 Deep			
SRM-30	A	22	3.0	30	30	M8x1.25Px21L	M8x1.25Px6 Deep			
SRM-35	A	64	3.0	35	22	3/8"BSWx38L	3/8"xBSWx6 Deep			
	A	16	1.5	35	25					
	В	21	1.5	35	25	3/8"BSWx38L	3/8"xBSWx6 Deep			
SRM-38	A	70	4.0	38	25					
	В	110	4.0	38	25	M8x1.25Px17L	M8x1.25Px6 Deep			
SRM-38	A	50	6.0	38	38					
	В	67	6.0	38	38	M8x1.25Px17L	M8x1.25Px10 Deep			
SRM-40	В	146	4.5	40	28	M10x1.25Px25L	M10x1.5Px6 Deep			
SRM-40	В	60	5.0	40	30	M8x1.25Px25L	M8x1.25Px6 Deep			
SRM-40	A	43	6.0	40	40					
	В	59	6.0	40	40	M10x1.5Px38L	M10x1.5Px10 Deep			
SRM-50	A	651	5.0	50	40					
	B	110	5.0	50	40	M10x1.5Px22L	M10x1.5Px12 Deep			
SRM-50	B	106	7.0	50	45	M10x1.5Px22L	M10x1.5Px12 Deep			
SRM-50	A	76	7.0	50	50	M10x1.5Px22L	M10x1.5Px12 Deep			

➤Type C,D,E available as per customer requirement

#### Note:

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- *Measurements are subject to 5% tolerance.*

• To achieve good sound suppression, do not overload fitting.





MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# **Elastomeric Floor Mount**

Catalogue Number : 9000112 : Rev. 04 Dated 29-06-2023

#### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and Ashrae Guidelines for Vibration Isolation

#### 2. Application:

Elastomeric Floor Mounts are used to isolate Noise and Vibration from high frequency Mechanical Equipments, typically 1,500 rpm or more. Generally these are used for vibration and noise isolation of wall mounted Condensing Units, Close Coupled Pumps with 5 HP or less Motor Rating, Low Pressure Pack etc..

#### 3. Product Features:

- 3.1 Metal Plate impregnated mounting holes are provided for sturdy anchoring
- 3.2 Serrated Elastomeric bottom plates prevent skidding
- 3.3 As Elastomeric offers excellent resistance towards oil, dirt grease, UV light etc, it more durable in the corrosive outdoors for long life
- 3.4 Colur codes are provided for easy identification

#### 4. Selection / Ordering:

Point load (Calculated to include all variables such as weight of water in / out pipe lines etc if applicable).

5. Installation Guide lines:

Included in packaging.



Model	Colour Code	Rated Load (Kg)	Rated	Dimensions (mm)						
			Deflection(mm)	L	W	Η	BP	D	d	
SFM-A-R	Red	18		80	) 46	40	60	M8	M8	
SFM-A-G	Green	35	8							
SFM-A-B	Blue	50								
SFM-B-R	Red	100		94	60	46	78	M10	M10	
SFM-B-G	Green	140	10							
SFM-B-B	Blue	200								
SFM-C-R	Red	250		135	82		115	M12	M12	
SFM-C-G	Green	350	10			70				
SFM-C-B	Blue	500								
SFM-D-R	Red	600		145	92			M20	M12	
SFM-D-G	Green	700	13			85	120			
SFM-D-B	Blue	900								
SFM-E-R	Red	1200								
SFM-E-G	Green	1800	13	175	130	90	150	M30	M14	

# SELECTION TABLE - ELASTOMERIC FLOOR MOUNT (Table No: EFM-290623)

# **Elastomeric Floor Mount**



#### Note:

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.





MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# **Elastomeric Modular Pads**

Catalogue Number : 9000113 : Rev. 03 Dated 30-06-2023



#### 1. Compliance:

British Standards, BS 3974 : Part I

#### 2. Application:

The Pads are suitable for the isolation of noise, shock and high frequency vibration produced by Mechanical, Industrial or Process Equipments on the floor. Generally used for Wall Mounted Condensing Units, Air Handling Units, Centrifugal Pumps etc... Pads are arranged linearly when required to isolate heavier loads.

#### 3. Product Features:

- 3.1 Superior to metal springs in terms of greater sound insulation ability.
- 3.2 Low cost, easy to install.
- 3.3 Pads are designed for a maximum deflection of approximately 20% of its unloaded thickness.
- 3.4 Load can be distributed over large surface area which reduces efforts in Leveling.
- 3.5 Pads permit loading from 3.5 kg/cm<sup>2</sup> 17.5 kg/cm<sup>2</sup> with maximum rated deflection of 8 mm
- 3.6 Pad consists of 81 Modules of Size : 50 mm x 50 mm with 20 mm thick moulded in compounded Natural Rubber. The unique Square Cell Design allows maximum deflection without Rib Collapse and Sealing against external contaminants.

#### 4. Technical Specifications:

- 4.1 Model : SMRP
- 4.2 Standard Size : 450 mm x 450 mm x 20 mm
- 4.3 Material : Compounded Natural Rubber. Other Elastomers such as EPDM, Neoprene, SBR etc.. available on request.
- 4.4 Loading : Recommended upto 75 kg per module
- 4.5 Deflection : Approximately 3 mm at Rated Load



MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# **Elastomeric** Duct Mount

#### Catalogue Number : 9000114 : Rev. 03 Dated 30-06-2023

#### 1. Compliance:

British Standards, BS 3974 : Part I

#### 2. Application:

To control transmission of noise to the building structure, Starline Duct Mounts serve as acoustic separators between sources of high frequency vibration and their suspension rods. Some example applications are illustrated below.

#### 3. Product Features:

- 3.1 Resilient rubber grommet with steel load distribution cups and extended sleeve, designed to reduce transmission of structure born noise from air ducts and suspended equipments / small pipes.
- 3.2 Supplied complete with top and bottom steel load distribution cups, electrogalvanised after manufacture for maximum corrosion resistance.
- 3.3 Extended sleeve of rubber element prevents metal to metal contact between suspension rod and suspension bracket / trapeze channel.
- 3.4 Available in two different sizes to suit width of duct / equipment suspension channel.
- 3.5 Colour coded for identification of Capacity.







### SELECTION TABLE - ELASTOMERIC DUCT MOUNT (Table No: EDM-300623)

Isolator Col		Colour	Capacity Kg	Dimensi	ons (mm)	Recommended			
	Model	Code	(7.5mm deflection)	Н	D	Suspension Rod			
	SDM-L		30	26	32	M10			
	SDM-A1	Green	50	76	11	M10/12			
SDM-A2		Red	100	20		M10/12			



#### Note:

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.
- To achieve good sound suppression, do not overload fitting.







MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

# Elastomeric Multi Layer Pads

Catalogue Number : 9000115 : Rev. 03 Dated 30-06-2023

#### 1. Compliance:

British Standards, BS 3974 : Part I

#### 2. Application:

Elastomeric Multi Layer Pads are ideal for applications where Pad type mountings are to be used. Featuring multiple patterned rubber sheets separated by steel load distribution plates, they provide better isolation of noise and vibration than single sheet pads.

#### 3. Product Features:

- a) Pad comprises of multiple layers of resilient rubber in series. This permits higher deflection under load than feasible with a single layer.
- b) Load distribution plates ensure full pad area is used and give more linear load deflection characteristics.
- c) Starline Ribbed Multi Layer Pad
  - 1. Unique Diagonal Ribs help to distribute applied load evenly over larger area of pad surface.
  - 2. Alternating raised ribs extend pad load range.
  - 3. Ribs above and below the pad are at right angles to each other, thereby forming non skid surfaces which resist creeping of the equipment.
- d) Starline Square Cell Multi Layer Pad
  - 1. Square Cell pattern has a higher load bearing capacity than ribbed.
  - 2. The Grid Design creates "Suction Pockets" for better grip on equipment / floor surface.
  - 3. The suction pockets make the pad more effective for noise attenuation than ribbed pads.
  - 4. Solid cell periphery extends pad life by preventing ingress of external contaminants.

#### 4. Pads for Bolted Installations :

In installations where equipment is bolted to the floor, the bolt must be isolated from the equipment base. Failure to do so, short circuits the pad and allows travel of noise / vibration to the building structure via the bolt. Starline offers the exclusive feature of Multi Layer Pad with pre drilled central hole and supplied complete with Grommet "G1". The Grommet breaks physical contact between the bolt and the equipment base, thereby permitting the pad to perform optimally.



Multi Layer Pad with Grommet G1



Ribbed Multi Layer Pad (SMLP66R/SMLP44R)



Square Cell Multi Layer Pad (SMLP66SC/SMLP44SC)



Ribbed Multi Layer Pad available in ribbed and Square cell models in all sizes Page: C-32

#### 5. Options:

Both Ribbed and Square Cell Multi Layer Pads are available with Grommet. Add suffix "G" after Model.

#### 6. Installation Guidelines:

- a) The Multi Layer Pad should not extend beyond the equipment base by more than 50 mm.
- b) Wherever the equipment leg has a very small bearing area, cement a 3 mm thick steel load distribution plate over the pad using rubber based adhesive.
- c) Use Starline Multi Layer Pad with Grommet "G1" where the equipment needs to be bolted to the floor.

### SPECIFICATIONS (Table No: EMLP - 300623))

Ribbed Multi Layer Pad	150 mm x 150 mm x 35 mm (SMLP66R)						
0; 1	150 mm x 150 mm x 70 mm (SMLP76R) 100 mm x 100 mm x 35 mm (SMLP44R)						
Sizes <sup>1</sup>	100 mm x 100 mm x 70 mm (SMLP54R)						
Construction <sup>*1</sup>	For SMLP66R and SMLP44R , 2 Layer Ribbed Rubber Sheet, 1 Layer of 16 Gauge Galvanized Steel.For SMLP76R and SMLP54R, 4 Layer Ribbed Rubber Sheet and 3 Layer of 16 Gauge Galvanized Steel.						
Material <sup>*2</sup>	Natural Rubber/Neoprene/EPDM						
Loading	Recommended - 2.8 kg/cm <sup>2</sup> (40 psi) Range : 2 to 4 kg/cm <sup>2</sup> (28 to 57 psi)						
Deflection	Approximately 4.5 mm at recommended load for SMLP44R and SMLP66R.						
	Approximately 9 mm at recommended load for SMLP54R and SMLP76R						
Square Cell Multi Layer Pad	150 mm x 150 mm x 35 mm(SMLP66SC)						
Circo *1	150 mm x 150 mm x 70 mm (SMLP76SC)						
51265	100 mm x 100 mm x 70 mm (SMLP44SC)						
Construction <sup>*1</sup>	For SMLP66SC and SMLP44SC , 2 Layer Ribbed Rubber Sheet, 1 Layer of 16 Gauge Galvanized Steel.For SMLP76SC and SMLP54SC, 4 Layer Ribbed Rubber Sheet and 3 Layer of 16 Gauge Galvanized Steel.						
Material <sup>*2</sup>	Natural Rubber/Neoprene/EPDM						
Loading	Recommended - $3.5 \text{ kg/cm}^2$ (50 psi)Range : 3 to $4.5 \text{ kg/cm}^2$ (43 to 64 psi)						
Deflection	Approximately 4.5 mm at recommended load for SMLP44SC and SMLP66SC.Approximately 9 mm at recommended load for SMLP54SC and SMLP76SC						

<sup>\*1</sup> : Pads with higher number of layers available on request

<sup>2</sup>: Other Elastomers like EPDM, Neoprene, SBR etc.. available on request

Due to policy of continuous improvement, the specifications are subject to change without prior notice.







#### Note:

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.





MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

### Restrained Spring Mount - Model: SRSM 25 mm Standard Deflection Catalogue Number : 9000116 : Rev. 03 Dated 31-12-2015

#### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and ASHRAE Guidelines for Vibration Isolation

#### 2. Application:

Isolation of seismic vibrations for Pumps, Boilers, Cooling Towers, Compressors etc.

#### 3. Product Features:

- 3.1 Spring elements are designed to operate without spring buckling with horizontal stiffness equal to vertical stiffness.
- 3.2 These springs are provided with 50% overload capacity at 1.5 times of rated deflection.
- 3.3 Steel frame with restrained Neoprene snubbers and dual vertical restraint plates are provided to limit movement of the connected machinery up to maximum 3 mm.
- 3.4 Replaceable springs and built in leveling arrangements.
- 3.5 Multi Directional Restraint with vertical limit stops.
- 3.6 The springs are powder coated with appropriate colour coding to facilitate identification.
- 3.7 Provided with Neoprene base pad which can isolate high frequency vibrations of audible range.
- 3.8 The restraining system is capable to withstand 1.0g acceleration force.
- 3.9 Springs are powder coated to 100 microns paint thickness (exceeds 1,000 hours of salt spray test) conforming to ASTM B-117. Options:
  - 1. Frame Hot Dip Galvanised (Prefix "HDG")
  - 2. Spring Neoprene Coated (Prefix "N")
  - 3. Spring Plastic Coated (Prefix "P")

#### 4. Selection / Ordering

Point load (calculated to include variables such as weight of water in pipe lines etc. if applicable)

#### 5. Installation Guidelines

Included in the packing





Model No.	Rated Load (kg)	Spring Colour	Dimensions (mm)							
		8	L	W	Н	BC	D	d		
SRSM25-A50	50	Black								
SRSM25-A100	100	Blue								
SRSM25-A150	150	Grey	120	55	140	100	12	3/8"		
SRSM25-A200	200	Orange								
SRSM25-A250	250	Brown								
SRSM25-A300	300	Purple								
SRSM25-B200	200	Green								
SRSM25-B250	250	Brown								
SRSM25-B300	300	Grey	1							
SRSM25-B400	400	Purple	160	72	180	140	14	1⁄2"		
SRSM25-B500	500	Black								
SRSM25-B600	600	Yellow	1							
SRSM25-B700	700	Blue	1							
SRSM25-C400	400	Brown								
SRSM25-C500	500	Grey	]							
SRSM25-C600	600	Orange	1							
SRSM25-C700	700	Green	]							
SRSM25-C800	800	Brown *	1 180	90	200	160	14	5/8"		
SRSM25-C900	900	Grey *						5,0		
SRSM25-C1000	1000	Orange *	]							
SRSM25-C1100	1100	Green *								
SRSM25-C1200	1200	Orange **	]							
SRSM25-C1300	1300	Green **	]							

~

# SELECTION TABLE - RESTRAINED SPRING MOUNT FOR 25 mm DEFLECTION (Table No. : SRSM25311215-3)

- Locking Bolt "D"



# \* with WHITE Core Spring

\*\* with BLUE Core Spring



Т

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.





MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

### Seismic Cased Restrained Spring Mount - Model: SCRSM

#### (Internally Adjustable) 25 mm and 50 mm Standard Deflection Catalogue Number : 9000117 : Rev. 14 Dated 27-02-2024

#### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and ASHRAE Guidelines for Vibration Isolation

#### 2. Application:

These are widely used as a noise and vibration isolator for Equipment carrying large amount of fluid in motion such as Chiller Units, Pumps, Boilers, Cooling Towers, and Compressors etc. These are also recommended for equipment subjected to external forces such high wind loads, Seismic activity, Machine Loading etc.

#### 3. Product Features:

- 3.1 Multi Directional Restraint with Vertical Limit Stops to limit vertical movement of isolating Equipment.
- 3.2 Replaceable springs.
- 3.3 Epoxy Powder Coated / Hot Dipped Galvanized body.
- 3.4 Springs have a deflection of 25 mm/50mm at Rated Load and are designed with 50% overload capacity to compensate for unexpected Load Variations and to reduce Operating Stress.
- 3.5 Casing incorporate Restraining Plates fitted with Resilient Neoprene Snubbers and Hold down Bolt which limit movement of Machinery to maximum of 3 mm.
- 3.6 The springs are provided with Neoprene Base Pad which can isolate High Frequency Vibrations of audible range.
- 3.7 Built-in Leveling arrangements.
- 3.8 The Restraining System is capable of withstanding up to 1.0 g Acceleration Force.
- 3.9 Springs and Casings have Epoxy Powder Coated finish, rated to withstand 1000 hours of Salt Spray Testing as per ASTM B117 Test Procedure. Optional Neoprene Coated springs are also available on request.
- 3.10 The Horizontal Stiffness of these springs are more than Vertical Stiffness. The springs are designed to have maximum 60% of deflection at Rated Load.
- 3.11 Mounting Holes are provided in isolators for bolting to the structures and to the supporting equipment.



SCRSM A/B/C Body



SCRSM 2C Body



SCRSM 4C Body

# **SELECTION TABLE - FOR 25 mm DEFLECTION SEISMIC CASED RESTRAINED SPRING MOUNT** (Internally Adjustable) (Table No. : SCRSM25-270224)

Model No Rated Load Spring Din	Dimensions (mm)								
(kg) Colour L W H BC	C D	d	Р	D1	D2				
SCRSM25-A25 25 Green									
SCRSM25-A30 30 Brown									
SCRSM25-A50 50 Black									
SCRSM25-A60 60 Yellow									
SCRSM25-A75 75 White 100 00 110 11	1 10	10		10	10				
SCRSM25-A100 100 Blue 138 90 110 11	4   12	10	20	12	12				
SCRSM25-A150 150 Grev									
SCRSM25-A200 200 Orange									
SCRSM25-A250 250 Red									
SCRSM25-A300 300 Purple									
SCRSM25-A400 400 Purple***									
SCRSM25-B200 200 Green									
SCRSM25-B250 250 Brown									
SCRSM25-B300 300 Grev									
SCRSM25-B400 400 Purple 260 100 105 22	0 16	16	25	115	16				
SCRSM25-B500 500 Black 200 100 195 250		10		14.5					
SCRSM25-B600 600 Yellow									
SCRSM25-B700 700 Yellow***									
SCRSM25-C400 400 Brown	_			14.5	16				
SCRSM25-C500 500 Grev									
SCRSM25-C600 600 Orange									
SCRSM25-C700 700 Green									
SCRSM25-C800 800 Brown*									
SCRSM25-C900 900 Grev* 260 100 195 23	0 16	16	35						
SCRSM25-C1000 1000 Orange*									
SCRSM25-C1100 1100 Green*									
SCRSM25-C1200 1200 Orange**									
SCRSM25-C1300 1300 Green**									
SCRSM25-2C1400 1400 Green									
SCRSM25-2C1600 1600 Brown*									
SCRSM25-2C1800 1800 Grev*									
SCRSM25-2C2000 2000 Orange* 200 100 105 25	0 10	10	25	145	10				
SCRSM25-2C2200 2200 Green* 380 100 195 350	0 10	10	35	14.5	10				
SCRSM25-2C2400 2400 Orange**									
SCRSM25-2C2600 2600 Green**									
SCRSM25-4C2800 2800 Green	-		-						
SCRSM25-4C3200 3200 Brown*									
SCRSM25-4C3600 3600 Grev*									
SCRSM25-4C4000 4000 Orange* 380 210 195 350	0 20	24	35	15	20				
SCRSM25-4C4400 4400 Green*				15					
SCRSM25-4C4800 4800 Orange**									
SCRSM25-4C5200 5200 Green**									
SCRSM25-6C5400 5400 Grev*									
SCRSM25-6C6000 6000 Orange*									
SCRSM25-6C6600 6600 Green* 500 000 105 05									
		20		20	24				
SCRSM25-6C7200 7200 Orange** 500 500 195 55	0 36	30	35	20	24				

with WHITE Core Spring
with BLUE Core Spring
with RED Core Spring



### SELECTION TABLE - FOR 50 mm DEFLECTION SEISMIC CASED RESTRAINED SPRING MOUNT (Internally Adjustable) (Table No. : SCRSM50-270224)

Model No.	Rated Load (Kg)	Spring				Dime	nsions	s (mm	)		
1120402 1107	Max	Colour	L	W	Н	BC	D	d	Р	D1	D2
SCRSM50-A010	10	Brown			162	130					
SCRSM50-A015	15	Orange									
SCRSM50-A030	30	Green									
SCRSM50-A040	40	Red									
SCRSM50-A060	60	White	170	75			10	11	20	10	12
SCRSM50-A100	100	Blue	170				10	11	20	12	
SCRSM50-A150	150	Black									
SCRSM50-A200	200	Yellow									
SCRSM50-A250	250	Purple									
SCRSM50-A300	300	Grey									
SCRSM50-C200	200	Red		100	230	227		16	35	14	16
SCRSM50-C250	250	Orange	260				18				
SCRSM50-C300	300	Brown									
SCRSM50-C400	400	Green									
SCRSM50-C500	500	Yellow									
SCRSM50-C600	600	Yellow*									
SCRSM50-C700	700	Yellow **									
SCRSM50-C800	800	Yellow ***									
SCRSM50-2C1000	1000	Yellow									
SCRSM50-2C1200	1200	Yellow*									
SCRSM50-2C1400	1400	Yellow **	380	100	230	350	18	16	35	14	16
SCRSM50-2C1600	1600	Yellow ***									
SCRSM50-4C2000	2000	Yellow									
SCRSM50-4C2400	2400	Yellow*		010		050	20	20	05	1-	20
SCRSM50-4C2800	2800	Yellow **	380	210	230	350	20	20	35	15	20
SCRSM50-4C3200	3200	Yellow **									
SCRSM50-6C3600	3600	Yellow*									
SCRSM50-6C4200	4200	Yellow**	380	300	230	360	30	24	50	20	24
SCRSM50-6C4800	4800	Yellow***	1								
SCRSM50-8C5600	5600	Yellow**	200	400	220	260	96	20	50	74	20
SCRSM50-8C6400	6400	Yellow***	380	400	230	360	30	30	50	24	30

\* with WHITE Core Spring

\*\* with BLUE Core Spring

\*\*\* with RED Core Spring



# Seismic Cased Restrained Spring Mount - Model: SCRSM (Internally Adjustable) 25 and 50 mm Standard Deflection



#### Note:

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.
  To achieve good sound suppression, do not overload fitting.





MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

### Housed Spring Mount

Catalogue Number : 9000118 : Rev. 02 Dated 13-12-2014

#### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and Ashrae Guidelines for Vibration Isolation

#### 2. Application:

The Housed Spring Mounts are used for isolating floor mounted sources of noise and vibration. These are made of nitrile rubber housing, nitrile rubber pads and epoxy powder coated springs. Since springs are housed inside rubber casing, it eliminates low frequency vibrations effectively. The nitrile rubber pads provided below the casing will effectively control vibrations of audible range. These are effectively used in Axial / Centrifugal Fans, Air Handling Units, Chillers and Cooling Towers, Rotary and Multi Cylinder Compressors, Diesel Generating Sets, Mechanical Test Rigs, Isolation of Sensitive Equipment etc..

#### 3. Product Features:

- 3.1 Oil resistant Nitrile rubber housing provides better elimination of vibration and sound.
- 3.2 Housed casing protects the springs from corrosion.
- 3.3 The horizontal stiffness of the spring is more than 80% of vertical stiffness. Also fully closed rubber casing prevents further lateral movements. This makes HSM model spring mounts highly stable and durable in all working environments.
- 3.4 The maximum deflection shall be 60% of total deflection at rated load with 50% overload capacity.
- 3.5 Provided with levelling adjustments.
- 3.6 Neoprene pads of 8-13mm are provided which ensure 3-4 mm deflection.
- 3.7 Colour Coded labels for easy identification.
- 3.8 The HSM mounts are available on following material specifications
  - 3.8.1 Zinc plated metallic casings no suffix
  - 3.8.2 Hot dip galvanized use HDG as suffix
  - 3.8.3 Stainless steel use SS as suffix


	ΠΟΟΘΕΙ		WUUNI SELEG		IADI	- <u> </u>	Ianie	INU	6-4	1-01)			
Part No.	Colour	Rated	Deflection										
	Code	Load(kg)	at Rated Load (mm)	Α	В	С	D	Е	F	G	Н	Ι	J
SHSM10-S	Green	10	20										
SHSM15-S	Black	15	20	1									
SHSM20-S	Yellow	20	20	63	54	60	76	38	M8	48	-	M6	-
SHSM40-S	Blue	40	20										
SHSM70-S	Grey	70	20	I									
SHSM25-A	Green	25	25										
SHSM50-A	Black	50	30										
SHSM75-A	Yellow	75	25										
SHSM100-A	Blue	100	25	88	85	90	110	70	M10	78	-	M8	-
SHSM150-A	Grey	150	25	[									
SHSM200-A	Orange	200	25	]									
SHSM250-A	Brown	250	25										
SHSM300-A	Purple	300	25	]									
SHSM200-B	Yellow	200	25										
SHSM300-B	Blue	300	25										
SHSM400-B	Brown	400	25	]									
SHSM500-B	Orange	500	25										
SHSM600-B	Green	600	25	127	130	150	180	95	M16	111	-	M12	-
SHSM700-B	Pink	700	25										
SHSM800-B	White	800	25	I									
SHSM1000-B	Purple	1000	25	]									
SHSM1200-B	Red	1200	25	]									
SHSM1400-B	Black	1400	25										
SHSM100-C	Blue	100	50										
SHSM200-C	Yellow	200	50										
SHSM300-C	Blue	300	50	155	130	150	180	95	M16	111	-	M12	-
SHSM400-C	Brown	400	50										
SHSM500-C	Orange	500	50										

### HOUSED SPRING MOUNT SELECTION TABLE (Table No.: C-41-01)



Page: C-42

### HOUSED SPRING MOUNT Theoretical Isolation Efficiency (Table No.: C-40-01)

Machine Speed	Efficiency %						
(rpm)	15 mm defl.	25 mm defl.	50mm defl.				
300	Do Not Use	34.0	75.2				
500	68.7	83.3	92.3				
750	88.1	93.2	96.7				
1000	93.7	96.3	98.2				
1200	95.7	97.4	98.7				
1500	97.3	98.4	99.2				
1750	98.0	98.8	99.4				
2000	98.5	99.1	99.5				

The above figures are theoretical values only based on the vertical natural frequency of the spring system assuming infinitely stiff structural supports. The effects of high frequency spring coil resonances on low frequency performance are also ignored.





### Note:

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.
- To achieve good sound suppression, do not overload fitting.



Page: C-43

Starline Enterprises

Head Office: MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

### Inertia Base Frames Catalogue Number : 9000120 : Rev. 01 Dated 20-02-15

### 1. Compliance:

1.1 Designed according to ASHRAE guidelines

### 2. Application:

- 2.1 Inertia Base Frames are recommended for installation under pumps, compressors, large fans, open type centrifugal chillers, IC Engines, Generators and other equipments likely to have high imbalance forces and large amplitude of vibrations. Inertial Bases:
  - 2.1.1 Reduce amplitude of vibrations and thereby ensure smoother working, reduced noise and vibration.
  - 2.1.2 Lower the centre of gravity of supported equipment and thereby reduce equipment sway.
  - 2.1.3 Minimize motion of equipment during startup and shut down.
  - 2.1.4 Provide a means for mounting equipment on vibration isolators.

### 3. Product Features:

- 3.1 Rigid welded steel pouring frames with reinforcement bars and isolator brackets for concrete inertia bases. Supplied in rectangular or T-shape, complete with vibration isolators.
- 3.2 Fabricated using formed steel channel. Optionally available in Structural Steel Channel construction.
- 3.3 The frame height shall be minimum 8- 10% of longest span between isolators with minimum height of 150mm. Standard Heights : 150, 200, 240 and 300 mm. Higher frames can be supplied for special applications.
- 3.4 Available for any equipment dimension. Rectangular shape supplied as standard. T-shape offered where it is required to support elbows of horizontal split casing pumps on the base itself.
- 3.5 Reinforced with 12 mm OD welded in steel bars each way at approximately 200 mm spacing.
- 3.6 Provided with height saving isolator fixing brackets. External brackets are supplied as standard. Recessed brackets are offered in case of space constraints.
- 3.7 Painted with NC Grey Primer.
- 3.8 Supplied together with Starline Isolators. Selection of mount type / models forms part of design process to provide a complete vibration isolation solution. Frames are compatible with open, cased and restrained mounts. These springs are designed with a horizontal stiffness equal to vertical stiffness to assure stability. Also spring will have capacity to over load 50% beyond rated capacity. Depending on isolation frequency, amplitude and location, any spring deflection can be provided.
- 3.9 Pre-located anchor bolts shall be placed inside base frame.
- 3.10 Snubbers shall be provided as standard accessory.



Concrete filling by others



Fig. 1: Rectangular base with external brackets (supplied as standard)

### Inertia Base Frames

### 4. Installation Guide lines:

- 4.1 Place the frame on marine ply or plastic sheet and pour concrete. Position and fix the equipment on the concrete inertia base.
- 4.2 Raise the inertia base with attached equipment over the vibration isolators, maintaining a house keeping gap of about 50 mm under the base. Follow standard spring mount installation procedure.

### 5. Ordering:

- 5.1 Concrete inertia bases are custom made for specific installations. Our Staff will propose the optimal frame design and vibration isolator selection for the application. Provide details of :
  - 5.1.1 Equipment to be mounted (dimensions, total weight, weight distribution, imposed loads, motor rating, pipe connection sizes etc..)
  - 5.1.2 Location of equipment in building.
  - 5.1.3 Project specifications for vibration isolation.

### 6. General Design Guidelines followed:

- Starline Inertia Base Frames comply fully with the design recommendations made by ASHRAE for Type C - Concrete Inertia Bases. The broad design guidelines followed are:
- 6.1 Frame height is at least 8 to 10% of longest span between isolators, with a minimum of 150 mm. ASHRAE recommendations relating height to motor ratings are followed where applicable. Height in excess of 300 mm is rarely proposed.
- 6.2 For pumps, if space permits and elbow offset from flange is exactly known, it is preferable to size the base to support elbows. If elbows overhang the base, it is crucial to provide isolation below them.
- 6.3 While ASHRAE states that mass of the concrete inertia base is not usually a design consideration, we recommend it should be at least equal to the supported load. Frames are designed accordingly.
- 6.4 Rectangular frames with external brackets are supplied as standard. Other designs are proposed if needed.

### 7. Notes:

- 7.1 Mounts shown with each base are for illustration only. Open, Cased or Restrained Mounts may be used as required.
- 7.2 Large bases may have more than four isolator fixing brackets.



Fig 2: Rectagular base with recessed brackets (add suffix 'RB' to model)



Fig 3: T-Shape base with external brackets (add suffix 'T' to model)



Fig 4: T-Shape base recessed brackets (add suffix 'T-RB' to model)





**Head Office:** 

MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

### Industrial Stainless Steel Bellows (SISB)

Catalogue Number : 9000121 : Rev. 01 Dated 02-02-2016

### 1. Introduction

All materials expand and contract with thermal change. In the case of piping, this dimensional change can produce excessive stresses throughout the piping system. Metal Bellows are cost effective means of achieving piping flexibility. The expansion joints are installed within ten pipe diameters downstream of elbows, tees, valves or vibrating sources.

### 2. Salient Features:

- 2.1 Bellows are made from Stainless Steel convolutions of sufficient thickness and reinforcement necessary to contain rated pressure.
- 2.2 The Bellows are designed for high cycle life to provide reliable decades of operation.
- 2.3 Flow liners (optional) provided to minimize turbulence, pressure drop, erosion etc.
- 2.4 Limit rods are provided to limit axial movement, while retaining ability to accommodate angular rotation. These can be provided with wide variety of material like GI, HDG, SS 304, SS 316L, SS 321 etc.
- 2.5 These Bellows are available on wide variety of materials such as SS 304, SS 316L, SS 321 etc.
- 2.6 The Flanges and Collars are provided with Epoxy coated Steel.

### 3. Non Destructive Testing:

- 3.1 Radiography Test
- 3.2 Liquid Penetrant Test
- 3.3 Magnetic Particle Test
- 3.4 Ultrasonic Test
- 3.5 Halogen Leak Test
- 3.6 Air Jet Leak Test
- 3.7 Hydrostatic Pressure Test

### 4. Destructive Testing:

- 4.1 Fatigue Cyclic Life Test
- 4.2 Squirm Test
- 4.3 Meridional Yield Rupture Test



Standard Type

Model	Pipe Size Inch (mm)	Length mm	Axial Compression mm	Axial Elongation mm	Angular Movement in Degrees
SISB 025	1" (25 mm)	200	20	20	15
SISB 032	1 ¼" (32 mm)	200	20	20	15
SISB 040	1 ½" (40 mm)	200	20	20	15
SISB 050	2" (50 mm)	200	20	20	15
SISB 065	2 ½" (65 mm)	200	20	20	15
SISB 080	3" (80 mm)	200	20	20	15
SISB 100	4" (100 mm)	250	25	25	15
SISB 125	5" (125 mm)	250	25	25	15
SISB 150	6" (150 mm)	250	25	25	15
SISB 200	8" (200 mm)	250	25	25	15
SISB 250	10" (250 mm)	250	25	25	15
SISB 300	12" (300 mm)	250	25	25	15
SISB 350	14" (350 mm)	300	25	25	15
SISB 400	16" (400 mm)	300	25	25	15
SISB 450	18" (450 mm)	300	25	25	15
SISB 500	20" (500 mm)	300	25	25	15
SISB 610	24" (610 mm)	300	25	25	15

### SELECTION TABLE - INDUSTRIAL STAINLESS STEEL BELLOWS (Table No. SISB020216)

### **Optional Designs:**



Weld Neck Type



Stub Flange

Technical Data:		
Temperature Range	:	- 50°C to 400°C
Pressure Range	:	10 - 40 bars
Burst Pressure	:	4 times Rated Pressure
Fluids for handling	:	Water, Weak Acids / Alkalies
Flange	:	Epoxy Coated Flanges
Flow Liner	:	No Liner as standard. SS 304, SS 316L and SS 321 on request
Bellows	:	SS 304 Standard. SS 316L and SS 321 as per request
Tie Rods	:	Galvanised Rods as Standard. Hot Dipped Rods, SS 304, SS 316 and SS
		321 Rods as per request.



Page: C-47

### **INDUSTRIAL STAINLESS STEEL BELLOWS**

### Model Decoding for Ordering:

Basic Model with Size (7 Digit)	End Connection (1 Digit)	Pressure Range (2 Digits)	Bellow Material (3 Digits)	Flow Liner Material (3 Digits)	Tie Rod Material (3 Digits)
	-O -Standard	-10- (for PN 10)	-304- (for SS 304)	-000- (for No Liner)	-000- (No Tie Rod)
	-W -Weld Neck	-16- (for PN 16)	-316- (for SS 316L)	-304- (for SS 304)	-0GI- (for Galvanised)
As per Previous	-S - Stub Type	-20- (for PN 25)	-321- (for SS 321)	-316- (for SS 316L)	-HDG- (for Hot Dip)
Table		-40- (for PN 40)		-321- (for SS 321)	-304- (for SS 304)
					-316- (for SS 316L)
					-321- (for SS 321)

*Note:* 

- Due to policy of continuous improvement, the specifications are subject to change without prior notice
  Measurements are subject to 5% tolerance.



Page: C-48



### **Head Office:**

MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

### **Elastomeric Floating Floor Mounts**

Catalogue Number : 9000124 : Rev. 02 Dated 30-06-2023



### 1. Compliance:

1.1 British Standards, BS 3974 : Part I

### 2. Application:

2.1 The Pads are suitable for the isolation of noise, shock and high frequency vibration produced by Mechanical, Industrial or Process Equipments on the floor.

### 3. Product Features:

- 3.1 Superior to metal springs in terms of greater sound insulation ability.
- 3.2 Low cost, easy to install.
- 3.3 Pads are designed for a maximum deflection of approximately 20% of its unloaded thickness.
- 3.4 Load can be distributed over large surface area which reduces efforts in Leveling.
- 3.5 Floating Floor Pads are available in various sizes like like 2x2x2 inches, 2x2x3 inches, 3x3x4 inches etc.. to suit variety of applications.

### 4. Technical Specifications:

4.1	Model	:	FMRP
4.2	Standard Size	:	450x450x50 mm, 450x450x75 mm, 450x450x100 mm
4.3	Material	:	Compounded Natural Rubber. Other Elastomers such as
			EPDM, Neoprene, SBR etc available on request.
4.4	Loading	:	Recommended upto 75 kg per module



**Head Office:** 

MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

### Pre-Compressed Combination Spring Hangers - Light Duty

### Catalogue Number : 9000125 Rev. 03 dated 01-06-2015

### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and Ashrae Guidelines for Vibration Isolation

### 2. Application:

Generally for light duty applications like small fans, humidifiers, variable air volume boxes, small fan coil units, small size piping and air ducting in mechanical rooms.

### 3. Product Features:

- 3.1 Double protection against transmission of noise to structures is assured as the neoprene component provides an effective acoustic barrier and the moulded neoprene cup below the spring prevents metal to spring contact, thus effectively isolating the suspended equipment from the structure.
- 3.2 The Springs are designed to have a stiffness ratio more than unity which ensures buckle free operation throughout load range.
- 3.3 Suspension rod misalignment (30 degree arc) is compensated in hanger design.
- 3.4 Locking rubber bush centralizes the spring and prevents dislocation.
- 3.5 Printed Deflection scale to indicate total spring deflection.
- 3.6 Pre-Compress spring effectively minimises transfer of variation in the pipe load/ equipment during installation thus protecting equipment connections/flexible joints.
- 3.7 Springs are powder coated with appropriate color coding to facilitate identification.
- 3.8 Frame is made of G.I. steel and powder coated to 100 microns paint thickness (exceeds 1000 hours of salt spray test) and conforming to ASTM B-117.

Options:

- 1) Frame Hot Dip Galvanised (Prefix Part Number with "HDG")
- 2) Spring Neoprene Coated (Prefix Part Number with "N")
- 3) Spring Plastic Coated (Prefix Part Number with "P")
- 3.9 The Springs are designed to have additional 50% of rated load at 1.5 of rated deflection.

### 4. Selection / Ordering:

Point load (Calculated to include all variables such as weight of water in pipe lines etc if applicable).

5. Installation Guide lines: Included in packaging.



SELECTION TABLE FOR PRE COMPRESSED COMBINATION SPRING HANGERS - LIGHT DUTY (Table No: C-17-01)

Isolator	Rated	Rated	Spring	Dimensions (mm)						
Model	Deflection	Load (kg)	Colour	L	W	SF*	RF	Η	d(max)	E(approx)
SPCCSHL-M6		6	Orange							
SPCCSHL-M9		9	Grey							
SPCCSHL-M15	13 mm	15	Blue	58	50	44	30	100	M12	40
SPCCSHL-M21		21	Green							
SPCCSHL-M28		28	White							
SPCCSHL-P6		6	Green							
SPCCSHL-P9		9	Red							
SPCCSHL-P15	25 mm	15	Black		50		20		110	40
SPCCSHL-P21		21	Yellow	30	50	64	30	120	MIZ	40
SPCCSHL-P28		28	Blue							
SPCCSHL-P35		35	Grey							
SPCCSHL-P50		50	Orange							

Represents average free height in each grouping of models. Height of some models in group may vary slightly from this figure.



### Note:

\*

- Due to policy of continuous improvement, the specifications are subject to change without prior notice.
- Measurements are subject to 5% tolerance.

• To achieve good sound suppression, do not overload fitting.



Page: C-51



### **Head Office:**

MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

### Precompressed Hanger - Light Duty Catalogue Number : 9000126 : Rev. 01 Dated 23-06-2021

### 1. Compliance:

- 1.1 Designed to BS 1726 -1 : 1987
- 1.2 Tolerance to BS 1726-1 : 2002
- 1.3 SAE and Ashrae Guidelines for Vibration Isolation

### 2. Application:

Suspension of water pipe line and seismically restrained rotating equipments.

### 3. Product Features:

- 3.1 The Springs are designed to have a stiffness ratio more than unity which ensures buckle free operation throughout load range.
- 3.2 Suspension rod misalignment (30 degree arc) is compensated in hanger design.
- 3.3 Direct connection to lower suspension rod by means of a threaded rod coupler.
- 3.4 Printed deflection scale to indicate total spring deflection.
- 3.5 Pre compressed spring effectively minimizes transfer of variations in pipe load during filling of pipes thus protecting equipment connections / flexible joints and also prevents overloading of the main equipment isolators.
- 3.6 Locking rubber bush centralizes the spring and prevents dislocation.
- 3.7 Springs are powder coated with appropriate color coding to facilitate identification.
- 3.8 Frame is made of G.I. steel and powder coated to 100 microns paint thickness (exceeds 1000 hours of salt spray test) and conforming to ASTM B-117.
- 3.9 The Springs are designed to have additional 50% of rated load at 1.5 of rated deflection.

### Option:

- 1) Frame Hot Dip Galvanised (Prefix Part Number with "HDG")
- 2) Spring Neoprene Coated (Prefix Part Number with "N")
- 3) Spring Plastic Coated (Prefix Part Number with "P")
- 4. Selection / Ordering:

Point load (Calculated to include all variables such as weight of water in pipe lines etc if applicable).

5. Installation Guide lines:

Included in packaging.



Isolator Model	Rated	Rated	Spring		Din	nension (	(mm)	
	Deflection	Load (kg) Colours		L	W	F*	Η	d(max)
SSHL-M6C		6	Orange				75	
SSHL-M9C		9	Grey		50	54		
SSHL-M15C	13 mm	15	Blue	65				M10
SSHL-M21C		21	Green					
SSHL-M28C		28	White					
SSHL-P6C		6	Green				90	M10
SSHL-P9C		9	Red					
SSHL-P15C		15	Black					
SSHL-P21C	25 mm	21	Yellow	65	50	70		
SSHL-P28C	-	28	Blue					
SSHL-P35C		35	Grey					
SSHL-P50C		50	Orange					

### SELECTION TABLE FOR PRECOMPRESSED HANGERS - LIGHT DUTY (Table No: SHLD-24-11-20)

\* Represents average free height in each grouping of models. Height of some models in group may vary slightly from this figure.

### Precompressed Hanger - Light Duty





• Due to policy of continuous improvement, the specifications are subject to change without prior notice.



- Measurements are subject to 5% tolerance.
- To achieve good sound suppression, do not overload fitting.

Page: C-53



### **Head Office:**

MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in www.starlinesupports.com

### Elastomeric Hanger - Light Duty

Catalogue Number : 9000127 : Rev. 01 Dated 06-02-2024

### 1. Notes:

- 1. Nuts, washer and rods by others.
- 2. Select isolator within operating load range.
- 3. To order element only, specify model APHE instead of APH.

### 2. Product Features:

- · Element incorporates projected collar to prevent metal to metal contact between rod and bracket.
- · Embedded steel plates on top of element for uniform loading.
- · Oil + Water resistant element
- · High deflection, low natural frequency.
- Elements colour coded for easy field verification (Colour coding can be by "dot / stripe" or "complete element")



Model	Colour Code	Rated Load (kg)	Rated	Dimensions (mm)				
			Deflection(mm)	А	В	С	D	E
SNHL-A	RED	10	8	60	32	40	47	M12
SNHL-B	GREY	20	8	60	32	40	47	M12
SNHL-C	YELLOW	30	8	60	32	40	47	M12
SNHL-D	WHITE	40	8	60	32	40	47	M12
SNHL-E	BLUE	50	8	60	32	40	47	M12

### **SELECTION TABLE (Table No : EHLD-060224)**

### Elastomeric Hanger - Light Duty



\* All thread rods, level adjustment nuts and washers by others.

### **Installation Guidelines:**

- 1. Co-ordinate location of each isolator with project submittals.
- 2. Attach hanger box to upper all-thread rod which should already be attached to structure.
- 3. Align lower all-thread rod through entre of hanger box bottom hole and attach to lower level adjustment nut.
- 4. Elevate equipment, duct or pipe and attach to lower all-thread rod. Be careful not to overload any one hanger.
- 5. If necessary, adjust level of equipment, duct or pipe with lower / upper level adjustment nuts.
- 6. Check to ensure adequate horizontal clearance between lower all-thread rod and bottom hole of hanger box.

### Note:

• Due to policy of continuous improvement, the specifications are subject to change without prior notice.



• To achieve good sound suppression, do not overload fitting.



Page: C-55

### **SOLE DISTRIBUTOR**

Enterprises

Head Office: MARS Complex, Poothole Road, Thrissur, Kerala India - 680 004. Ph: +91 487-2385001, 2385002 E-mail: customerservice@starline.in, www.starlinesupports.com

Factory: Sree Sai Krithika Industrial Estate 4 / 293, S.F. No. 221 & 91, Sreerapalayam Post - Podipalayam, Coimbatore, Tamil Nadu, India - 641 105







# **Previous Project Approvals**

Page 1 of 1

Head Office: Mars Complex, First Floor , 38 / 791 - Poothole Road , Thrissur , Kerala, INDIA - 680 004 Factory: Sree Sai Krithika Industrial Estate, 4 / 293 , S.F. No. 221 & 91, Seerapalayam, Podipalayam Post, Coimbatore, Tamil Nadu, INDIA - 641 105

Phone : (91) (487) 238 5001 , 238 5002 Email : purchase@starline.in

### JAZAN PORT & CITY INFRASTRUCTURE PROJECTS DEPARTMENT



City Port Division SAPMT Site Office – Jazan Economic City Baish Highway- Kingdom of Saudi Arabi5

			1	DOCUMENT	TRANSMIT	TAL			
TO:		HASS	AAN ABDEEN		FROM:	MOHAMAD B. D.	ABLIZ		
Addre	ess:	Projec Branch for Col P.O. Bo	t Manager Al-Kifah Hold htracting 5x 7973, Damr	ing Company nam – 31472, KSA	Address:	Project Manager JEC Commercial Po SAPMT Site Office - Baish Highwav-KSA	rt - Onshore Project - Jazan Eco. City		
@Mail Addre	l ss	hassa	an.abdeen@	alkifah.com	@Mail Address	mohamad.dabliz	@aramco.com		
Conta	ct No.	+966 5	05155402		544729				
Contr	act No	. 66000	38281 (IK)		BI-25-000	)37-0008	100		
TRAN	ISMIT	ALNO.:	CPD	KCC(ONS)-T-382	B DATE:	Mar	ch 30, 2019		
SU	JBJECT	Mat	erial Techn	cal Requisition –	Vibration Isolato	r			
				o Objection as Note o Comment onditionally Approve	d 🛛 Reviewed v 🗆 Revise & re ed	vith comment submit	Information Rejected		
Item No.	Qty	RE	F. No.	Doc. No.		Description			
1		KCC-JEC(C 4	CC-JEC(ONS)38281-T- 4966 KCC-JEC(ONS)38281-M 0233 Rev. 00			Material Technical Requisition – Vibration Isolator			
	4	52 - VLASK VLA	0	***** Not	thing follows *****		**************************************		
Actio	n Requ	ired:	Please refer t	o attached review	response.	/	7		
Rema	arks:	4				ca/ Z	5		
ORIGI	INATO	R:	MOHAMA	B. DABLIZ	SIGNATURE:	NT RI	/		
				RESTRIC	TED DOCUMENTS				
7	This docu	ment has bee	n reviewed by SA	PMT. Such review does n	of relieve the Contractor o	f their responsibilities unde	r the terms of the contract		
					an energy into contractor o				
RECEI	VED B	γ:			-				
			PRINT	ED NAME	SIGNATURE	TEL. NO.:	DATE		
						AL KIFAH CON PROJECT CONT DOCUMENT CO	ITRACTING CO. ROL DEPATMENT NTROL SECTION		
						been	CHARGE IN		
						neur			



Date: 26 March 2019

### TRANSMITTAL FORM CONTRACT NO.: 6600038281 BI/JO. NO.: 25-00037 / 0008 TRANSMITTAL NO. KCC-JEC(ONS)38281-T-04966

### SAUDI ARAMCO'S CITY PORT PROJECTS DIVISION JEC CITY COMMERCIAL PORT – ONSHORE JAZAN ECONOMIC CITY

Attention : MR. MOHAMAD B. DABLIZ : Company Representative

Subject : MATERIAL TECHNICAL REQUISITION – VIBRATION ISOLATOR

X TECHNICAL SUBMITTAL	HSE
SHOP DRAWINGS	KDI-QHSE-11
AS BUILT DRAWING	REPORTS
DESIGN	REQUEST FOR INFORMATION (RFI)
ISSUE FOR REVIEW	OTHERS

### SUBMITTAL REQUEST NUMBER

QTY.	DOCUMENT / DRAWING NO.	REV.	TITLE	ACTION
02	KCC-JEC(ONS)38281-	00	Material Technical Requisition – Vibration	FOR
sets	MTR-0233-00		Isolator	APPROVAL

Released by: N ABDEEN HAS CONTRACTOR REPRESENTATIVE





INFO.KCC@ALKIFAH.COM WWW.ALKIFAHCONTRACTING.COM

-	
	10-00
	100
	Sec. 1
10	
-	
	- 0
	9 F
	052
	30
	0 5
	20
	20
	:0

# DOCUMENT REVIEW COMMENTS

Projec	ct Name:	Port On Shore	Issued Date:	26 March 2019
Transı	mittal Number:	KCC-JEC(ONS)38281-T-4966	Received Date:	27 March 2019
Docur	nent Number:	KCC-JEC(ONS)38281-MTR-0233-00 REV00	Completed Date:	27 March 2019
Docur	ment Title:	Material Technical Requisition – Vibration Isolator	BI/JO No.: 25-00037-0008	Contract No.: 6600038281
ltem No.	Section No. / Title	Comments- No Comment	Comment By	Remarks
Ħ	9COM	No Comment	EAW	No Comment
2	Vendor Selection	No Comment	EAW	No Comment

Reviewed by:

Ernest Williams, Material Specialist Saudi Aramco: Company General Use 1



# DOCUMENT REVIEW COMMENTS

Project	Name:	JEC Commercial Po	ort - Onshore		BI/JO No .:	Contract No.:
i i				20	25-00037-008	6600038281
Transmi	ittal Number:	Document & Revis	sion Number:	Document Title:		
KCC-JEC	(ONS)38281-T-04966	KCC-JEC(ONS)3	8281-MTR-0233-00	MTR -VIBRATION ISOLATOR	2	
Review	ed by:	Roehlito V. Javier	7		Completed Date:	3/30/2019
ltem No.	Section No. / Title		0	omments	Rem	arks
ਜ	General	1. Recon the Ind 2. Selecti ASHRA Fans s wind. 3. Selecti	imended Vibration Isola dustry Standards. ions for Equipment Vibr AE recommendation Cha hould be coated Spring ion should be in accorda	tion Springs, Pad, Sway Hangers, etc. conforms to ation Isolation should be in accordance with pter 48 – All Roof Installed Condensing Units and Restrained Type to prevent movements due to ince with the Vendor recommendations.	REVIEWED WI	TH COMMENTS

Saudi Aramco: Company General Use 1

			and the second se		
		OWCO	Project - Ri	is Al-	Charles .
SICNAT	STATE CHAIR	SWCC	ridjene is	USED AN	http://www.au
	I OE	DA DA	TE S	Le.	ENGERONESU
C	APPLICATION FOR	MATERIALA	PROVAL	break	NA .
Ste 1	Project Tittle: ( 너희 ) 써	حطه التعلية ايراس ال	ىجەع (لمىكلى لە	روع ال	ÚL8
TO.	Lever		DATE		11-JAN-2022
EH V	EF-		YOUR REF. N	10	0093
SR	SF		MTL. NO.RE	F	ICF-EF-MIM-00
15,13	102		REVIND.		A
ALRIFA	H CONTRACTING COMPANY	Contractor/ Con	sorthin		
plier - Material	Joint Gulf Business Co	orp (IGB Corp) - Vib	ration Isolat	ors Wi	th Selection
N					21 212 1 102241.222
Name and Street	PLACE OF ORIGIN OF MATERIAL	1 CHE	(* 1 SAUD	ARABI	(A 1 DIHER
ROUTION.	SAUDI ADADIS MATCHAL ATTAC	THE D	A LYDE		1. 1. 11.12
SUPPLIER	Inhit Soll Decime Con	n IIGB Comb. Debi	UNIONA LA	111	6.1 m
Contraction of the	point than an an an an	is from cloubly - right	-	FAX	
MEG.	Starline E	Enterprises		TEC:	
				FAX:	
SCHURCER.		India			
	(<) APPROVED BY EWICLD		) NOT REQUE	TED	
TICIN	VOLUME NO & TITLE				
	ANTIOLE .				
	CACIE.	CF-M.	C RAME F		
THEN?	INTERNATIONALIS	1	O DRAMMES		
	O CATALOGUE		DTHERS (CD)		
1030P	WORK CONTRACTOR OF THE OWNER	Second Second	1		
11.2		NOILE	4424 111		
		المالية الأمدانية الم	www. We	EL.	
	15	And a state of the	N	1912	
0	(d) SAME	DIFFERENT	1	) NOT	APPLIED
1		BUT INTERCACOURSE	مشروع الد	11-	
G	ADDISONED ASSAULTED	السعلي مراد			
Q	RELECTED	DAUL			
PECIFICATION	FULLY COMPLIAN	CE T	NON COMPS	LANCE	
		TO         EH       VEF         SR       SF         IKH       KF         NH       KF         Diet       Material         PLACE OF ORIGIN OF MATERIAL         RTATION       PLACE OF ORIGIN OF MATERIAL         SUPPLER       Joint Gulf Business Cor         MEG.       Starline I         STEINER       Joint Gulf Business Cor         MEG.       Starline I         STEINER       (*) APPROVED BY BWSC C         MEG.       Starline I         STEINER       (*) APPROVED BY BWSC C         MEG.       (*) APPROVED BY BWSC C         STEIN       VELIABLE NO & TITLE         MINOLE       PAOE         ITEN       (*) SAME         (*) FREE SLIST FER ED GERTHINGS         (*) FREE SLIST FER ED GERTHINGS         (*) FREE SLIST FER ED GERTHINGS         (*) SAME         (*) SAME         (*) SAME         (*) SAME         (*) SAME	TO         EH       VEF         SSR       SF         NH       RSF         ALRIFAH CONTRACTING COMPANY       Contractor/Company         Joint Gulf Business Corp (JGB Corp) - Vib         PIACE OF ORDIN OF MATERIAL         ENDENCE OF NON AVAILABEL ATLACHED         SUPPLIER       Joint Gulf Business Corp (JGB Corp) - DAIM         MFG       Starline Enterprises         SCIURER       Joint Gulf Business Corp (JGB Corp) - DAIM         MFG       Starline Enterprises         SCIURER       Joint Gulf Business Corp (JGB Corp) - DAIM         MFG       Starline Enterprises         SCIURER       Joint Gulf Business Corp (JGB Corp) - DAIM         MFG       Starline Enterprises         SCIURER       (*) APPROVED BY ENVELD         MFG       Starline Enterprises         SCIURER       (*) REE SLIST F R ED CEPTINGATEB         (*) SAME       JOIFTEIRE HI         (*) RAME       JOIFTEIRE HI         (*) APPROVED AS HOTED       JOIFTEIRE HI         (*) APPROVED AS HOTED	TO       DATE         IEH       VEF         ISR       SF         IKH       KF         ALREAR CONTRACTING COMPANY       Contractor/Consortium         PLOCE OF DRIGH OF MATERIAL       (* ) SAUD         PLOFMinimized       Joint Gulf Business Corp (IGB Corp) - Vibration Isolate         RTATION       PLACE OF DRIGH OF MATERIAL       (* ) SAUD         RTATION       PLACE OF DRIGH OF MATERIAL       (* ) SAUD         RTATION       ENDERCE OF NON-AVAILABELITY OF       (.) YEB         SUPPLER       Joint Gulf Business Corp (JGB Corp) - DAIMMAM       (.) YEB         SUPPLER       Joint Gulf Business Corp (JGB Corp) - DAIMMAM       (.) YEB         SUPPLER       Joint Gulf Business Corp (JGB Corp) - DAIMMAM       (.) YEB         SUPPLER       Joint Gulf Business Corp (JGB Corp) - DAIMMAM       (.) YEB         SUPPLER       Joint Gulf Business Corp (JGB Corp) - DAIMMAM       (.) YEB         SUPPLER       Joint Gulf Business Corp (JGB Corp) - DAIMMAM       (.) YEB         SUPPLER       Joint Gulf Business Corp (JGB Corp) - DAIMMAM       (.) YEB         SUPPLER       Joint Head       (.) YEB       (.) YEB         SUPPLER       Joint Adaption Title       (.) YEB       (.) YEB         NTEM       (.) YEB	TO       EATE         YOUR REF. NO       MTL. NO. REF.         ALKIFAN CONTRACTING COMPANY       Contractor/ Consortium         Joint Gulf Business Corp (IGB Corp) + Vibration Isolators Will         PletrMinonial       Joint Gulf Business Corp (IGB Corp) + Vibration Isolators Will         PletrMinonial       Joint Gulf Business Corp (IGB Corp) + Vibration Isolators Will         PletrMinonial       Joint Gulf Business Corp (IGB Corp) + Vibration Isolators Will         INTATION       ENDERCE OF DROMINDE MATERIAL       (* 1 BAUUI ANABR         ENDERCE OF NON AVAILABELTY OF       ( ) YES         SUPPLER       Joint Gulf Business Corp (IGB Corp) - DAMMAM         INTEL       Joint Gulf Business Corp (IGB Corp) - DAMMAM         NRG       Starline Enterprises       TEL         SUPPLER       Joint Gulf Business Corp (IGB Corp) - DAMMAM       TEL         NRG       Starline Enterprises       TEL         NRG       Starline Enterprises       India         (*) APPROVED IN EWCLE       ( ) NOT BEDUMENT       ( ) NOT BEDUMENT         NED       APPROVED IN EWCLE       ( ) BRAWINGES       ( ) DIFERS (GO)         NED       APPROVED AS ADTED       ( ) DIFERS (GO)       ( ) NOT         NED       APPROVED AS ADTED       ( ) DIFERS (GO)       ( ) NOT <t< td=""></t<>





# REQUEST FOR TECHNICAL APPROVAL MATERIAL REQUISITION

SUBMITAL CODE ARCHITECTURAL CIML STRUCTURAL FIPINGANECHANICAL	ELECTRICAL COMMUNICATION	Differs .	TERMUS SPECIFICATION SYSTEM	INSPECTION LEVEL	NON INSPECTABLE	DIAL I ACTION	HU COMMENT		semittal and responded Brough		Page 1
ROCEOLINES C	WNGGSDEC. 1	0	T. 30-32 SAMO	NMR FORM	NN	IFOR SAUDI ARAMCO U VIEW / COMMENT / APPRC	HOCEPAN AMM BARAN AMM BARAN MALANANA MALANA MALANA MALANA MALANA MALANAN		be submitted through tran Email,		
SA ENGINERANS S NIA SA ENGINERANS P	DATA SHEETS / DRAV		RE-701013 SH	175		RE	APPENDING A		This document will		
KINATIONAL COMPLEX FOR BES AND SERVICES	SCREPTION		OLATORS	FORM SA	NN	DOR NAME & ID	CORP) (10039138) CORP) (10039138) CORPANY - MITC COMPANY - MITC (10033165)	db:	Sgrature NOC Project Manager	ame Neal Kaban BER 22 APY. 2021	
KING SALMAN NT MAGTINE INDUST PACCAGE 7 RAS AL-KHAUR RAS AL-KHAUR	2500153-0008 MATERIAL DE		VIBRATION IS	MIN'P.O. NO.	AD-2005-004	VEN	P-JONIT C	Approve	Manune	Gullemaz h	
Project Tittle Location Contract No.	BI/JONs.			EA DUI	MYDP-8	JRER NAME	NE ENTERISES		BB BB	Name: Edwin ( Dete: 7.0. M	
sduetries				Rev, No	0	ANUFACTU	1- STARU	-	4	100	
the Complex for Maritime I	nathan		LCD. Na oty stast K.S.A Domo	REF. SJEWITTAL NO.	KIC-RA-MR-194	900M M	723000009 274000009 2-4000009	Reviewed h	Signature MC Processment	Name: Nadeem Man	
<li>Ali M. Al-Serrar company Representation ing Salman Internation of Services is Al Khair</li>	r. Satman A. Al-Rar	njeci Engineer	NAUTANNI INTRANATINANON Intrana Tanàn, Jac Son O. Bri Fra Son Son Son Francisco Pro-	RESUGNITAL		Description	ACCESSORES ACCESSORES	id by:	The TA:	4-2021	
Name: M Postion: C Project N Location: Ra	: Namer M	Posision: P	A Company: 10 Address: PJ Telifex No:	TATTIMELS W	ğ	Naterial	VIBRATION II	Property	Sgra Kir Beer	Eaugeer Atm	
Ë	Looston: ATTN: Name: Poston: FROM: Company:	FROM	M	-	<u>ه</u>	+			Nem		

Ţ	7	diogram gray	South Aremos	Dire 23/3/3/8	Subimital Code/Discipline.	Architectural Aral Aral Da Mar Europian Arabitectura da	Vermanical Pengla Welding		FOR CLIENT COMMENTS				HIRE TH VESSIN TOWN	for the second se	" pec31.18	I				A REPARTMENT	design of the second	1)ec. 21, K	2:00	maawad By Tte Mar Aladai Subsco			and the second	24/12-12016	
۲	IDIECT	(BAN) TEADING		02/50000					Caulingue/Specification/Standard Brownig	و وسایردهاندا رواند و هدوه	B. Brochurer / Dra.opus		t. Hececure	r Gerkenvestsherand	a 'set Mased / Other		B. Becuret Statings			I. Perseine	* Stet/ular/craint/ craine/ and	3. Ted Repet/Others				Processification		Davie Entripre	P3
•	RAS TAN URA REPINERY CLEAN FUEL PR	REQUEST FOR MATERIAL APPROVAL/VENOOR A	10100-00-090 PD-0014-(mp0)	Centrals and		References internation of United Arvies - 1000-Arvies Land	Subject/Aumo: NAR for Alsonnov isota ttor		Manufacture of Nerody (Supple) (10	Merindacharau:		Marcin Rundam A/A	د. توانیکونور	JOHS GUD RESIDENT REPAINS EST.	Surpler (D hundren: 100351136	Nonutrary Size	WEKCO	Manufacture & Muther	Photo Di Nuradaca: 1/2.		MADUCAT MONAMMENAL SUMME IN MURICIAL	Suppler In Munder: 20045072	Paul 10 Number: N/A	Note: "In second memory was to second and a second sec	10.00 att. Such innis doite for selenting union attending attending	בי אסייניבות אינויים ואיני על לאר געוו <b>ויים.</b> ייסי שערים אינויים איניים איניים איניים איניים איניים איניים איניים איניים איניים	31118-111763, UTTOPIL())), d. # 34078		
	24			TOORISAS ATUM DAS VAUDA	Multure Beaury ( IS Manage	k Chatton:	العر قبيعهم المراجم الم						VIIIATION ISCUATOR	FITTOROUS WOOL	Manas Ukan Janadi MriA										The state of the s	- And a rel	CALLER 1	- A - A -	
		11	į	Ë	5	TOD HAD BE	Lection (Pan	];					-												Ruman Halling		1		

desgual kisila Seedi Arence	b102/12/12 :+044	المقادما الثمام والمعوادين	фектастия    Сіла   bui ding Поннон	Jenediankeak 🎽 Aluhe & weberg Elekstriket 🗍 Instrum-Endelsen Dathers	POR CLIENT COMMUNIS	51	21		DO NOT O VESSATING	Torque L					A CAL COMMENTANY	and a state of the	Sipameri (	2 B. Jon	Referend for TR: Mil. Alekal Second	Stockal pr
HOLECT LIPROVAL (REA)	mrszonac		Are Submitud		רארטעלטיאלע אונקעראיזיאיז אינגאראיי לאראלע אונקעראיז	A, Cordicarta / Dure Steets	B Brouwer/Caldoput	0.0rawiup	E. Hraudum	F Sperificacions / Scandards	di. Tett. Suppert / Citheria	A Cartholis / Day Steps	A Biothern / Catalogues	C.Samake	(thread c	E. Madaurid	E, Seerthadons / Sandards	G Terl Report / Other.		Increase with surface Community       Increase with surfaces       Increase with surfaces       Increase A number       Increase A number       Increase
RAS TANURA RÉHMÉRY (1.6AN FUEL M Request for material approval/vendôr A 10100-00-090-P014-bmp04			Inference Submitted res UNE-MARK (MND AMAR 400)	surject/Area:	Menufactories of Visadas / Sungline / ID	Mu which mer	stantme sats result. Menditoriati () Humble:	Plant to Mumber N/A	Suppliment.	אמאיר קטוני וועואקא דוש וואס נגד.	Septimum mandret: Laarnaa	Miner utility of the second	WECCO	haden udsactament all this redige	March 10 Muserkann: M/A	Supplier.	MARDOOT NON-MANY DAY TRADMG ET.	tuppter ib Runber. 10049177		The discurbants have betweened to primerial conformance with the contrast. Such reales note not in their this selected and this responsibilities under the items plante contrast, nor public 2010 autom any contraction requirements.
	TECNICIS RELIMINAS SAUDIA	McAbaro Bourie / CC Manige		er Subarthen au:	Description of Metadal				-		CERTIFICATION AND A		Interaction levels: N/A						eleminary hourseant base	
jį	ğ	Ë	National R	la cticau) Pan	a la	W.				-									PHONE OF STREET	

) e





# REQUEST FOR TECHNICAL APPROVAL MATERIAL REQUISITION

SUBMITAL COUR ARCHITECTURAL CIML STRUCTURAL FIPINGANECHANICAL	ELECTRICAL COMMUNICATION	Differs .	TERMUS SPECIFICATION SYSTEM	INSPECTION LEVEL	NON INSPECTABLE	DIAL I ACTION	HU COMMENT		semittal and responded Brough		Page 1
ROCEOLINES C	WNGGSDEC. 1	0	T. 30-32 SAMO	NMR FORM	NN	IFOR SAUDI ARAMCO U VIEW / COMMENT / APPRC	HOCEPAN AMM BARAN AMM BARAN MALANANA MALANA MALANA MALANA MALANA MALANAN		be submitted through tran Email,		
SA ENGINERANS S NIA SA ENGINERANS P	DATA SHEETS / DRAV		RE-701013 SH	175		RE	APPENDING A		This document will		
KINATIONAL COMPLEX FOR BES AND SERVICES	SCREPTION		OLATORS	FORM SA	NN	DOR NAME & ID	CORP) (10039138) CORP) (10039138) CORPANY - MITC COMPANY - MITC (10033165)	db:	Sgrature NOC Project Manager	ame Neal Kaban BER 22 APY. 2021	
KING SALMAN NT MAGTINE INDUST PACCAGE 7 RAS AL-KHALF RAS AL-KHALF	2500153-0008 MATERIAL DE		VIBRATION IS	MIN'P.O. NO.	AD-2005-004	VEN	P-JONIT C	Approve	Manune	Gullemaz h	
Project Tittle Location Contract No.	BI/JONs.			EA DUI	MYDP-8	JRER NAME	NE ENTERISES		BB BB	Name: Edwin ( Dete: 7.0. M	
sduetries				Rev, No	0	ANUFACTU	1- STARU	-	4	100	
the Complex for Maritime I	nathan		LCD. Na oty stast K.S.A Domo	REF. SJEWITTAL NO.	KIC-RA-MR-194	900M M	723000009 274000009 274000009	Reviewed h	Signature MC Processment	Name: Nadeem Man	
<li>Ali M. Al-Serrar company Representation ing Salman Internation of Services is Al Khair</li>	r. Satman A. Al-Rar	njeci Engineer	NAUTANNI INTRANATINANON Intrana Tanàn, Jac Son O. Bri Fra Son Son Son Francisco Pro-	RESUGNITAL		Description	ACCESSORES ACCESSORES	id by:	The TA:	4-2021	
Name: M Postion: C Project N Location: Ra	: Namer M	Posision: P	A Company: 10 Address: PJ Telifex No:	TATTIMELS W	ğ	Naterial	VIBRATION II	Property	Sgra Kir Beer	Eaugeer Atm	
Ë	Looston: ATTN: Name: Poston: FROM: Company:	FROM	M	-	<u>ه</u>	+			Nem		

Goowin Austen Johnso	n AECOM	Royal Commiss	sion for AJ-Ula	Nesn	na & Partners
Design Consultant	PIMC	Empl	over	Mai	n Contractor
TECHNICAL SUE	BMISSION	Project No. Sub. Ref. 3459 MAR	Discipline	Contractor Ref. NAP-MEC-MAT-000079	Rev 0ate 00 08-Dec-2021
Subject Reference	20	1000			
GEN-General	DCSB - Oocumer	X ANAH M.	atenia	MS - Method Statemer	u.
SD - Drawing	] TR - Test Report	PRQ-Pre	quilification	OT - Other (Specify)	
Project	: Ashar Develop	ment - New Tented Resc	irt		
Client	: Royal Commiss	ion for Al-Ula (RCU)			
Consultant	: Godwin Auster	Johnson Architects (GA	N)		
Main Contractor	: Nesma & Partr	ers Contracting Co., Ltd	63		
Title & Description	Selection of Vi	bration Isolator for Ex?	naust Fan	Contract Doc. Ref.	3
	Alatan Territor B	ump Group and Buck Br	27.		3469 Ashar Development New
Purpose & Location	water aposter P	and room and Rock Po		spec. sec. and clause	Tent Resort
Manufacturer/ Supplier	STAR LINE			BOQ Item No.	2
Sub Contractor	7.			Drawing Ref.	
Submittal Checklist				in the starting sector	
Tubolited Theast	W. Dofersberg				
Suppler Precault	Scation/Trade ticens	pc-:	OAOC Docu	mont (MS: TTP atz.)	
Brochure/Technic	cal Data		Compliance	Statement (in case of alter	natives proposed)
Reports			5smple		
Previous Project R	eference/ Approvals		Others (Dra	wintgs)	
111000-010				A10	
Contractor's Confirmation			Reason for	Akomaliyo	
Conforms to Spec	execution on as				
Considered to be t	Equal/Batter than Sp	perfied			
Specified					
Annihted by Contractor			Received by Co	multant	
stational for the country of the		1		DECEWED F	OM CONTRACTOR ON
energian of community		10		RECEIVED FR	COMICONTRACTOR ON
		10			
aid Mothrat Ei Ghobushy (I	DA/OC Manager	1.9		09	DEC 2021
aid Mothfat Ei Ghobashy (1	0A/QC Manager	fit	Speakure	GAU	DEC 2021
aid Mothtar Ei Ghobashy (I Signature	QA/QC Manager	Sump	Signature	GAJ Date	DEC 2021 Stamp
aid Mokhtar Ei Ghobushy (1 Signature Material Submitted	DA/OC Manager	Stump	Signature Consultant Cor	Date 05	DEC 2021 Stamp
aid Moshrar Ei Ghobushy () Signature Material Submitted	DA/QC Manager	Stamp	Sectore Consultant Con * No objection * OTY/ type/ m	to the proposed manufa	DEC 2021
aid Mothrat Ei Ghobashy () Signature Material Submitted Note: it will be painter	DA/QC Manager	Stamp re requirement.	Sectore Consultant Con * No objection * QTY/ type/ m material subm	to the proposed manufa nodel of the equipment si ittal / shop dwg.	DEC 2021
aid Mothfar Ei Ghobashy () Signature Material Submitted Note: it will be painter	DA/QC Manager	Stamp	Signature * No objection * QTY/ type/ m material subm * Manufacture	to the proposed manufa nodel of the equipment so ittal / shop dwg. r to comply the project sp	DEC 2021 Stamp Incturer (Star line). ubject to approved pecification for the proposed
aid Methtar Ei Ghobushy () Signature Material Submitted Note: it will be painter	DA/OC Manager	Stamp re requirement.	Sector * No objection * QTY/ type/ m material subm * Manufacture material.	to the proposed manufa nodel of the equipment so ittal / shop dwg. r to comply the project sp	DEC 2021 Stamp Incturer (Star line). ubject to approved pecification for the proposed
aid Mothtar Ei Ghobashy () Signature Moterial Submitted Note: it will be painter	DA/QC Manager	Stump re requirement.	<b>Consultant Con</b> * No objection * QTY/ type/ m material subm * Manufacture material.	to the proposed manufa nodel of the equipment so ittal / shop dwg. r to comply the project so	DEC 2021 Stamp Incturer (Star line). Subject to approved Decification for the proposed
aid Methtar Ei Ghobushy () Signature Material Submitted Note: it will be painter	DA/QC Manager	Stamp re requirement.	Sector * No objection * QTY/ type/ m material subm * Manufacture material.	to the proposed manufa model of the equipment so ittal / shop dwg. r to comply the project sp	DEC 2021 Stamp Incturer (Star line). ubject to approved pecification for the proposed
aid Methtar Ei Ghobushy () Signature Material Submitted Note: it will be painted Onfiemed by	0A/QC Manageri d as per architectua Arch/ Cuil M	Sturnp re requirement.	Sectore * No objection * QTY/ type/ m material subm * Manufacture material.	to the proposed manufa nodel of the equipment so ittal / shop dwg. r to comply the project sp	DEC 2021 Stamp Incturer (Star line). ubject to approved pecification for the proposed
aid Mothtar Ei Ghobushy () Signature Material Submitted Note: it will be painted Onfirmed by rgnature	DA/QE Manageri d as per architectur Arch/ Cuil Arch/ Cuil Arch/ Cuil	Stamp re requirement.	Sector * No objection * QTY/ type/ m material subm * Manufacture material.	to the proposed manufa nodel of the equipment so ittal / shop dwg. r to comply the project sp	DEC 2021 Stamp Incturer (Star line). ubject to approved pecification for the proposed
aid Mothtar Ei Ghobashy () Signature Material Submitted Note: it will be painted Confirmed by Ignature	DA/QE Manageri d as per architectua Arch/ Cuil Acch/ Cuil Cherrit MM	Starnp re requirement.	<b>Consultant Con</b> * No objection * QTY/ type/ m material subm * Manufacture material.	to the proposed manufa nodel of the equipment so ittal / shop dwg. r to comply the project sp	DEC 2021 Stamp Incturer (Star line). ubject to approved pecification for the proposed
aid Mothtar Ei Ghobishy () Signature Material Submitted Note: it will be painted Confirmed by spatiate Larre C Note 2	Arch/ Cuil Arch/ Cuil Arch/ Cuil Arch/ Cuil Cherrit MM 10 DECEMBER 20	Stamp re requirement.	<b>Consultant Con</b> * No objection * QTY/ type/ m material subm * Manufacture material.	to the proposed manufa nodel of the equipment so ittal / shop dwg. r to comply the project so SHOEB AHMED 20.12.2021	DEC 2021 Stamp Incturer (Star line). ubject to approved Decification for the proposed
aid Mothtar Ei Ghobashy () Signature Material Submitted Note: it will be painter Confirmed by righture Larre 2 Nate 2 Nocument Status	Anch/ Cuil Anch/ Cuil	Sturnp re requirement.	* No objection * No objection * QTY/ type/ m material subm * Manufacture material.	to the proposed manufa nodel of the equipment so ittal / shop dwg. r to comply the project sp SHOEB AHMED 20.12.2021	DEC 2021 Stamp Incturer (Star line). Inject to approved Decification for the proposed
aid Mothtar El Ghobashy (1 Signature Material Submitted Note: it will be painter Onfirmed by agnature Jame 2 Noturnent Status	Arch/ Cull Arch/ Cull Arch/ Cull Cherrit MM 0 DECEMBER 20	Stump stump N Structurel 21	Sectors * No objection * QTY/ type/ m * Manufacture material subm * Manufacture material.	to the proposed manufa nodel of the equipment su ittal / shop dwg. r to comply the project sp SHOEB AHMED 20.12.2021	DEC 2021 Stamu Incturer (Star line). Ibject to approved Decification for the proposed Ibj Others
aid Mothtar El Ghobashy () Signature Material Submitted Note: it will be painter Onfirmed by agnature Jane 2 Nocument Status COCE A Approved	Arch/ Cull Arch/ Cull Arch/ Cull Cherrit MM 0 DECEMBER 20	Stump stump N Structurel 21	Sectors * No objection * QTY/ type/ m material subm * Manufacture material.	Annexis to the proposed manufa nodel of the equipment so ittal / shop dwg. r to comply the project sp SHOEB AHMED 20.12.2021	DEC 2021 Stamu Incturer (Star line). ubject to approved pecification for the proposed ID/ Others
aid Mothtar El Ghobashy () Signature Material Submitted Note: it will be painter Confirmed by Agneture Jane 2 Nocument Status Coursent Status Coursent Status	Arch/ Cull Arch/ Cull Arch/ Cull Cherrit MM O DECEMBER 20 CODE I Approved with com Materia Code May P	Stump stump M Structurel 21 aments. Approved Material Oxide	Consultant Con * No objection * QTY/ type/ m material subm * Manufacture material.	to the proposed manufa ments to the proposed manufa nodel of the equipment so ittal / shop dwg. r to comply the project sp SHOEB AHMED 20.12.2021	DEC 2021 Stamp Incturer (Star line). ubject to approved pecification for the proposed ID/ Others
aid Mothtar Ei Ghobashy () Signature Material Submitted Note: it will be painter Onfinined by agnature lane 2 Nocument Status CODE A Approved tenal Onle May Proceed instructor may proceed	DA/QC Manager d as per architectual Arch/ Out Cherrit MM O DECEMBER 20 Contents MM Approved with com Materia Oder May P Contents My P	Stamp re requirement.	Senture • No objection • QTY/ type/ m material subm • Manufacture material.	to the proposed manufa nodel of the equipment so ittal / shop dwg. r to comply the project sp SHOEB AHMED 20.12.2021	DEC 2021 Stamp Incturer (Star line). ubject to approved becification for the proposed ID/ Others CODE E For Information
aid Mothtar Ei Ghobishy (1 Signature Material Submitted Note: it will be painted Sofferned by gnature larre 2 Nocument Status CODE A Approved tenal Onler May Proceed instructor may proceed instructor may proceed instructor may proceed instructor may proceed instructor may proceed	Arch/ Cod Arch/	Stamp re requirement.	Code C	to the proposed manufa nodel of the equipment so ittal / shop dwg. r to comply the project so SHOEB AHMED 20.12.2021	DEC 2021 Stamp Incturer (Star line). ubject to approved Decification for the proposed ID/ Others

5	BIN QURA	Ŀ₹		ABU ALI I REQUES	FISH HATCHERY PROJ BI: 10-00457-0006 ST FOR MATERIAL TECH	IECT – RAS ABU ALI 6 HNICAL APPROVAL	ซู้	Saudi Aramca
TO: ATTN:	Mr. Ghassan Al Hilal Company Representa Offshore Special Proje Mr. Joseph B Hage Sr. Project Engineer Offshore Special Proje	titve ects Division cds Division			Project No. : 10-00457-0006 Contract Number : 6600033949/03 PROJECT TITLE : ABU ALI FISH LOCATION I RAS ABU ALI	A HATCHERY PROJECT	No. of Copies: SPECIFICATIONS REFERENCES Division No. SECTION NO.	SUBMITTAL CODE A ARCHITECHTURAL C CIVIL S STRUCTURAL B V MECHANICAL E ELECTRICAL I INSTRIUMENTATION
FROM:	BIN QURAYAHOLDI Al-Khobar 34484, Sau Tei: 013-868-9569669668 Email: construction	ING COMPANY di Arabia A Fax: 013曲磁路2020 文语 Dinquraya.com					DRAWING REFERENCES: SAUDI ARAMCO STANDARDS:	Shiping 1
NEW SUBMIT	TAL 11	MATERIAL REQU BQ-457-FHP-R	ISITION NO. ITA-0104	REV. NO.	S.A. DUMMY P.O. NO. NA	SA FORM-175 NA	NMR FORM NA	INSPECTION LEVEL
SN	BRIEF DES	CRIPTION State TANT	acone		VENDOR	MANUFACTURER	(FOR SAUDI AR	AMCO USE ONLY)
1 MOUN	ITING PAD; SPRING; VI	IBRATION ISOLATOR	6000001859	10012037	AMIANTIT RUBBER INDUSTRIES	AMIANTIT RUBBER INDUSTRIES		
PAD:	SEPARATOR, RUBBER see attached previous	I PAD; ANTI VIBRATION approvals, for reference.	6000001527	10019992	TECHNO RUBBER CO. JOINT GULF BUSINESS TRD., JGB	TECHNO RUBBER CO. STARLINE ENTERPRISES		
				10003059	SARA INT'L FACTORY FOR DUCT MARIAM TRADING CO. & PARTNERS			
						-	Vio Objection Correct & Resubmit	No Objection as noted
Note: Please	ese untached Prelimin ULK MATERIAL)	ary MTO, for reference					Approval is only for general conformar review does not relieve the Contractor the Contract nor authorize	nce with the contract documents. Such that its responsibility under the terms of ad additional compensation.
Frepared by:	Reviewed 1	sy:	3			Fastewed Nr (Sap)(T)	Approved t	by: (SAPINT)
Xin	0		U.L		and the appendix	· O Weer	12	d freque
Name: Wasim Al	ringineer Rook C rram Nime Ray	C Supervisor C heel Ahmed Name: Em	AlgC Manager ad Bukhamseen	N N	active Minuger Project Mana In Jefful Name: Baud Anthen Date: Baud Anthen	ger Projectalist Name: Haney Hancon Date: 02/08/2022	Name: Joseph B Hage Date: 02/08/2022	d Engineer
	2	and look (1)			dillas			

Page 1 of 1

profer. ASMAEL (**3**8.) ALMOUSA Ffilton 0021 CLIENT OPER, CONSUL EHAF CONSULTING OUTGOING CORRESPONDANCE/DOCUMENT LOG Corresp Corresp 570m Τð CATEGORY Description Remarks. Date No. M-HVAC-1999-057 HCW+TR-25-INFRITA 6ASE (FOR CHILLED WATER PUMPS) ASM-MATERIAL MARCH AMĞ ANNAAHI AAN SHEMILTAE 2019 0021 STARLINE, INDIA 2013 \*\*\*\*\*\*\*\*\*\*\*\*\* (LEGEND: A - Approved / AAM - Approved as Noted 1 R - Rejected, Not Approved / R&R - Nevsed & Kesubmin SAC ( See Abacted Comment) AMG - ADMIN / ENGR'S Released & Approved By: 2 6 MAR 2019 PHILCENTENO ENGR. A AMG - DOCS CONT.) (AMG - MECH ENGR) ENGR. GLENN ZARA ENGR. TAUFIQUE KHAN AR. MARK POLONIO (AMG - ELECT ENGR) (AMG - CIVIL ENGR.) (AMG - ARCH) RECEIVED BY: ASMAEL

Page 1 of 1





# Certifications

Page 1 of 1

Head Office: Mars Complex, First Floor , 38 / 791 - Poothole Road , Thrissur , Kerala, INDIA - 680 004 Factory: Sree Sai Krithika Industrial Estate, 4 / 293 , S.F. No. 221 & 91, Seerapalayam, Podipalayam Post, Coimbatore, Tamil Nadu, INDIA - 641 105

Phone : (91) (487) 238 5001 , 238 5002 Email : purchase@starline.in

## CERTIFICATE OF COMPLIANCE

Certificate Number Report Reference Date

EX28297 EX28297-20201216 2020-December-22

HANGERS, PIPE

Issued to: Starline Enterprises Sree Sai Krithika Industrial Estate, 4 / 293, SF No. 221 & 91, Seerapalayam, Podipalayam Post Coimbatore Tamil Nadu, 641105 IN

This is to certify that representative samples of

f See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/CAN/UL 203 - Standard for Pipe Hanger Equipment for Fire Protection Service.

 Additional Information:
 See the UL Online Certifications Directory at

 <a href="https://iq.ulprospector.com">https://iq.ulprospector.com</a> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

4 mally

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/.

## CERTIFICATE OF COMPLIANCE

Certificate Number Report Reference Date

EX28297 EX28297-20201216 2020-December-22

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

USL - Pipe Hangers.

Model: CHS13, CHS19, CHS25, CHS30, CHS40, CHS50, CHS65, CHS75, CHS88, CHS100 CHS125, CHS150, CHS200, SSC022, SSC028, SSC035, SSC040, SSC048, SSC060, SSC075 SSC090, SSC115, SSC140, SSC168

Bampleg



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <a href="http://ul.com/aboutul/locations/">http://ul.com/aboutul/locations/</a>



# **Certificate of Compliance**

This certificate is issued for the following:

### Pipe Hanger Components for Automatic Sprinkler Systems

Model: CHS Clevis Hanger

Model: SSC Loop Hanger

**Prepared for:** 

Starline Enterprises Sree Sai Krithika Industrial Estate 4/293, SF. No 221/91 Seerapalayam Post – Podipalayam, Coimbatore, Tamil Nadu, 641105 India

Approval Standard: FM 1951, 1952, 1953 (December 2016)

Approval Identification: PR455931

Approval Granted: 13 November 2023

To verify the availability of the Approved product, please refer to <u>www.approvalguide.com</u>

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

David B. Fuller VP, Manager – Fire Protection FM Approvals 1151 Boston-Providence Turnpike Norwood, MA 02062





Member of the FM Global Group





**Certificate of Registration** 

This is to certify that



# **STARLINE ENTERPRISES**

Sree Sai Krithika Industrial Estate, 4/293, SF No.221 & 91, Seerapalayam, Bodipalayam(Post), Coimbatore-641105, Tamil Nadu, India

has been independently assessed by QRO and is compliant with the requirement of:

# ISO 9001:2015 Quality Management System

For the following scope of activities:

### MANUFACTURE AND SUPPLY OF ENGINEERING PRODUCTS

Date of initial registration: 06th June 2023 Date of this Certificate: 22nd May 2024 Certificate Expiry: 05th June 2025 Recertification due: 05th June 2026

Certificate Number: 305023060639Q







Head of Certification

Validity of this certificate is subject to annual surveillance audits to be done successfully on or before 365 days from date of the audit. (In case surveillance audit is not allowed to be conducted; this certificate shall be suspended / withdrawn). The Validity of this certificate can be verified at www.qrocert.org

This certificate of registration remains the property of QRO Certification LLP, and shall be returned immediately upon request.